Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards

504th Meeting

Docket Number: (not applicable)

Location: Rockville, Maryland

Date: Thursday, July 10, 2003

Work Order No.: NRC-997 Pages 1-328

NEAL R. GROSS AND CO., INC. Court Reporters and Transcribers 1323 Rhode Island Avenue, N.W. Washington, D.C. 20005

1 UNITED STATES OF AMERICA 2 NUCLEAR REGULATORY COMMISSION 3		1
3 4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS (ACRS) 5 504th MEETING 6 +++++ 7 THURSDAY, JULY 10, 2003 8 +++++ 9 ROCKVILLE, MARYLAND 10 The ACRS met at the Nuclear Regulatory 11 Commission, Two White Flint North, Room T2B3, 11545 12 Rockville Pike, at 8:30 a.m., Mario V. Bonaca, 13 Chairman, presiding. 14 COMMITTEE MEMBERS: 15 MARIO V. BONACA, Chairman 16 GRAHAM B. WALLIS, Vice Chairman 17 STEPHEN L. ROSEN, Member-At-Large 18 GEORGE E. APOSTOLAKIS, Member 19 F. PETER FORD, Member 20 THOMAS S. KRESS, Member 21 GRAHAM M. LEITCH, Member 22 DANA A. POWERS, Member 23 VICTOR H. RANSOM, Member 24 WILLIAM J. SHACK, Member	1	UNITED STATES OF AMERICA
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS (ACRS) 504th MEETING + + + + + + THURSDAY, JULY 10, 2003 + + + + + + ROCKVILLE, MARYLAND The ACRS met at the Nuclear Regulatory Commission, Two White Flint North, Room T2B3, 11545 Rockville Pike, at 8:30 a.m., Mario V. Bonaca, Chairman, presiding. COMMITTEE MEMBERS: MARIO V. BONACA, Chairman GRAHAM B. WALLIS, Vice Chairman STEPHEN L. ROSEN, Member-At-Large GEORGE E. APOSTOLAKIS, Member F. PETER FORD, Member THOMAS S. KRESS, Member GRAHAM M. LEITCH, Member DANA A. POWERS, Member VICTOR H. RANSOM, Member WILLIAM J. SHACK, Member	2	NUCLEAR REGULATORY COMMISSION
5 504th MEETING 6 + + + + + + 7 THURSDAY, JULY 10, 2003 8 + + + + + + 9 ROCKVILLE, MARYLAND 10 The ACRS met at the Nuclear Regulatory 11 Commission, Two White Flint North, Room T2B3, 11545 12 Rockville Pike, at 8:30 a.m., Mario V. Bonaca, 13 Chairman, presiding. 14 COMMITTEE MEMBERS: 15 MARIO V. BONACA, Chairman 16 GRAHAM B. WALLIS, Vice Chairman 17 STEPHEN L. ROSEN, Member-At-Large 18 GEORGE E. APOSTOLAKIS, Member 19 F. PETER FORD, Member 20 THOMAS S. KRESS, Member 21 GRAHAM M. LEITCH, Member 22 DANA A. POWERS, Member 23 VICTOR H. RANSOM, Member 24 WILLIAM J. SHACK, Member	3	+ + + +
THURSDAY, JULY 10, 2003 THE ACRS met at the Nuclear Regulatory Commission, Two White Flint North, Room T2B3, 11545 Rockville Pike, at 8:30 a.m., Mario V. Bonaca, Chairman, presiding. COMMITTEE MEMBERS: MARIO V. BONACA, Chairman GRAHAM B. WALLIS, Vice Chairman STEPHEN L. ROSEN, Member-At-Large GEORGE E. APOSTOLAKIS, Member F. PETER FORD, Member THOMAS S. KRESS, Member GRAHAM M. LEITCH, Member DANA A. POWERS, Member VICTOR H. RANSOM, Member WILLIAM J. SHACK, Member	4	ADVISORY COMMITTEE ON REACTOR SAFEGUARDS (ACRS)
THURSDAY, JULY 10, 2003 + + + + + + PROCKVILLE, MARYLAND The ACRS met at the Nuclear Regulatory Commission, Two White Flint North, Room T2B3, 11545 Rockville Pike, at 8:30 a.m., Mario V. Bonaca, Chairman, presiding. COMMITTEE MEMBERS: MARIO V. BONACA, Chairman GRAHAM B. WALLIS, Vice Chairman GRORGE E. APOSTOLAKIS, Member F. PETER FORD, Member THOMAS S. KRESS, Member GRAHAM M. LEITCH, Member DANA A. POWERS, Member VICTOR H. RANSOM, Member WILLIAM J. SHACK, Member	5	504th MEETING
8 9 ROCKVILLE, MARYLAND 10 The ACRS met at the Nuclear Regulatory 11 Commission, Two White Flint North, Room T2B3, 11545 12 Rockville Pike, at 8:30 a.m., Mario V. Bonaca, 13 Chairman, presiding. 14 COMMITTEE MEMBERS: 15 MARIO V. BONACA, Chairman 16 GRAHAM B. WALLIS, Vice Chairman 17 STEPHEN L. ROSEN, Member-At-Large 18 GEORGE E. APOSTOLAKIS, Member 19 THOMAS S. KRESS, Member 20 THOMAS S. KRESS, Member 21 GRAHAM M. LEITCH, Member 22 DANA A. POWERS, Member 23 VICTOR H. RANSOM, Member 24 WILLIAM J. SHACK, Member	6	+ + + +
PROCKVILLE, MARYLAND The ACRS met at the Nuclear Regulatory Commission, Two White Flint North, Room T2B3, 11545 Rockville Pike, at 8:30 a.m., Mario V. Bonaca, Chairman, presiding. COMMITTEE MEMBERS: MARIO V. BONACA, Chairman GRAHAM B. WALLIS, Vice Chairman STEPHEN L. ROSEN, Member-At-Large GEORGE E. APOSTOLAKIS, Member F. PETER FORD, Member THOMAS S. KRESS, Member GRAHAM M. LEITCH, Member DANA A. POWERS, Member VICTOR H. RANSOM, Member WILLIAM J. SHACK, Member	7	THURSDAY, JULY 10, 2003
The ACRS met at the Nuclear Regulatory Commission, Two White Flint North, Room T2B3, 11545 Rockville Pike, at 8:30 a.m., Mario V. Bonaca, Chairman, presiding. COMMITTEE MEMBERS: MARIO V. BONACA, Chairman GRAHAM B. WALLIS, Vice Chairman STEPHEN L. ROSEN, Member-At-Large GEORGE E. APOSTOLAKIS, Member F. PETER FORD, Member THOMAS S. KRESS, Member GRAHAM M. LEITCH, Member DANA A. POWERS, Member VICTOR H. RANSOM, Member WILLIAM J. SHACK, Member	8	+ + + +
Commission, Two White Flint North, Room T2B3, 11545 Rockville Pike, at 8:30 a.m., Mario V. Bonaca, Chairman, presiding. COMMITTEE MEMBERS: MARIO V. BONACA, Chairman GRAHAM B. WALLIS, Vice Chairman STEPHEN L. ROSEN, Member-At-Large GEORGE E. APOSTOLAKIS, Member F. PETER FORD, Member THOMAS S. KRESS, Member GRAHAM M. LEITCH, Member DANA A. POWERS, Member VICTOR H. RANSOM, Member WILLIAM J. SHACK, Member	9	ROCKVILLE, MARYLAND
Rockville Pike, at 8:30 a.m., Mario V. Bonaca, Chairman, presiding. COMMITTEE MEMBERS: MARIO V. BONACA, Chairman GRAHAM B. WALLIS, Vice Chairman STEPHEN L. ROSEN, Member-At-Large GEORGE E. APOSTOLAKIS, Member F. PETER FORD, Member THOMAS S. KRESS, Member GRAHAM M. LEITCH, Member DANA A. POWERS, Member VICTOR H. RANSOM, Member WILLIAM J. SHACK, Member	10	The ACRS met at the Nuclear Regulatory
Chairman, presiding. COMMITTEE MEMBERS: MARIO V. BONACA, Chairman GRAHAM B. WALLIS, Vice Chairman STEPHEN L. ROSEN, Member-At-Large GEORGE E. APOSTOLAKIS, Member F. PETER FORD, Member THOMAS S. KRESS, Member GRAHAM M. LEITCH, Member DANA A. POWERS, Member VICTOR H. RANSOM, Member WILLIAM J. SHACK, Member	11	Commission, Two White Flint North, Room T2B3, 11545
MARIO V. BONACA, Chairman GRAHAM B. WALLIS, Vice Chairman STEPHEN L. ROSEN, Member-At-Large GEORGE E. APOSTOLAKIS, Member F. PETER FORD, Member THOMAS S. KRESS, Member GRAHAM M. LEITCH, Member DANA A. POWERS, Member VICTOR H. RANSOM, Member WILLIAM J. SHACK, Member	12	Rockville Pike, at 8:30 a.m., Mario V. Bonaca,
MARIO V. BONACA, Chairman GRAHAM B. WALLIS, Vice Chairman STEPHEN L. ROSEN, Member-At-Large GEORGE E. APOSTOLAKIS, Member F. PETER FORD, Member THOMAS S. KRESS, Member GRAHAM M. LEITCH, Member DANA A. POWERS, Member VICTOR H. RANSOM, Member WILLIAM J. SHACK, Member	13	Chairman, presiding.
GRAHAM B. WALLIS, Vice Chairman STEPHEN L. ROSEN, Member-At-Large GEORGE E. APOSTOLAKIS, Member F. PETER FORD, Member THOMAS S. KRESS, Member GRAHAM M. LEITCH, Member DANA A. POWERS, Member VICTOR H. RANSOM, Member WILLIAM J. SHACK, Member	14	COMMITTEE MEMBERS:
STEPHEN L. ROSEN, Member-At-Large GEORGE E. APOSTOLAKIS, Member F. PETER FORD, Member THOMAS S. KRESS, Member GRAHAM M. LEITCH, Member DANA A. POWERS, Member VICTOR H. RANSOM, Member WILLIAM J. SHACK, Member	15	MARIO V. BONACA, Chairman
GEORGE E. APOSTOLAKIS, Member F. PETER FORD, Member THOMAS S. KRESS, Member GRAHAM M. LEITCH, Member DANA A. POWERS, Member VICTOR H. RANSOM, Member WILLIAM J. SHACK, Member	16	GRAHAM B. WALLIS, Vice Chairman
19 F. PETER FORD, Member 20 THOMAS S. KRESS, Member 21 GRAHAM M. LEITCH, Member 22 DANA A. POWERS, Member 23 VICTOR H. RANSOM, Member 24 WILLIAM J. SHACK, Member	17	STEPHEN L. ROSEN, Member-At-Large
THOMAS S. KRESS, Member GRAHAM M. LEITCH, Member DANA A. POWERS, Member VICTOR H. RANSOM, Member WILLIAM J. SHACK, Member	18	GEORGE E. APOSTOLAKIS, Member
GRAHAM M. LEITCH, Member DANA A. POWERS, Member VICTOR H. RANSOM, Member WILLIAM J. SHACK, Member	19	F. PETER FORD, Member
DANA A. POWERS, Member VICTOR H. RANSOM, Member WILLIAM J. SHACK, Member	20	THOMAS S. KRESS, Member
VICTOR H. RANSOM, Member WILLIAM J. SHACK, Member	21	GRAHAM M. LEITCH, Member
WILLIAM J. SHACK, Member	22	DANA A. POWERS, Member
	23	VICTOR H. RANSOM, Member
JOHN D. SIEBER, Member	24	WILLIAM J. SHACK, Member
	25	JOHN D. SIEBER, Member

1	ACRS STAFF PRESENT:
2	JOHN T. LARKINS, Executive Director -
3	ACRS/ACNW, Designated Federal Official
4	SHER BAHADUR, Associate Director - ACRS/ACNW
5	HOWARD J. LARSON, Special Assistant ACRS/ACNW
б	SAM DURAISWAMY, Technical Assistant ACRS/ACNW
7	MIKE SNODDERLY, Senior Staff Engineer
8	MAGGALEAN W. WESTON, Staff Engineer
9	RALPH CARUSO, ACRS Staff
10	NRC STAFF PRESENT:
11	FRED BURROWS, NMSS/FCSS/FM
12	SMANTHA CRANE, RES/DET
13	AMY CUBBAGE, NRR/DRIP/NRL
14	KATHY HARVEY GIBSON, NNSS/FCSS/SPIB
15	FRANK GILLESPIE
16	HERMAN GRAVES, III
17	JAMES HAN, RES/DSARE/SMSAB
18	MARY K. HILEMAN, RES/DSARE
19	BAKR IBRAHIM, NMSS/DCOM
20	T.C. JOHNSON, NMSS/FCSS
21	PHILIP JUSTUS, NMSS/WM/HLWB
22	GARY KAPLAN
23	JOEL KLEIN
24	JOEL KRAMER NMSS/FCSS/SPIB
25	RALPH LANDRY, NRR/DSSA/SRXB

		J
1	NRC STAFF PRESENT: (cont.)	
2	STEVE LaVIE, NRR/DSSA/SPSB	
3	ALAN LEVIN, RES/DD	
4	STRANLAI LU, NRR/DSSA/SXRB	
5	GARY MIZU, NRI-OGC	
6	JAMES E. MORRIS, NMSS/INMS/RGB	
7	ALEXANDER MURRAY, NMSS/FCSS/SPIB	
8	ANDREW PERSINKO, NMSS/FCSS/SPIB	
9	MUHAMMAD M. RAZZAQUE, NRR/DSSA/SRXB	
10	BRIAN RICHTER, NRR/DRIP/RPRP	
11	BRIAN SMITH, NMSS/FCSS/SPIB	
12	WILKINS SMITH, NMSS/FCSS/SPIB	
13	JOHN STAMATAKOS	
14	JOSEPH STAUDENMEIER, RES/DSARE/SMSAB	
15	BRIAN THOMAS, NRR/DRIP/FRAS	
16	GEORGE THOMAS, NRR/DSSA/SRXB	
17	ALI TABATABAI, ACRS (LINK)	
18	EDWARD D. THROM, NRR/DSSA/SPSB	
19	SPYROS TRAIFORDS, ACRS (LINK)	
20	CHRISTOPHER S. TRIPP, NMSS/FCSS/SPIB	
21	BILL TROSKOSKI, NMSS/FCSS/SPIB	
22	REX WESCOTT, NMSS/FCSS/SPIB	
23	ALSO PRESENT:	
24	LEE ABRAMSON, RES/DRAA/PRAB	
25	DAVID ALBERSTEIN, DOE	
٠		

	4
1	BENNETT BEACY, RES/DRAA/PRAB
2	ED BRABAZON, DCS
3	ARTHUR BUSLIK, RES/DRAA/PRAB
4	NANCY CHAPMAN, SERCH Bechtel
5	BOB FOSTER, DCS
6	ROBERT GAMBLE, GE
7	TEKIA V. GOVAN
8	HOSSEIN HAMSEHEE, RES/DRAA
9	LANE HAY, SERCH Bechtel
10	JAMIE JOHNSON, DOE
11	MARK KLOSKY, DCS
12	JUNICHI KURAKAMI, Japan Nuclear Fuel Cycle
13	Development Institution
14	EILEEN McKENNA, NRR/DRIP/RPRP
15	PAIGE NEGRES, GE
16	SCOTT NEWBERY, RES/DRAA
17	ALEX POLENSKY, Morgon, Lewis & Bockics, LLP
18	ATAMBIR RAO, GE
19	TOM ST. LOUIS, DCS
20	SAM THOMAS, DOE/WNSA
21	TOMMY TOUCHSTONE, DCS
22	ROBERT L. TREGONING, RES/DET
23	GEIT VORA, RES/DET/MEB
24	DAVID WEROER, MPR Associates/DOE
25	STEPHEN ZAH, DOE

	5
1	C-O-N-T-E-N-T-S
2	Opening Remarks by the ACRS Chairman 7
3	Mixed Oxide Fuel Fabrication Facility
4	Andrew Persinko 10
5	Gary Kaplan
6	Christopher Tripp 47
7	Rex Wescott
8	Alexander Murray 87
9	Andrew Persinko 106
10	Proposed Criteria for the Treatment of 119
11	Individual Requirements in Regulatory Analyses
12	Brian Richter
13	ESBWR Pre-Application Review
14	Amy Cubbage
15	Atambir Rao
16	Expert Elicitation in Support of 10 CFR 50.46 . 244
17	Robert Tregoning 246
18	Adjourn
19	
20	
21	
22	
23	
24	
25	

1	P-R-O-C-E-E-D-1-N-G-S
2	(8:31 a.m.)
3	CHAIRMAN BONACA: Good morning. The
4	meeting will now come to order.
5	This is the second day of the 504th
6	meeting of the Advisory Committee on Reactor
7	Safeguards. During today's meeting the Committee will
8	consider the following: Mixed Oxide Fuel Fabrication
9	Facility, ESBWR pre-application review, proposed
10	criteria for the treatment of individual requirements
11	of regulatory analysis, expert solicitations report
12	for risk-informed events, Part 50.46, and proposed
13	ACRS reports. A portion of this meeting will be
14	closed to discuss the proposed ACRS Report on
15	Safeguards and Security.
16	This is meeting is being conducted in
17	accordance with the provisions of the Federal Advisory
18	Committee Act.
19	Dr. John Larkins is the Designated Federal
20	Official for the initial portion of the meeting.
21	We have received no written comments or
22	requests for time to make oral statements from members
23	of the public regarding today's sessions.
24	A transcript of portions of this meeting

is being kept, and it is requested that the speakers

1 use one of the microphones, identify themselves, and speak with sufficient clarity and volume so that they 2 3 can be readily heard. 4 I would like to announce a change in the 5 agenda. The agenda item regarding the ESBWR preapplication review, which was scheduled to be held 6 7 between 8:35 and 10:30 a.m., is now scheduled between 12:45 and 2:45 p.m. The agenda item regarding Mixed 8 Oxide Fuel Fabrication Facility is now scheduled to be 9 held between 8:35 a.m. and 10:30 a.m. 10 11 Before we proceed with the meeting, I 12 would like to begin with some items of current interest. First of all, we have a number of people to 13 14 welcome on board. 15 We have a summer intern, Gilena Monroe, will with us 16 be for the summer 17 Unfortunately, she's coming today and then she is leaving before the ACRS meets again. So it's going to 18 19 be a short --20 (Laughter.) 21 We're glad to see you here. Welcome 22 onboard. 23 We have two Senior Staff Engineers joining 24 One is Dr. Bhagwat B. Jain. Good morning. will join us as well, effective July 15th. 25

1 going to be part of the staff. 2 The other person is Marvin Sykes. He also 3 is going to be a Senior Staff Engineer with us. 4 Welcome on board. 5 Another issue I would like to bring your attention to is items of interest. There are quite a 6 7 few items of interest there. 8 First οf all, you will find NRC 9 announcements, quite a bit of organization and 10 management changes that may be of interest to you. 11 We have a couple of staff requirement 12 memoranda you want to look at, a number of speeches, operating plant issues, and an interesting letter and 13 14 the congressional correspondence where Chairman Diaz 15 has required evaluate the potential been to efficiencies that would be gained by consolidating or 16 eliminating the Regional Offices, dated June 26th, 17 2003. You may find that of interest. 18 With that, I will move to the first item 19 20 the agenda, which is the Mixed Oxide Fuel 21 Fabrication Facility, and Dr. Powers will lead us 22 through this presentation. 23 I will. MEMBER POWERS: I will try. 24 CHAIRMAN BONACA: He will try.

MEMBER POWERS:

25

Members should turn to

Item 4 in their notebook, and you'll see that we have on the agenda about two hours to cover a variety of topics.

Last month we gave you a thumbnail sketch of all that's been going on in connection with this Mixed Oxide Fuel Fabrication Facility, highlighted some of the issues and findings from the Subcommittee meetings, and today we're going to take some of the central features of those items and go into them in some depth.

Right now the staff is proceeding along on a plan to issue a Safety Evaluation Report in September. They have some few open items that we will discuss. I believe the plan is to issue an SER in September, regardless of the resolution of those open items, though, quite frankly, I'm very optimistic that we will close those.

I propose deferring any letter from this Committee on the SER or the application until September, unless we identify some fault in the current ongoing activities that we think need to be commented on in the interim. Quite frankly, I don't think there's anything of that type.

We have a jam-packed two hours here of a lot of stuff, much of which you're going to have, at

1	best, a passing familiarity with, whether you've
2	derived it from previous presentations or your own
3	reading on this. We're going to go fairly quickly
4	through this material. I'm going to be rigid in
5	enforcing time schedules. So I urge speakers to move
6	to the salient points with some confidence that,
7	despite their advancing ages, most of the members can,
8	in fact, read the viewgraphs and the associated
9	material.
10	With that, I will ask Drew Persinko if he
11	can start us off on this issue and outline what we're
12	going to be hearing here.
13	CHAIRMAN BONACA: Go ahead, Drew.
14	MR. PERSINKO: Good morning. My name Drew
15	Persinko, and I am the MOX Project Manager in the
16	Office of Nuclear Material Safety and Safeguards.
17	First, I would like to thank the Committee
18	for accommodating the rescheduling of this session,
19	due to some unforeseen events that have occurred.
20	I'm going to give some brief introductory
21	remarks before we get into the real meat of the
22	presentation, the real hard-core technical issues, but
23	I think it's important to get kind of an overview of
24	the MOX facility.
25	Depicted in this slide is both the

geographical and jurisdictional boundaries for the MOX facility as well as the Pit Disassembly and Conversion Facility. As you can see, it's depicted that weaponsgrade plutonium will arrive at the Pit Disassembly Conversion Facility, which is under the jurisdiction of the Department of Energy. The material, the powered plutonium oxide, that comes out of the PDCF is planned to arrive at the MOX Fuel Fabrication Facility, which is where the NRC becomes involved in the project. The NRC is responsible for licensing the Mixed Oxide Fuel Fabrication Facility, and it's also responsible for the reactor side of the project, too, which involves processing, reviewing the MOX fuel into Currently, the Catawba and McGuire the reactors. Reactors are the two reactors that are planned for the project. As you can see on the facility, the MOX Fuel Fabrication Facility is in fairly close proximity to the PDCF. Both are located on the Savannah River site. MEMBER WALLIS: I think there's also a recycling of waste back to the DOE? MR. PERSINKO: Correct. The waste from

the facility is temporarily stored at the Fuel Fab

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

Facility, and then it's transferred back to DOE on the Savannah River site for processing. This is just to give you the high-level picture of location and geographical boundaries.

What's not shown on here, though, is also about a year ago there was a change in the project. Some of the material will be coming to the MOX facility that was previously destined to be immobilized. So it will be coming to the MOX Fuel Fabrication Facility and not going through the PDCF. That's not shown on this slide, though.

We just want to depict a high-level view of the process. The first three boxes on the top are the aqueous polishing part of the process, the wet side of the process. It's the purpose of this is to further purify the plutonium dioxide that's received at the facility.

This is similar to the process that is used at the La Hague plant in France. It involves dissolving the plutonium oxide in a nitric acid using silver as a catalyst. The petroleum nitrate is then purified, removing impurities such as americium and gallium and uranium. It's using a solvent-extraction process in post columns. It also involves recovering the solvent -- extracting the Pu or generating the

1 solvent and recycling the nitric acid. 2 Then there is the conversion part of it 3 where the material is converted back to a plutonium 4 oxide through oxical cination and precipitation. 5 this point the plutonium powder is blended with depleted uranium oxide, and the bottom part of this 6 7 slide is the dry side of the process, which is similar to the Melox, the process that's used at the Melox 8 facility in southern France. 9 It involves blending the plutonium oxide 10 11 with the depleted uranium oxide in two-step blending, 12 and it is much the same as a fuel fab facility. It is pressed into pellets. Pellets are inserted into rods, 13 14 and the rods are made into assemblies, and then that's 15 transported to the reactors. The licensing --16 MEMBER LEITCH: There's a statement made 17 in some of our reading that says, "The alternate 18 19 feedstock, the diversity of impurities and the level 20 of impurities is higher." Is there any precedent for 21 processing this kind of material? In other words, do 22 they do something like that in France or --23

> situation? **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS

> > 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

MEMBER LEITCH: -- is this a unique

MR. PERSINKO: No.

24

1 MR. PERSINKO: I don't know about the DOE. 2 They may be doing it at the DOE, but in France they 3 reprocess the spent fuel, and they're not dealing with 4 weapons-grade plutonium. They're dealing with spent 5 fuel, and it's a different mixture in France than what's here. 6 7 MEMBER POWERS: I would inject that the 8 basic chemical process can be used to purify stuff 9 that's real, honest-to-God garbage. I mean it's a robust recovery processing technology that's been 10 11 developed. 12 MEMBER LEITCH: So we ought not particularly concerned, then, about the level 13 14 impurities or the diverse nature of those impurities? 15 MR. PERSINKO: Well, we have looked at it as part of our chemical review, except you'll see the 16 17 open items you have later, but they're not directed specifically at the alternate feedstock. It's just 18 19 concerns we have with the process that's 20 regardless of alternate feedstock. 21 MEMBER POWERS: I think it's safe to say 22 that it complicates the operation of the facility, 23 which may be more of a concern in the second stage of 24 the process. It's also safe to reiterate Peter's

concern about the issues of material corrosion in the

1 system that gets exacerbated by any time you have a 2 diversity of chemicals in the system. 3 MEMBER LEITCH: Okay. 4 MEMBER POWERS: So I wouldn't ignore it. 5 MR. PERSINKO: The licensing of facility is being performed under -- although there's 6 7 several regulations that do apply, the primary regulation that applies is the 10 CFR Part 8 Domestic Licensing of Special Nuclear Material. 9 10 For plutonium facilities, a two-step 11 process is permitted, and that is what we are doing. 12 There is an approval, a construction authorization approval, a construction authorization, and then 13 14 there's a second review, which is the operation and 15 the possession of special nuclear material. We are currently only at the construction 16 17 step right now. That's all we're talking about right 18 now. 19 70 requires for the start 20 construction of a plutonium facility that the NRC 21 approves the design bases of the principal structure, 22 systems, and complements. I emphasize design bases 23 because that's all we're really -- that is what we are 24 required to review and that is what we have been

reviewing.

1 So, assuming a favorable decision for 2 construction, the operating license application will be at a lower level of detail than what we are 3 4 currently reviewing because the regulations only 5 require design basis at this point. It also requires a quality assurance 6 7 program be approved. I would like to point out that the regulation in Part 70 does require that for a 8 9 plutonium facility that the quality assurance program be an Appendix B program, similar to or the same as 10 11 reactors. 12 We have reviewed and approved the program for the facility already, and it requires that 13 14 an Environmental Impact Statement be performed. 15 have issued a draft EIS. We received numerous comments on it. We issued a draft EIS. We received 16 17 numerous comments on it, and we are currently in the process of addressing those comments. 18 We plan to 19 issue a final EIS in September. 20 MEMBER LEITCH: That QA plan you discussed is for the operations phase? 21 I mean, for the 22 construction phase only? 23 MR. PERSINKO: For the construction phase, 24 procurement. It's not operations, but it includes

more than strictly construction. Also, I believe it

1	covers procurement as well.
2	MEMBER LEITCH: But there will be another
3	QA plan for operations?
4	MR. PERSINKO: I think it will be updated.
5	It will be updated for operations.
6	MEMBER LEITCH: And I suppose one of the
7	things that concerns me is the qualification and
8	training and staffing of the plant, the facility.
9	They will all be issues that will be discussed in the
10	operating phase?
11	MR. PERSINKO: Well, they will be issues
12	in the operating phase, but I think there's also
13	issues about training now that we look at as well, to
14	make sure that it has the right training aspects of it
15	currently as well and the right qualifications.
16	In fact, it's not part of the QA well,
17	it's related to the QA plan, but that was one of the
18	issues in the criticality area that we looked at. But
19	the QA plan does address the 18 criteria that are in
20	the Appendix B, in QA 1, Appendix B. But it will be
21	updated for operations.
22	MEMBER LEITCH: Okay.
23	MEMBER KRESS: Does the EIS deal with
24	transportation issues?
25	MR. PERSINKO: Yes, it does.

1 I just want to point out the last bullet: 2 "Determine principal structure, systems, components versus the term `items relied on for 3 4 safety.'" Sometimes we forget ourselves and we use 5 those terms interchangeably. So if we do, bear with 6 us. 7 The term "principal structure, systems, and components, "also referred to as PSSCs, is a term 8 9 that's applicable to construction. It's in the regulation that applies to the construction of the 10 11 facility. The term "items relied on for safety," 12 often called IRFS, is a term that will be used at the license application, the operational phase, possession 13 14 and use phase. 15 It just has to do with the terms in the The two are very similar in nature. 16 regulation. 17 PSSCs for this project primarily have been proposed at The IRFSs are expected to be, 18 a systems level. assuming a favorable authorization, the IRFSs are 19 20 expected to be at more of a component level. 21 MEMBER APOSTOLAKIS: So the PSSCs are what 22 we would call safety-related SSCs in reactors? Is it 23 the same thing? 24 MR. PERSINKO: It's similar, yes, I think

It's similar. We don't use the term "safety-

so.

1	related," but I think it has a similar
2	MEMBER APOSTOLAKIS: Yes, that's why I'm
3	asking.
4	MR. PERSINKO: Design bases, I want to
5	just emphasize once again that that's what we're
6	looking at, per the regulations. The definition we
7	have used is the definition that's in 50.2.
8	MEMBER APOSTOLAKIS: So this exists now?
9	I don't understand. You say
10	MR. PERSINKO: What's that?
11	MEMBER APOSTOLAKIS: "information which
12	identifies the specific functions to be performed."
13	MR. PERSINKO: That's correct. That was
14	what's in the construction authorization request.
15	MEMBER APOSTOLAKIS: Okay.
16	MR. PERSINKO: That's what we are
17	reviewing right now.
18	The next phase: This is the heart, I
19	would say, of 10 CFR Part 70. I think you've had
20	discussions with other people from NRC about Part 70
21	and the performance requirements. It's not a risk-
22	based approach; it's a risk-informed approach, whereby
23	in the accident scenarios you have consequences on one
24	axes and likelihoods on the other.
25	This is in the revised Part 70. It

1	applies
2	MEMBER WALLIS: This jargon about "highly
3	unlikely" means absolutely nothing to me.
4	MEMBER APOSTOLAKIS: Is there any
5	quantitative guidance as to what is unlikely?
6	MR. PERSINKO: It's not in the
7	regulations. It's in the Standard Review Plan.
8	MEMBER APOSTOLAKIS: Then there is
9	guidance?
10	MEMBER WALLIS: Do you mean modest theft
11	and things like that or something?
12	MR. PERSINKO: Correct.
13	MEMBER WALLIS: So there is a
14	quantification? What is it?
15	MR. PERSINKO: In the Standard Review
16	Plan, though, but not in the regulation.
17	MEMBER APOSTOLAKIS: So what is it? What
18	is an unlikely event?
19	MR. PERSINKO: "Highly unlikely" is on the
20	order of about 10 to the minus fifth, unlike
21	MEMBER APOSTOLAKIS: Per year? Per year?
22	MR. PERSINKO: Per year.
23	MEMBER APOSTOLAKIS: Yes?
24	MR. PERSINKO: Per accident scenario,
25	though. It's not a cumulative risk analysis.

1 And "unlikely" is in the order of 10 to 2 the minus third to 10 to the minus fifth. 3 MEMBER WALLIS: So "not unlikely" is quite 4 likely to occur during the life of the plant or 5 something? MR. PERSINKO: Yes. Yes. The applicant 6 7 has proposed non-quantitative definitions that it intends to use for these terms, and that's in the 8 9 construction authorization request as well, but in the 10 Standard Review Plan there are some 11 quantitative numbers. 12 "hiqh MEMBER APOSTOLAKIS: The consequences public dose" is greater than 25 rem. 13 14 MR. PERSINKO: Correct. 15 MEMBER APOSTOLAKIS: Now does it say 16 anywhere that this is from a particular sequence or 17 cumulative? 18 PERSINKO: No, it's a particular MR. 19 sequence. 20 MEMBER POWERS: It's sequence by sequence. 21 We have been over this many times. This is the ISA 22 approach. 23 MEMBER APOSTOLAKIS: The what? 24 MEMBER POWERS: This is the ISA approach. 25 MEMBER WALLIS: And you have workers and

1 public, and then you have people who are not workers 2 who are treated as workers. 3 MR. PERSINKO: That's correct. You have 4 In this particular facility we could spend 5 a whole couple of hours on it, if you would like. MEMBER WALLIS: No, we don't want you to 6 7 do that. MR. PERSINKO: But just to let you know 8 that there is -- because this facility is an island 9 and within a DOE site, there are facility workers, 10 11 which are the workers that work right at the MOX 12 facility; there are site workers, which work at the Savannah River site, and there are the public, which 13 14 are the people offsite. 15 I will just point out very quickly, and we can get into it, but it's rather complicated. 16 there are also, per the definition of a worker in Part 17 20, you could have a worker who is, our definition of 18 19 worker who is on the Savannah River site. 20 person who does not experience a radiological -- a 21 worker is a person who does experience a radiological 22 dose in the course of his or her normal course of 23 duties. 24 example, according to 25 interpretation, which is in Part 20, if you're a

cafeteria worker on the DOE site, you're considered a member of the public for Part 20 purposes. For Part 70 purposes, however, there is a provision in Part 70 that deals specifically with the performance requirements, that if you meet certain provisions, certain training requirements, certain notifications about the risk of the facility, that person can be treated as а worker for the purposes the performance requirements.

MEMBER KRESS: Is there an equivalent table of this for other types of consequences other than radioactive, such as heavy-metal poisoning or plutonium exposure, that's --

MR. PERSINKO: No, these are the -- well, there are doses. There are also requirements in the requirements. there's dose There's requirements in the Part 70 regulations dealing with chemicals, but we have to be careful with that because we have very carefully in Part 70 -- for example, we don't regulate chemicals for the sake of regulating chemicals. We only regulate them according to the regulation which talks about licensed materials and hazardous chemicals derived from licensed materials, and if a chemical release can affect the safety of the plant in some other way.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1	MEMBER KRESS: I see.
2	MEMBER APOSTOLAKIS: So there has been
3	analysis like this for the proposed facility? How
4	many sequences that lead to high consequence have been
5	identified?
6	MR. PERSINKO: I don't know the exact
7	number.
8	MEMBER KRESS: It's a small number,
9	though. It's like three or four.
10	MR. PERSINKO: I don't remember.
11	MEMBER KRESS: So, you know, when you add
12	up these
13	MEMBER APOSTOLAKIS: When you add them up,
14	you don't get
15	MEMBER KRESS: You don't get a lot. It's
16	not like
17	MEMBER POWERS: We'll discuss that over
18	the course of the presentation. There's a specific
19	item on the estimated risk to the public.
20	MR. PERSINKO: I just want to explain also
21	that the performance requirements, when you read the
22	regulation, talk about IRFS and meeting the
23	performance requirements. So it strictly applies to
24	the operational phase, but the applicant has adopted
25	this approach in order to identify the PSSCs as well,

which is I think a good idea because it gives you some guidance. Otherwise, there's no guidance in the regulation as to what is a PSSC.

Okay, I would like to talk about schedule a bit. We have a little history here. Also, we received an Environmental Report back in 2000, December of 2000. We received the construction authorization request, the first one, in February of '01.

Evaluation Report for construction in April of '02, at which point, slightly before we issued that SER, the applicant -- there was a program redirection whereby the immobilization part of the project was cancelled and a large part of the material that was destined to be immobilized will be going to the MOX facility. So that required some upfront modifications to the policy part of the process.

So, based on that, the Environmental Report and the Construction Authorization Report were revised. That's why you see there was a revised ER sent in in July of '02, a revised Construction Authorization Report in October of '02, to accommodate the material that was formerly meant to be immobilized.

1 The staff has issued a draft EIS for 2 public comment in February of this year. It was out 3 for public comment. We received the public comments. 4 The public comment period is closed and we are in the 5 process of finalizing -- of addressing those comments. Staff also issued a revised draft SER for 6 7 construction in April of this year, which is the subject of today's meeting. We also intend to issue 8 a final EIS and a final SER in September of '03. 9 intend to issue an EIS Record of Decision and a 10 11 Construction Licensing Decision in October of '03. 12 That concludes my presentation. MEMBER POWERS: Any questions on the 13 14 overview? 15 (No response.) If not, I will ask Gary Kaplan to give us 16 17 the applicant's perspective on the general facility and mission and layout and the discussion of their 18 19 safety philosophy, both with respect to prevention and 20 mitigation. 21 Gary, I'm dying to know: What is this, 22 Hastings doesn't like us anymore? We have offended 23 him? 24 MR. KAPLAN: I think he's in Bermuda this 25 week.

1	MEMBER POWERS: What?
2	MR. KAPLAN: I think he's in Bermuda this
3	week.
4	MEMBER POWERS: Bermuda? From now on,
5	we're going to visit him directly. If he's not going
6	to show up here, we're going to go where he is.
7	(Laughter.)
8	MR. KAPLAN: Good morning. My name is
9	Gary Kaplan. I'm the ISA lead for the MOX Project.
10	If we go to the next slide, as you know,
11	the mission of the MOX facility is to transform
12	plutonium so it's unusable.
13	If we go to the next slide, we briefly
14	talk about the facility layout. The key features on
15	this slide are the actual MOX processing area. It's
16	the largest building in the center. It's the BMP.
17	You'll find the label there.
18	The aqueous polishing building is adjacent
19	right to it, contiguous building. It's the BAP to the
20	lower left.
21	Another major feature right here is the
22	Emergency Diesel Generator Building, over here in the
23	lower right corner. Notice the stack is right over
24	here, and it's approximately 100 meters to the edge of
25	our fenceline over here, and it's approximately five

1 miles to the site boundary of the Savannah River site. 2 So those are some of the key features of the layout. Could you point out on 3 MEMBER POWERS: 4 this slide where waste is accumulated and then 5 transferred back to this thing we were seeing? 6 MR. KAPLAN: Let's see, well --7 MEMBER POWERS: It's mainly chemical 8 waste. 9 Right. It's just briefly MR. KAPLAN: 10 stored in the -- let's see, which building here? 11 believe in the AP Building there's a storage area, and 12 then it would be shipped by or transferred by pipe to this event oversight facilities. I'm not sure which 13 14 direction. I believe it will be stored in the Aqueous Polishing Building. 15 16 MEMBER POWERS: Right. 17 MR. KAPLAN: Okay, the next couple of 18 slides, we have those. You can go to the next slide. 19 I'm going to give an overview of the process of what 20 we are doing for the CAR, what we've done for the CAR, 21 and what we're doing for the license application, as 22 well as the final slide I'll talk a little bit about 23 our terminology and try to clear up some of the 24 discussion with defense in-depth. 25 The ISA that we are performing is an

1 integral part of the design process. It's 2 iterative process with design. As the design evolves, 3 the ISA, we perform more sophisticated and detailed 4 analysis as necessary. 5 Initially, in the CAR, based on the site description and the preliminary design, we identify 6 7 hazards and events associated with the NF design and operations. We considered natural phenomena that are 8 relevant to the Savannah River site. We considered 9 external, man-made hazards from nearby facilities, 10 11 nearby railways or roadways or airports. 12 From that, for some of the natural phenomena and the external, man-made hazards, we did 13 14 initial screening evaluations to determine if they 15 were credible. For instance, we screened out avalanches, tsunamis, things like that, based on where 16 the site is, very low-likelihood events. 17 The one man-made hazard that we did an 18 19 evaluation of was aircraft crashing into the facility, 20 and delayed probability event from accidents. 21 MEMBER APOSTOLAKIS: Now the aircraft is 22 non-intentional? 23 Non-intentional, correct. MR. KAPLAN: 24 MEMBER POWERS: That's correct. The seismic is a little 25 MEMBER WALLIS:

1	problematic.
2	MR. KAPLAN: Which one?
3	MEMBER WALLIS: You've got this one event,
4	seismic
5	MR. KAPLAN: Right.
6	MEMBER WALLIS: one event every 500
7	years, more or less.
8	MR. KAPLAN: And certainly we considered
9	seismic. That wasn't screened out, right.
10	Based on the potential unmitigated
11	consequences of these events, we identified a safety
12	strategy, and from that we identified the principal
13	SSCs required to either mitigate or prevent these
14	events.
15	As Drew's little matrix showed, you can
16	either attempt to mitigate the consequences or you can
17	prevent the consequences. Either way, you can satisfy
18	the criteria 10 CFR 70.61.
19	Once we identified the principal SSCs, we
20	then identified specific design-basis.
21	MEMBER POWERS: Gary, I think that comment
22	that you can either prevent or you can mitigate is a
23	little too stark. You still have a requirement of
24	defense in-depth in this facility.
25	MR. KAPLAN: That's correct, right.

1	MEMBER POWERS: So I wouldn't portray it
2	as it's one or the other.
3	MR. KAPLAN: Right.
4	MEMBER POWERS: You end up having to do
5	both.
6	MR. KAPLAN: We do both, and we'll talk
7	about that in the last slide. What we credit, in
8	principal SSCs we normally do one or the other. There
9	was the box in the middle that kind of allowed you to
10	do part of both, either reduce the likelihood somewhat
11	and reduce the consequence. The range is so small in
12	there that we didn't use that box anywhere. We either
13	made the event highly unlikely or we reduced the
14	consequences down very low.
15	MEMBER POWERS: Well, it seems to me that
16	I would not just
17	MR. KAPLAN: Couch it that way? Right.
18	MEMBER POWERS: And I just comment or
19	harken back to your approach on Red Oil, where you're
20	saying, okay, I'm going to keep the temperatures
21	low
22	MR. KAPLAN: Right.
23	MEMBER POWERS: but I'm also going to
24	clean the solvent.
25	MR. KAPLAN: Sure.

1 MEMBER POWERS: I mean, you can't rely on 2 one thing to keep everything low. 3 MR. KAPLAN: That's correct. 4 The design basis that we have described in 5 the CAR included the safety function values, where appropriate, and commitments to codes and standards 6 7 that we're going to design the facility to. 8 One example of this would be we identified, as you said, earthquake as a natural 9 10 phenomena hazard. In an event scenario we would come 11 up with the building could fall and disperse 12 plutonium. So we come up with a strategy: Design the building to withstand the earthquake, and we describe 13 14 that. 15 We identify the appropriate magnitude earthquake that we're going to design to, and we've 16 17 provided all the structural code and standards in the CAR that we're designing to, as well as methodology. 18 19 MEMBER APOSTOLAKIS: What that 20 earthquake? Do you know? 21 MR. Ι think it's KAPLAN: g 22 earthquake. 23 MEMBER APOSTOLAKIS: Point two? 24 MR. KAPLAN: Right. It's anchored with a different --25

	33
1	MEMBER APOSTOLAKIS: Is it another oh,
2	yes, that's
3	MR. KAPLAN: Right.
4	MEMBER KRESS: You choose that by sound
5	frequency?
6	MR. KAPLAN: That's correct.
7	MEMBER KRESS: Driven by New Madrid?
8	MR. KAPLAN: Not the seismic. Does
9	anybody in my crowd know what that is driven by?
10	MEMBER POWERS: It's driven by Charleston,
11	and there's another fault zone just north of the
12	Savannah River site. It also changes your
13	frequencies, but it's consistent with the design of
14	facilities on the Savannah River site.
15	MR. KAPLAN: Right, and there is a
16	discussion letter today on seismic
17	MEMBER POWERS: Right.
18	MR. KAPLAN: that I think will cover
19	some more detail on that.
20	Okay, if you go to the next slide,
21	continuation of the process: As the design evolves,
22	we do more detailed analysis, and major steps are: We
23	identified detailed event scenarios that identify
24	specific IRFSs and also we challenged those IRFSs to
25	determine if they can withstand all the different

events.

The main type of analysis we're doing are process hazards analysis. We're doing haz ops, "what if's," fault tree analysis, where appropriate, to challenge and identify IRFSs.

The next major step is we demonstrate that the IRFSs are effective through supporting calculations. The majority of these calculations are standard design calculations. An example would be, following up on the earthquake example is they're doing design calculations to demonstrate that the building will withstand a .2 g earthquake, and that certainly supports the ISA.

We also do, as necessary, failure loads analysis on the specific IRFSs to ensure that they can withstand the challenges. A good example that we've already talked a lot about is the HEPA filters. We've identified HEPA filters as a major, as a principal SSC, and we have done failure modes analysis to determine, will soot, temperature, other factors, how they can impact the HEPA filters, and then we do evaluations to demonstrate that we can handle the soot, the temperature, things like that.

The next major piece is we demonstrate the event likelihood satisfies the performance criteria of

10 CFR 70.61. What we have committed to at this point
is compliance with the single-failure criterion,
worked out a contingency for criticality events.
We're going to identify means to detect
failures of IRFSs. We've committed to specific codes
and standards, and we've committed to the 10 CFR 50
applicable Appendix B QA program.
I think that covers it. That gives you a
high-level overview of our ISA process from the
beginning all the way through the license application.
MEMBER POWERS: I think it's important for
people to understand that the ISA, in summary, comes
in the second step for this.
MR. KAPLAN: That's correct. That's
correct.
MEMBER APOSTOLAKIS: The second step?
Which step is that?
MEMBER POWERS: At this point we're still
working with the design basis.
MR. KAPLAN: That's correct. The second,
with the license application, we will summarize all
these calculations that demonstrate the IRFSs can
perform their job.
MEMBER APOSTOLAKIS: Now this likelihood

1	MR. KAPLAN: No, on an event-sequence
2	basis we're going to demonstrate that we meet single-
3	failure criteria.
4	MEMBER APOSTOLAKIS: But it says,
5	"likelihood."
6	MR. KAPLAN: Well, this is how we're
7	meeting the likelihood criteria.
8	MEMBER APOSTOLAKIS: I see. You don't
9	have an explicit, quantitative measure of the
10	likelihood?
11	MR. KAPLAN: That's correct. As part of
12	the license submittal, we will not have, that's
13	correct.
14	MEMBER APOSTOLAKIS: And single failure
15	includes passive failures
16	MR. KAPLAN: Sure.
17	MEMBER APOSTOLAKIS: and everything?
18	MR. KAPLAN: That's correct.
19	MEMBER APOSTOLAKIS: But a system?
20	MR. KAPLAN: Well, we do have an event-
21	sequence basis. So for all these hundreds of events
22	that we've identified, we will show that we meet
23	single-failure criteria.
24	MEMBER APOSTOLAKIS: I don't understand
25	what that means, the "sequence." I mean, I can

1 understand, if you give me a system, that there would 2 be no single failure failing the system. 3 MR. KAPLAN: Right. 4 MEMBER APOSTOLAKIS: But if you give 5 sequences, you mean that there would be no sequences with one event in them? 6 Is that what you mean? 7 MR. KAPLAN: There would be no sequences where we don't meet the single-failure criteria 8 9 applying the IRFS. It's a little different than 10 reactors because a lot of our events, you know, we 11 have distributed material at risk throughout the 12 facility as opposed to a reactor. So there's lots of isolated events that don't really depend on an entire 13 14 system. It might depend on more isolated features. 15 MEMBER APOSTOLAKIS: That's fine, but how does one apply the single-failure criterion to a 16 I mean, that's where I don't --17 sequence? Well, I happen to have my 18 MR. KAPLAN: 19 probability expert with us. Maybe he can help. Mark? 20 MEMBER APOSTOLAKIS: You have to come to 21 the microphone and tell us who you are. 22 MR. KLOSKY: Mark Klosky, DCS. 23 I think what we're trying to illustrate 24 here is that we identify event sequences, and in so 25 doing, identify the requisite features that we've

1	identified as at this stage principal SSCs, but later
2	to become IRFSs. What we're saying is that no single
3	failure to the system, the system being the IRFS, will
4	result in the event sequence occurring.
5	MEMBER APOSTOLAKIS: So you're going back
6	to the system then?
7	MR. KLOSKY: Yes.
8	MEMBER APOSTOLAKIS: You're not
9	applying
LO	MR. KLOSKY: The system, correct, yes.
L1	MEMBER APOSTOLAKIS: Which means, though,
L2	there would be no event sequence with just one event?
L3	Right?
L4	MR. KLOSKY: Yes.
L5	MEMBER APOSTOLAKIS: Okay.
L6	MR. KLOSKY: That's correct.
L7	MR. KAPLAN: Okay, we'll go to the next
L8	slide. This slide illustrates the defense-in-depth
L9	philosophy and it attempts to clarify some of the
20	associated terminology.
21	If you assume in the middle we have the
22	hazard and/or the event, our first layer of defense
23	from these hazards and events are what we call
24	additional protection features. These reduce the
25	challenges to the IRFSs by either preventing or

1 mitigating the event before it would impact or require 2 the IRFSs to take action. 3 These are protection features normally 4 associated with normal operations such as trained 5 operators, normal operations alarms. More specific ones might be the nitrogen blanket that we have in the 6 7 glove boxes, the hand-held fire extinguishers, things 8 that we don't credit in the safety analysis as 9 principal SSCs or IRFSs. They're certainly in the 10 facility and provide additional protection. 11 MEMBER WALLIS: This is а very 12 interesting, sort of qualitative cartoon, but what really matters is the degree of total protection, and 13 14 the fact that you have three stages doesn't assure a 15 certain degree of protection necessarily. MR. KAPLAN: That's correct. This is just 16 17 trying to illustrate there were some terminology questions --18 19 MEMBER WALLIS: It's not qualitative if 20 it's a cartoon. 21 Right. MR. KAPLAN: 22 MEMBER WALLIS: But this is some measure 23 of total protection achieved by this process? 24 MR. KAPLAN: To meet the 10 CFR 70.61 25 requirements, all we're crediting are the principal

1	SSCs or IRFSs, and that satisfies that portion. We
2	believe the rest of this satisfies the requirements of
3	10 CFR 70.64, the defense-in-depth requirements. We
4	don't have a qualitative
5	MEMBER WALLIS: So there's no measure of
6	defense in-depth?
7	MR. KAPLAN: That's correct. We don't
8	have a quantitative target at this point, that's
9	correct.
LO	MEMBER WALLIS: So there's no indication
L1	that having three steps is better than two or anything
L2	except as a qualitative thing?
L3	MR. KAPLAN: Right, that's correct. And
L4	this wouldn't really indicate that we have three.
L5	There might be 10 layers in there, that's right.
L6	MEMBER WALLIS: It doesn't help you to
L7	decide whether to have three or four if you don't have
L8	any missions.
L9	MR. KAPLAN: The next layer of defense are
20	the actual principal SSCs and IRFSs. Those are the
21	features that we credit to satisfy 70.61.
22	Note that we've committed to the single-
23	failure criteria. So this is where, just in this
24	layer alone, we have redundancy and/or diversity at
25	this point, just in this one laver.

1	The next layer are what we call
2	MEMBER POWERS: You specifically said,
3	"redundancy and/or diversity" there. Talk to me a
4	little bit about your philosophy on when you select
5	between redundancy, mere redundancy, and when you go
6	with diversity.
7	MR. KAPLAN: These facilities are based on
8	no extra line design. I believe in most cases we have
9	redundancy.
LO	MEMBER POWERS: Yes, I think you're
L1	basically going with a redundancy design.
L2	MR. KAPLAN: That's correct. There are
L3	some cases I'm trying to think of some specific
L4	examples where there's diversity in what's used. I
L5	don't have any off the top of my head. I don't
L6	know
L7	MEMBER POWERS: But if we look at the
L8	principal safety features that you have, for instance,
L9	take emergency power, basically, a redundant system.
20	That's a highly redundant system.
21	MR. KAPLAN: That's correct.
22	MEMBER POWERS: What, four different
23	electrical power sources coming into the facility?
24	MR. KAPLAN: There's the standard power.
25	There's the standby diesels. There's the emergency

1	power, and we have batteries also, if necessary.
2	MEMBER POWERS: Yes.
3	MR. KAPLAN: Right.
4	MEMBER POWERS: And if we look at HEPA
5	filtration, basically, a redundant system.
6	MR. KAPLAN: The part that's credited is
7	basically redundant, that's correct, but there's
8	multiple players of HEPA filtration also outside of
9	that redundancy.
10	MEMBER POWERS: That also seems to be
11	another critical design feature that Drew mentioned.
12	You have adopted a zonal kind of construction to this
13	facility?
14	MR. KAPLAN: That's correct.
15	MEMBER POWERS: And so you have
16	essentially four nested zones with pressure
17	differentials between each of them?
18	MR. KAPLAN: Between, yes, the glove boxes
19	and the public, right.
20	MEMBER POWERS: So those are the essential
21	design bases that we're looking at in this stage on
22	this. It basically is a redundant system, basically,
23	a classic zonal kind of strategy?
24	MR. KAPLAN: That's correct. Well, in the
25	glove box is where the plutonium is. There's one

1 ventilation system that's surrounded by another 2 ventilation system in the room, surrounded by the 3 building ventilation system. That's correct. 4 That's one of the examples of a defensein-depth feature. 5 Those are features that we don't credit in the safety analysis, but they are IRFSs for 6 7 some other event, where we have decided to upgrade them to IRFSs for an additional protection. 8 An example is the building ventilation 9 It's not credited to satisfy any of the 10 requirements of the 70.61, but we have that feature 11 12 So that provides another layer of defense. MEMBER KRESS: When you identify something 13 14 as an IRFS, does then put the requirements on testing, 15 inspection --16 MR. KAPLAN: Oh, sure. MEMBER KRESS: -- and quality assurance? 17 That's correct. 18 MR. KAPLAN: 19 MEMBER KRESS: And things of that nature? 20 MR. KAPLAN: We apply the whole QA program 21 well as additional it, that's correct, as 22 management measures that we've specified. 23 Then, to finalize the terminology, all of defense-in-depth 24 these combined would be our 25 philosophy. So we've kind of used two sets of defense

1	in-depth, one for specific features as well as the
2	entire license.
3	MEMBER POWERS: Let me ask you this
4	question: We've discussed prevention and mitigation
5	features, but in the end, when you have an event, you
6	have to put the facility into a safe configuration,
7	and that's a problem because there's material in the
8	system; you can't get the material out of the system,
9	and it has to be there.
10	What is the safe configuration for your
11	facility?
12	MR. KAPLAN: The safe configuration is
13	what we've committed to in keeping the glove box
14	ventilation system basically running. That's the safe
15	configuration.
16	On the AP side, for short durations we can
17	shut the processes down and be in a stable
18	configuration.
19	MEMBER POWERS: It seems to me you move
20	the fluid to tanks in the AP system.
21	MR. KAPLAN: That's correct.
22	MEMBER POWERS: You shut the furnaces
23	down. You maintain the ventilation. That's your safe
24	configuration?
25	MR. KAPLAN: That's correct.

1	MEMBER POWERS: At that point you can
2	continue with that situation essentially indefinitely?
3	MR. KAPLAN: That's correct, for long
4	periods of time. That's right.
5	So the major system that has to keep
6	running is the ventilation system. That's similar to
7	what reactor systems would be like. It's completely
8	independent and separate.
9	MEMBER POWERS: And that's essentially
10	you're providing them complete ability?
11	MR. KAPLAN: That's right.
12	MEMBER POWERS: Yes, that's right. I
13	think it's important to understand that in the design
14	basis here.
15	MR. KAPLAN: That's right.
16	MEMBER POWERS: That there is a safe
17	configuration; there is prevention; there is
18	mitigation in this facility. Okay.
19	MR. KAPLAN: Okay.
20	MEMBER POWERS: It is only when you come
21	to the construction phase of the application that we
22	get any real estimation of the residual risk that this
23	facility poses?
24	MR. KAPLAN: Excuse me.
25	MEMBER POWERS: It is only at the end, in

1 the construction phase, that we get what this 2 Committee would recognize as the completed ISA, which 3 is some indication of the risk this facility poses to 4 the public? You get the results of the ISA? 5 MR. KAPLAN: You get the results of the I mean, you have some indication now. 6 ISA. 7 MEMBER POWERS: Oh, yes, right. Yes, we have some indication, but the formal results of the 8 9 ISA really appear as part of the construction. 10 MR. KAPLAN: As part of the ISA, you were saying? 11 MEMBER POWERS: Yes, that's right. 12 MR. KAPLAN: That's correct. 13 MEMBER POWERS: Okay, good. Thank you. 14 15 MR. KAPLAN: Okay, thank you. 16 MEMBER POWERS: We move now to some of the 17 major technical issues associated with this. are you going to walk us through and introduce your 18 19 various speakers here? 20 MR. PERSINKO: Yes. Okay. For 21 criticality safety, it's going to be Christopher 22 Tripp. Following that, we will have fire safety, Rex 23 Wescott. Red-Oil discussion will be Alex Murray, and 24 then the next one will be Rex Wescott also. Seismic 25 is going to be John Stamatakos.

1 MEMBER WALLIS: Is someone taking about 2 explosions in fires and such? 3 MR. PERSINKO: Yes, fire safety, Rex 4 Wescott will talk about, and explosives we'll cover 5 also. MR. TRIPP: I'm going to talk a little bit 6 7 about the criticality safety review for the MOX Fuel Fabrication Facility. First, I'm going to go through 8 the design bases a little bit and then discuss the 9 open issue that we still have. 10 11 These are the 10 design bases for the 12 facility that are described in Chapter 6 of the CAR. They mostly consist of programmatic design criteria 13 14 that we have reviewed at the CAR stage. They give us 15 confidence, hopefully, that the design, if we see a design, it will be found generally acceptable. 16 17 favorable, made We found favorable conclusions, with the exception of the second one on 18 this list that I'll discuss in some more detail in a 19 20 minute. 21 MEMBER WALLIS: Now the second one, I was 22 curious; we know nothing about this coming in. 23 seems to me this magic number of .95 would seem to me 24 rather strange. I mean, what really matters is the

probability of getting a k-effective of one. There's

1	nothing magical about .95?
2	MR. TRIPP: Right, that's true. As long
3	as the true k-effective of the system is less than
4	MEMBER WALLIS: Point nine-five plus or
5	minus a sigma of, you know, .05 or something is
6	probably unacceptable.
7	MEMBER POWERS: I'll remind you that we're
8	working on design bases here.
9	MEMBER WALLIS: Oh, this is a "funny
10	world" word?
11	MEMBER POWERS: No, no, we're working on
12	design bases.
13	MEMBER WALLIS: Well, okay, we're in the
14	regulatory world then.
15	MEMBER POWERS: We're working on design
16	bases, which you use as the basis for your design.
17	MEMBER WALLIS: Yes. Well, why is this
18	the basis? The real basis should be, what's the
19	probability of getting a k-effective that's
20	unacceptable?
21	MR. TRIPP: Well, yes, and I think what we
22	have used was a setting a conservative margin that
23	gives us some confidence that we don't exceed a
24	k-effective of one in the real world.
25	MEMBER WALLIE: If it is really

1	conservative, yes, and maybe you'll get into that.
2	MR. TRIPP: Yes.
3	MEMBER WALLIS: So coming in and not
4	knowing the history of this kind of stuff, it seemed
5	to me strange you just focused on the maximum
6	k-effective, because it isn't by itself a hazard of
7	any kind.
8	MR. TRIPP: Right.
9	MEMBER WALLIS: It isn't a reassurance of
10	any kind really, either.
11	MR. TRIPP: Well, what we're doing is
12	we're setting some limit in k-effective that gives us
13	assurance that's it's sub-critical really. The only
14	distinction we really need to make is between sub-
15	critical and
16	MEMBER WALLIS: Well, you're going to talk
17	about an uncertainty in that then, yes. Okay, we'll
18	go ahead, please.
19	MR. TRIPP: Yes, that includes the
20	uncertainty.
21	I'm not going to belabor each of these.
22	Several of these come out of the regulations. The
23	first one comes from the baseline design criteria in
24	70.64.
25	The second one is really a design basis;

we consider it a design basis because this has to be known prior to doing the design calculations to set the sub-critical limits. You need to know what the acceptance criterion is before you can complete the design.

The third comes from 70.61(d), and it deals with a margin of sub-criticality and requirement to identify the abnormal conditions in the facility. Criticality accident alarm systems are required by 70.24(a), unless specific exemption is requested and granted.

In terms of management measures, that really applies to how the QA plan will be applied to criticality safety-related IRFSs. Since we haven't identified specific components relied on for safety, this is more a description of the safety grades and how they apply to criticality controls, rather than specific management measures applied to specific controls.

Our technical practices include commitments to ANSI/ANS-8 Series standards for criticality as well as technical requirements on, how do you perform criticality calculations, what type of controls are -- what type of requirements apply to different controls, and so forth?

The final one is basically because of the inherent conflict between a desire to use water-based suppression for fire protection and the desire to exclude water for criticality purposes.

So if we can go to the next slide, we identified that one of the design bases is identification of the dominant control parameters for the major process areas, and that's really defined at a high level at this point. For instance, we would be talking about controlling mass and geometry for a particular system. It is more at a systems level than at a component level.

So we were specifically asked to address the waste processing at the MOX facility. The first thing is, of course, repeating what Drew said, the waste is going to be stored at the MOX facility and it's going to be processed under DOE jurisdiction.

So for criticality purposes, the main concern is prevention of getting significant quantities of fissionable material into the waste streams that can then be transferred to unfavorable geometry. The control strategy has been identified as consisting of these items: dual controls and concentration of mass, so that there's at least two barriers prior to getting fissionable material into

1	the waste streams.
2	Here's the double contingency. Rather
3	than identify the specific controls, identify the
4	specific type of controls that will be used, active
5	controls may consist of things like in-line monitors.
6	Passive controls would be items such as siphon breaks,
7	overflows, and so forth. Dual independent sampling is
8	also frequently used.
9	We have bought off that we think this is
10	a reasonable approach.
11	MEMBER WALLIS: What is this waste like?
12	Is it a liquid or slurry, or what is it? Is it a
13	mixture of things? It's piped to DOE. So,
14	presumably, it's a slurry or something?
15	MR. TRIPP: Yes, it would be in a liquid
16	form.
17	MEMBER WALLIS: It's all dissolved?
18	MR. TRIPP: Yes. Well, the waste, for
19	instance, the waste from the aqueous polishing would
20	be, it should be very low-concentration liquids. So
21	the idea is to get the concentration of plutonium
22	to
23	MEMBER WALLIS: There's no solids that can
24	settle out?
25	MR. MURRAY: If I could just interrupt. mv

1 name is Alex Murray. I'm one of the Chem. Safety 2 Reviewers for the NRC. For the waste materials at the proposed 3 4 facility, they should be clear solutions without 5 solids. 6 MEMBER WALLIS: Thank you. 7 MR. MURRAY: Okay. MEMBER POWERS: Well, to be fair, one of 8 9 the major concerns you have is that you will, in fact, 10 get plutonium in solution over there and have a 11 precipitation of plutonium hydroxide coming out 12 because you've failed to control the pH of the system properly. But, basically, you're working with clear 13 14 liquids here. I mean, you hope you're working with 15 clear --So there's going to be 16 MEMBER WALLIS: 17 some assurance that you can keep the liquid clear? That's what these 18 MR. TRIPP: Right. 19 designs are attempting to do. There are filters, and 20 so forth, on the system as well. 21 So this is consistent with what we see in 22 the usual nuclear industry at other facilities, and 23 it's also the same type of approach they've adopted for things like ventilation and reagent recovery 24

So, really, at the design basis level,

systems.

1	that's pretty much the extent of what we reviewed at
2	this point.
3	MEMBER FORD: It's pretty well exactly the
4	same process as used at La Hague, materials, controls,
5	for this particular part of it, correct?
6	MR. TRIPP: Yes, the same general
7	approach.
8	MEMBER FORD: And there's been no problems
9	at La Hague, materials problems?
LO	MR. TRIPP: Materials problems
L1	MEMBER FORD: Materials of construction
L2	problems? I don't know the answer to it. I'm asking
L3	you. Have there been problems of materials of
L4	construction degradation at La Hague?
L5	MR. TRIPP: I'm not sure how that relates
L6	to the criticality safety of the waste.
L7	MEMBER FORD: Well, it doesn't, not
L8	specific to that, but we're just talking about the
L9	waste of liquid, clear liquid, and trying to get rid
20	of it. This is not, presumably, water.
21	MR. TRIPP: It's not water, but it's a
22	combination of things that basically has extremely low
23	levels of fissionable materials, so very low amounts
24	of plutonium.
25	So what happens after that is, from my

55 1 point of view, is not really a concern. Maybe the 2 chemical reviewer could talk more to that. 3 MEMBER FORD: Okay. 4 MR. PERSINKO: I would just like to point 5 out, though, that we did not do a rigorous review of the La Hague plant. I mean we visited the site. 6 7 talked with the engineers over there, as well as the So we are familiar with much of the 8 regulators. 9 plant, but we didn't do a rigorous review of the La 10 Hague facility. 11 MEMBER POWERS: I think what it is safe to 12 say is that over the last 40 years we have accumulated an enormous amount of experience working with these 13 14 particular solutions and liquids and a variety of 15 different materials and what-not. It's probably safe to say that, if the materials are kept within their 16 planned concentrations, that there are no degradation 17 modes, unanticipated degradation modes. 18 19 MEMBER FORD: That was the point of my 20

MEMBER FORD: That was the point of my question, Dana. All over the world you have had problems of degradation of materials of construction in waste facility plants, just gigantic chemical plants. I'm just pointing to La Hague because that seems the nearest equivalent of any problems.

MEMBER POWERS: You can point to the Purex

21

22

23

24

facility and places like that that have had longer lifetimes. What we know is we have become very expert in this because we have made every mistake possible, and sometimes more than once.

(Laughter.)

But, again, what you can't say now is, if you get outside your range that you have designed this material to, how fast does the material degrade, because I can always say, "Wait, we get farther and farther and farther," and, eventually, yes, you can corrode this material. But if you stay within the range that you expect, you're okay.

MR. KLOSKY: Mark Klosky, DCS. I just want to clarify a couple of things about the waste.

I think we mentioned the process, that we have the solvent-extraction process that is separating the impurities. In this case that's what we're taking about. Prior to going into the waste, we have monitoring plutonium concentrations. So, with respect to criticality, as Chris indicated, the plutonium concentration is low.

I understand your question to be, what are the material concerns? We're using the stainless steel construction, and with respect to safety, we have evaluated consequences and determined that the

1 radiological consequences and chemical consequences 2 that could potentially arise due to leaks do not 3 exceed the performance requirements of Part 70. 4 Further, the material is in an acidic 5 medium; it's a nitric acid medium containing the material, which in this case if we're talking the 6 7 actually weapons-grade plutonium, has limited quantities of impurities, not the same impurities that 8 accompany the separated nuclear fuel from commercial 9 facilities, which have the added damaging effect of 10 11 the radiolysis, the radiation damage. 12 So our environment here is actually less corrosive than that of a commercial reprocessing 13 14 facility, due to the non-inclusion of the fission 15 parts. First of all, I have to 16 MEMBER POWERS: 17 apologize to all the speakers. Dr. Ford asked me to include the materials degradation in the issues that 18 19 I sent to you, and, of course, I promptly forgot to do 20 it. So he's bound and determined to make me pay for 21 this. 22 (Laughter.) 23 But there are interesting material issues 24 I believe it is correct that the stainless

passivates

in

steel

naturally

25

sufficiently-

1	concentrated nitric acid and becomes corrosive in
2	sufficiently dilute nitric acid. In addition, there
3	are chlorides and things like that that exacerbate the
4	attack on materials.
5	MEMBER FORD: I guess my final question on
6	this for the time being is: Are all these piping
7	systems inspectable?
8	MEMBER POWERS: Inspectable? That's a
9	good question.
10	MEMBER FORD: Are they above ground, below
11	ground? Where are they?
12	MR. KLOSKY: I will say that one of the
13	PSSCs identified by the applicant is a material
14	surveillance, maintenance and surveillance program.
15	So that is identified as a PSSC.
16	As far as your question about whether all
17	the pipes are inspectable, I don't know, maybe the
18	applicant could answer that, but I believe the pipes
19	in the process cells are not inspectable.
20	MR. ST. LOUIS: I'm Tom St. Louis with
21	DCS.
22	All of the piping and materials are
23	accessible for inspection. We have many components
24	that are in process cells that are normally closed and
25	are not normally accessed, but there is a means to go

1	in for access.
2	All of these areas are monitored for
3	leakage, and if there's leakage, there are procedures
4	planned to shut down the plant and access the area to
5	do repairs.
6	MEMBER FORD: But the waste stream that
7	goes to DOE in the pipeline, above the ground or
8	below, are they inspectable?
9	MR. ST. LOUIS: Yes.
10	MEMBER FORD: That's above ground?
11	MR. ST. LOUIS: No, it's a buried line, a
12	double pipe.
13	MEMBER FORD: It's in a tunnel or
14	something?
15	MR. ST. LOUIS: It's a double-pipe
16	construction, and it is monitored for leakage. Now we
17	actually have three waste streams that go to DOE. One
18	is the high alpha, which is most of the chemical
19	waste; a stripped uranium waste stream, and then we
20	have a low-level waste stream that goes to a different
21	treatment facility.
22	MEMBER FORD: Thank you.
23	MR. TRIPP: I'm now going to discuss a
24	little bit about the one open issue here, which was
25	identified NCS-4 in the draft SER. This relates to

the determination of the k-effective limits.

The codes that are used to calculate subcritical limits have different amounts of bias and uncertainty for the different systems. So what DCS has done is they have defined five AOAs, or areas of applicability, to which all the plant processes can be divided.

The code has been validated in each of these areas separately and a different upper subcritical limit determined. Again, this is to ensure, give you a certain amount of confidence that the process is sub-critical if you're below that limit.

Another portion of this is that, because the design applications are not exactly identical to the benchmarks, there may be other aspects of the bias that are not taken into account when you do the calculation of the benchmark. So some additional administrative margin is applied.

What we have accepted at other facilities is traditionally .05 for the abnormal condition case. In addition, we have had a lot of discussion about what should be the margin for the normal case. An approach that has been adopted at some facilities is that it's been allowed to be determined on a case-by-case basis because some systems are much more

1 sensitive to changes in the system parameters than 2 others in terms of their effect on k-effective. 3 Because this depends on design, it really 4 can't be determined prior to the design. So what we 5 have said, agreed, is that the abnormal condition margin of .05 would be acceptable as part of the 6 7 design basis, and then some normal margin would be determined as part of the design, depending on the 8 9 sensitivity of the particular system. So the methodology for doing that is 10 something that we have not gotten a complete handle on 11 12 So those are really the two aspects of as yet. determining the limits. 13 MEMBER APOSTOLAKIS: So it's essentially 14 15 I mean, it's not -- is there any expert judgment? supporting calculation that considers possibilities 16 and their likelihood of occurring? I mean, why .05 17 and not .1? How much does that bind? 18 19 MR. TRIPP: Well --20 MEMBER APOSTOLAKIS: If I go to .04, am I 21 in trouble? 22 MR. TRIPP: Yes, the value really has not 23 ever had a historical technical basis. It's always 24 been based largely on judgment, and this is throughout 25 the designer history, not just at the MOX plant.

1	applies to transportation as well. It's in the rule,
2	Part 71.
3	MEMBER APOSTOLAKIS: And it's always .05?
4	MR. TRIPP: Well, no, there are some
5	inconsistencies from one licensed facility to another.
6	MEMBER APOSTOLAKIS: Because it's
7	judgment?
8	MR. TRIPP: That's part of the complexity
9	of this.
10	MEMBER WALLIS: It seems to me in this era
11	it ought to be risk-informed.
12	MR. TRIPP: Well, it ought to be risk-
13	informed. Part of the problem
14	MEMBER APOSTOLAKIS: Probability-informed.
15	MR. TRIPP: Part of our goal is to make it
16	risk-informed by allowing it to depend on the system.
17	In other words, if you have a system that's very
18	sensitive to changes in k-effective, it should have
19	more margin than a system that's relatively
20	insensitive.
21	MEMBER APOSTOLAKIS: Yes.
22	MR. TRIPP: I think that's where the risk-
23	informing comes in. That could be based on
24	calculations, sensitivity-type calculations.
25	MEMBER WALLIS: Eventually, you have to

1 bring in the awful word "probability." 2 (Laughter.) 3 MEMBER POWERS: I guess I will inject 4 that, historically, we had a couple of criticality 5 events that killed some people, and people found that objectionable and they said, "What do we do about 6 7 this?" From that, a fairly prescriptive regime was established. The most visible element of that regime 8 is the double-contingency principle. 9 We have established what I would call a 10 11 standards-based safety system with respect 12 criticality as opposed to a defense-in-depth or other kind of criticality. Quite frankly, that has served 13 14 us very well. 15 So I would be reluctant to say, in the name of purity or religious fervor, let's risk-inform 16 this prescription that's come down. 17 MEMBER WALLIS: I don't think that's the 18 19 idea of any kind of purity. I think you know better what you're doing if you have some measure of the 20 21 Maybe it's work, but you may be lucky. 22 know better what you're doing if you have a measure of 23 what you're achieving. I think it's a rational thing. 24 It's not a question of purity. 25 But I don't want to get into a debate with

1 you about that. I would just sort of urge the staff 2 gently in that direction. 3 MEMBER POWERS: Well, before you urge too 4 much, remember, we're doing one MOX facility. I don't 5 think we're planning a regime of MOX facilities. don't think Drew could stand it. 6 7 (Laughter.) MEMBER WALLIS: This isn't just for MOX. 8 9 This is for anything. Whenever you're talking about 10 safety, there ought to be some measure of how safe it is. 11 12 So let's just go on with it. Okay? MR. TRIPP: One additional thing is that, 13 14 for the second area of applicability, the MOX pellets, 15 rods, and assemblies, that is equivalent to the lowenriched part of the plant. We're dealing with 6 16 17 percent material. We've accepted already a margin of .05 for 18 19 normal conditions for that. So that's how we're 20 attempting to be --21 MEMBER APOSTOLAKIS: So there is some sort 22 of evaluation -- say, pick one of those, the plutonium nitrate solutions --23 24 MR. TRIPP: Right. MEMBER APOSTOLAKIS: -- of how k-effective 25

1	can approach one? Is there some assessment of how
2	that can happen?
3	(Laughter.)
4	MR. TRIPP: Yes, that's all part of the
5	evaluation process.
6	MEMBER APOSTOLAKIS: What does that
7	include? And why is it an open issue, because they
8	haven't done it or what?
9	MR. TRIPP: It's an open issue primarily
10	because of the lack of benchmarks for plutonium in MOX
11	systems. It makes it much more difficult to validate
12	the codes than for other, for low-enriched or high-
13	enriched fuel applications.
14	MEMBER APOSTOLAKIS: Would humans come
15	into the picture anywhere here, some human error
16	perhaps?
17	MR. TRIPP: Human error?
18	MEMBER APOSTOLAKIS: Well, I mean, is it
19	possible? I don't know how they do it. Or is it all
20	machines?
21	MR. TRIPP: Well, yes, there's humans as
22	analysts. Analysts have to model the systems, and so
23	forth. There's a lot of human judgment that comes
24	into effect
25	MEMBER APOSTOLAKIS: But it cannot affect

k-effective?

MR. TRIPP: It can affect k-effective.

MEMBER WALLIS: That's why we model k greater one, right?

MR. KLOSKY: Mark Klosky, DCS.

Let me try to differentiate between the probability of moving the system from normal conditions to a limit, and at this point it's .95, for argument's sake. There's a certain sequence of events that have to occur for us to approach .95, and then, as Chris illustrated, there's a certain probability that .95 represents critical.

In benchmarking the code, what one does is take critical experiments, determine bias, determine uncertainty, but, as Chris has illustrated, there is an inherent uncertainty, or perhaps beyond which Chris can elaborate, that NRC feels a certain margin needs to be added. You could statistically account for the number of exponents using statistical measures, of course, but I guess the question of representative of the data to the application is where the NRC is, I think, coming from, but I'll let Chris speak to that.

MEMBER WALLIS: But if NRC feels it is a good enough margin, that is not a very defensible position.

1	MR. TRIPP: Well, it is a bit of a
2	quandary. There never has been a lot of guidance or,
3	frankly, consistency in approaching this issue.
4	MEMBER APOSTOLAKIS: Is there a place
5	where I can go and understand this issue better? Is
6	there a report that describes all this, how the
7	calculations are done, and so on?
8	MEMBER POWERS: Oh, how the calculations
9	are done?
10	MEMBER APOSTOLAKIS: Yes, and the kind of
11	issues that are taken into account.
12	MEMBER POWERS: Well, I'm not 100 percent
13	sure what you're asking here, but if you want to know
14	how you calculate k-effective yes?
15	MEMBER APOSTOLAKIS: No, no, no, no.
16	MEMBER WALLIS: What's the process of
17	evaluating
18	MEMBER APOSTOLAKIS: The process of doing
19	this.
20	MEMBER WALLIS: Right.
21	MEMBER APOSTOLAKIS: That's the question.
22	I mean, there's must be somewhere where it is
23	described.
24	MR. TRIPP: It is. Well, it's described
25	in the first of all, it's described in the Standard

1	Review Plan somewhat. There are also a number of
2	NUREG documents that have been prepared that discuss
3	in-depth validation methodology, and we can provide
4	you references to those.
5	MEMBER APOSTOLAKIS: Good.
6	MR. TRIPP: And the Validation Report, DCS
7	has submitted a Validation Report that goes through
8	this in great detail.
9	MEMBER APOSTOLAKIS: Well, maybe that will
LO	be the one.
L1	MR. TRIPP: Okay.
L2	MEMBER WALLIS: Is there any kind of
L3	inspection check that is some sort of an indication of
L4	what k-effective you're actually achieving?
L5	MR. TRIPP: Not really. I mean, you don't
L6	know the true k-effective of the system. That's why
L7	you have to back off with a conservative margin. If
L8	it goes critical on you, you know you're over one.
L9	(Laughter.)
20	MEMBER WALLIS: So that's a yes or no.
21	It's a rather frightening test.
22	CHAIRMAN BONACA: Well, he explained the
23	concern is that you may estimate it is at .95 and the
24	reality becomes critical.
25	MEMBER WALLIS: It may actually be .98.

1	CHAIRMAN BONACA: Okay, so you want to
2	have assurance of margin. The question that's being
3	asked is, could you explain for one of these processes
4	where the issue is? I mean, why are you concerned
5	that the calculation you are making, in planning for
6	that activity, may lead you to a one when you believe
7	that you calculated .95?
8	MR. TRIPP: Well, each of these has a
9	for each of these areas, there's a number of
10	benchmarks that are analyzed. They calculate
11	k-effective, experiments that have a k-effective very
12	close to one. They calculate a spread in the
13	k-effective values.
14	CHAIRMAN BONACA: Okay.
15	MR. TRIPP: So you apply a statistical
16	methodology to determine sigma on that.
17	CHAIRMAN BONACA: Okay.
18	MR. TRIPP: And there's a confidence limit
19	associated with it. So it's a statistical methodology
19 20	associated with it. So it's a statistical methodology you go through.
20	you go through.
20	you go through. MEMBER APOSTOLAKIS: Well, that's what I
20 21 22	you go through. MEMBER APOSTOLAKIS: Well, that's what I want to read about.

1 MR. TRIPP: -- which is separate from this 2 CAR. 3 CHAIRMAN BONACA: Going a step further, 4 the concern now is? 5 MR. TRIPP: Well, the basic concern now, we could look at the next slide. That really 6 7 illustrates the four areas where we have remaining 8 concerns. 9 CHAIRMAN BONACA: Okay. But they all revolve around 10 MR. TRIPP: 11 the first one, essentially, and it's the lack of 12 plutonium and MOX benchmarks with certain physical characteristics such as benchmark experiments that 13 14 contain certain absorbers that are desired to be 15 credited; for instance, borated concrete, cadmium, steel, and so forth. Also, benchmarks for certain 16 17 neutron energies, certain plutonium isotopics, 18 hydrogen-to-Pu ratio and that sort of thing. 19 are gaps in the data, and there are questions about 20 which benchmarks are applicable in which range. 21 CHAIRMAN BONACA: And you're concerned 22 that, without this validation of the computer code, 23 the computer code may not give you the .05 margin? 24 MR. TRIPP: Right, right. 25 CHAIRMAN BONACA: Okay.

1	MR. TRIPP: Without the validation, you
2	may calculate something as sub-critical when, in fact,
3	it may be critical.
4	CHAIRMAN BONACA: Okay.
5	MR. TRIPP: So I've talked about the first
6	one a little bit. The second one I'll talk about a
7	little bit more is there is a new methodology that's
8	been developed over the past several years by Oakridge
9	National Laboratory, which is sensitivity uncertainty
10	methodology.
11	MEMBER APOSTOLAKIS: So that's available,
12	too?
13	MR. TRIPP: That is. Yes, there are
14	NUREGs that you can read about that.
15	MEMBER APOSTOLAKIS: How many NUREGs? You
16	keep saying, "NUREGs." You have a number of NUREGs
17	for each item? Isn't there a single place where I can
18	go and find out?
19	MR. TRIPP: There are a number of reports
20	that are prepared that all deal with validation
21	methodologies.
22	MEMBER APOSTOLAKIS: A number of them? If
23	I read the latest, would that be okay?
24	MR. TRIPP: Well
25	MEMBER APOSTOLAKIS: This seems like an

1	overwhelming amount of information. For every item,
2	there's a number of NUREGs.
3	MR. TRIPP: Well, yes, it's a complex
4	process. It's kind of difficult to get your hands
5	around it. That's true.
6	MEMBER WALLIS: How do you train someone
7	to do it?
8	MR. TRIPP: Experience, using the code
9	MEMBER POWERS: I'm going to have to ask
10	members to move right along. We've got more
11	contentious issues ahead.
12	CHAIRMAN BONACA: I think the most
13	important point right here for the Committee is to
14	understand how far are you from resolving these open
15	well, how far are they from resolving these open
16	issues? You have a history here in the back of how
17	you raised the issue; you received information and
18	MR. TRIPP: Yes, why don't we turn to
19	that
20	CHAIRMAN BONACA: Okay.
21	MR. TRIPP: because you can ask any
22	specific questions about those issues, but I'll move
23	along here.
24	We received the latest revision of the
25	Validation Report in January. We had received a

1 couple of prior revisions. It comes in three parts, 2 and it's separate from the CAR. I think one of them 3 is on the third revision now. 4 But we received the latest version in 5 January. We had a meeting in March to discuss the major issues which appear on the previous slide, and 6 7 we received the SCALE 5 code from Oakridge in May. That's been under development. 8 It has not been released to the criticality community for general use. 9 We're the only ones, outside of the developers, that 10 11 have access to it at this point in time. 12 We are using it to do our independent, confirmatory calculations. 13 14 MEMBER RANSOM: Isn't that a DOE code? 15 MR. TRIPP: Yes. It's prepared by Oakridge under contract to NRC. 16 17 MEMBER RANSOM: Okay. And it was also used by 18 MR. TRIPP: 19 Oakridge as part of supporting the DCS submittal for 20 the part that deals with MOX and plutonium powders. 21 We issued an RAI. I should point out that 22 we have only -- we had actually received an updated 23 version of the Validation Report addressing these issues within the last week. So we're in the early 24 25 stages of reviewing it.

1	They appear to redefine some of the ranges
2	of parameters to much narrower ranges in some of the
3	parameters, and it looks as though that may address
4	some of our issues.
5	MEMBER WALLIS: Do they monitor how well-
6	mixed the powders are? That must have a great effect
7	on criticality?
8	MR. TRIPP: Yes.
9	MEMBER WALLIS: Are they monitoring it all
10	the time of how well-mixed the powders are?
11	MR. TRIPP: Yes. Well, from the point
12	where the powders, where the depleted uranium and
13	plutonium powders are blended together, the
14	homogeneity is very important.
15	MEMBER WALLIS: Yes.
16	MR. TRIPP: It has a big effect on
17	criticality.
18	MEMBER WALLIS: It's monitored all the
19	time? It is monitored?
20	MR. TRIPP: Yes, it will be monitored.
21	The amounts of uranium and plutonium will be monitored
22	that are going into the tank.
23	MEMBER WALLIS: And how well-mixed it is
24	very important?
25	MR. TRIPP: Right. Right, it has to have

1 the right moisture content. They have a mechanical 2 stirrer, and so forth. I believe it's also sampled to 3 ensure that. 4 MEMBER RANSOM: Will Framatone be using 5 French data or is there any French data on this process, criticality, I guess, data? 6 7 MR. TRIPP: Are you referring to benchmark 8 experiments? Right. Well, benchmark 9 MEMBER RANSOM: 10 codes, I quess. 11 MR. TRIPP: Well, they're actually using 12 a different code than what the French used. using the SCALE code, which is an American code. 13 14 French use the Apollo code, which is the French code. 15 So although they're doing the design, they're using different tools to do so; plus, we have different 16 isotopics. So for the ranges the physical parameters 17 are somewhat different. 18 19 So. in conclusion, we found 20 acceptability of all the design bases except for the 21 k-effective limit. We knew very early on in the 22 review -- in fact, before we even started working on 23 the MOX -- that this would be probably the most 24 challenging part for criticality safety, due to the

scarcity of available benchmarks.

1 We are in the process of reviewing the 2 Validation Report, the most recent one that was just 3 submitted in July, and we are using this new code to 4 resolve some of the open issues. Hopefully, we'll 5 have it resolved by September. MEMBER RANSOM: How is this related to --6 7 least from mу experience, most criticality accidents have happened as a result of inventory 8 9 control problems, you know, in different parts of the 10 process. 11 Right. MR. TRIPP: 12 And you want to prevent MEMBER RANSOM: So is this tied in with some kind of accumulation. 13 14 inventory control process? 15 MR. TRIPP: Yes. For instance, in the 16 blending, you're measuring -- you have like a flow 17 totalizer to measure the amounts of powder that are going into the blend tank, or in the glove boxes you 18 19 have mass limits. So it requires you to track the 20 amount of material. 21 Then in the ventilation, we're using this 22 same philosophy we're using for the waste storage, 23 where we have two barriers. So there could be a slow 24 accumulation over time, and I would expect that to be

haven't

received

monitored,

but

we

25

detailed

1 information at this stage, at the CAR stage on that. 2 MEMBER POWERS: I would like to move on to 3 the next topic, if we could. 4 MEMBER WALLIS: Well, things are going to 5 heat up a bit. Is this fire safety? 6 MEMBER POWERS: 7 MEMBER WALLIS: Yes. 8 MR. WESCOTT: Hi. My name is Rex Wescott. 9 I'm the ISA Reviewer, and I'll be talking about the MOX fire protection review. 10 11 Next slide. There was concern in the 12 Subcommittee about the plant's design basis in regard 10 CFR 70 does not contain explicit to fire. 13 14 requirements for facility fire protection analogous to 15 what you might find in 10 CFR 50.48 or Appendix R. Instead, fire protection is implicitly addressed by 16 the performance requirements. 17 The applicant must assure that 10 CFR 76 18 19 requirements are complied with under all credible fire 20 scenarios. At the MOX facility, this compliance is 21 assured through a combination of prevention, and I 22 define "prevention" as no incipient fires. In some 23 areas, prevention can be no emission sources, but I 24 think overall no incipient fires is probably a good

25

definition for prevention.

1 We define prevention in the AP process 2 cells, where actually emission is prevented, and you 3 find prevention in the inerted glove boxes, glove 4 boxes that are inerted by nitrogen. So if you do have 5 an ignition source, you won't have a fire. Another means of fire protection and 6 7 suppression and/or combustible loading controls -- and I put these together because what they do is they 8 allow a fire, but they don't allow a fire that's going 9 to lead to a release. And you find this --10 11 MEMBER WALLIS: Another method of sort of 12 prevention is this requirement to keep the temperature of liquids five degrees below the flash point? 13 14 would seem to me a pretty small margin. 15 MR. WESCOTT: I'm not sure about -- well, I mean keeping liquids below the flash point is 16 17 certainly a means of fire protection because, after all, if you get to the flash point, you still need an 18 19 ignition source to start a fire. I mean, 20 allowing the liquid to get above the flash point is 21 not going to start a fire in itself. 22 MEMBER WALLIS: I just wondered. It just 23 struck me that five degrees didn't seem to be much 24 margin.

MR. KLOSKY:

25

This is Mark Klosky, DCS.

1 We've had recent communications with NRC. We're amending that response. We're going to an LFL 2 3 argument, and it's --4 MEMBER WALLIS: A what argument? 5 MR. KLOSKY: Based on the percentage of the flammability limit. 6 7 MEMBER WALLIS: Flammability? 8 MR. KLOSKY: Yes. So we are going to 9 amend that response. We're working with NRC. It's an 10 open item. 11 MEMBER WALLIS: Thank you. 12 WESCOTT: Yes, I think that's a MR. chemistry open item, is probably one of the reasons 13 14 I'm not terribly familiar with it. 15 We define suppression and combustible loading controls in the truck base, the secured 16 17 warehouse. In the glove box area, you have clean agent suppression because they are moderator control 18 areas, and you have, basically, combustible loading 19 controls in the fuel rod and canister storage areas. 20 21 Now the third means of fire protection is fire barriers. What fire barriers do is confine the 22 23 internal fire to one fire area, and where the fire can 24 be tolerated, and you also protect against external fires using fire barriers. 25

1 Go to the next slide. The fire protection 2 strategy for MOX does not incorporate a universal design basis fire, such as, say, a 1-kilowatt power 3 4 fire for one hour or something analogous to that. 5 But we do have the fire protection strategy dose incorporate some quantitative values. 6 7 For example, fire area boundaries are a minimum of a two-hour fire, as per ASTM E-119. Compartment air 8 9 temperatures into the ventilation system are limited to 2,000 degrees Fahrenheit. That's at the intake, to 10 protect the final HEPA filters. The dilution of the 11 12 air brings it down to less than 400 degrees, which is the design basis for the filter at the final filters. 13 14 We have some material confinement 15 barriers, like the various transport casks, which are 16 actually as per DOE design. They do have a temperature and time limit on them. So the idea there 17 is to make sure that the fire in a compartment 18 19 affecting these particular transport casks is limited 20 by controls or suppression to something less than that 21 temperature --22 MEMBER WALLIS: It's a strange number. 23 It's 800 degrees C. 24 MR. WESCOTT: Yes, 800 degrees C is right. 25 (Laughter.)

That's right. I'm sorry, I stuck with English units here.

The next slide. The one remaining open item in fire protection is that the applicant has evaluated fire scenarios where temperatures could exceed the E-119 curve. What we're concerned here is rise the possibility that the very fast in temperature, primarily due to liquid hydrocarbon fires, could put a stress on the wall that's not really being taken into account with a standard fire test. What we need is a demonstration or evaluation, an explanation, that the fire barriers can the rapid fire development withstand compromising their integrity.

Next slide. Now I'm going to replace this slide with a slide I prepared last night from a response we got from the licensee that may better explain the problem. This is really more of a cartoon than an actual presentation of the problem.

MEMBER APOSTOLAKIS: I'm just curious, while they are getting ready: We had a presentation by the staff two or three years ago, when they were talking about their fire research program, and there were all sorts of limitations listed in the standard fire curve. Now we turn around and use it.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1 MR. WESCOTT: Okay, maybe I'll have to go 2 back to the other slide. 3 (Laughter.) But this is the licensee's response to us. 4 5 MEMBER APOSTOLAKIS: This is the E-119 curve. 6 MR. WESCOTT: 7 This is a standard curve. These are the results of some of their fire modeling. 8 Now, with hydrocarbons, the type of curves 9 10 they're getting there is not unexpected. In fact, 11 that's always been a trouble with the E-119 curve when 12 you're dealing in the petroleum industry, and the petroleum industry has really done a lot of research 13 14 and has developed some new rating curves. In fact, I 15 think they've developed a 1708, D-1708, curve, which is shown on the slide I just had taken off. 16 17 In fact, if we could go back to that slide now, it will show the problem. This is the E-119. 18 19 is the D-1708 that was developed I 20 primarily by the petroleum industry. What we're 21 hoping is that, maybe by comparing the walls -- well, 22 it's really up to DCS how they want to deal with this 23 problem, but one possible solution may be to compare

their walls with walls that meet this hydrocarbon

curve and be able to show that, not only would the

24

1 wall withstand an E-119 curve fire, but would also 2 withstand a hydrocarbon-type fire. 3 MEMBER APOSTOLAKIS: So remind me what the 4 curve means to begin with. 5 WESCOTT: Well, it's temperature versus time. 6 7 MEMBER APOSTOLAKIS: Yes, and what does 8 that mean? MR. WESCOTT: Well, what they do, how they 9 run a fire test, is they have these furnaces, and this 10 11 curve was developed, oh, probably in the 1920s or so 12 from what they called "fire crib tests," where they set on fire cribs of wood that they think will 13 14 approximate what you would find in a building, a 15 house, and measure the temperatures. Well, once this curve is established, then 16 17 in your testing facility you have gas furnaces and you fire these, so that the temperatures are met as a 18 19 You have a wall. Say you're testing a wall. 20 You have a wall set up, and you have thermocouples on 21 the other end of it, on the other side of it. 22 The criteria is normally 325 degrees 23 Fahrenheit because that's often the point where paper 24 or other ordinary combustibles will catch on fire. 25 MEMBER APOSTOLAKIS: Yes.

1	MR. WESCOTT: So to pass the rating, it's
2	got to withstand, you know, it's got to stay below 325
3	on the other side, and then just to make sure, they
4	hit it with a fire hose after it's all fueled. That
5	kind of shows that it has maintained its integrity.
6	MEMBER APOSTOLAKIS: What are the units in
7	time? I can't read it.
8	MR. WESCOTT: Oh, those should be hours.
9	Well, let me see, I don't know whether it's
10	MEMBER APOSTOLAKIS: It's longer than
11	hours.
12	MR. WESCOTT: No, in minutes, I guess.
13	Minutes, minutes, those are minutes. Let me see if I
14	have
15	MEMBER APOSTOLAKIS: So I have a fire on
16	one side for 20 minutes at a certain temperature, then
17	if I follow this curve, I'm guaranteed that the other
18	side of the wall will be 300 degrees or something?
19	MR. WESCOTT: That's right, or less.
20	That's the whole intent.
21	And that concludes my presentation.
22	MEMBER POWERS: We have had, in our
23	discussions, one other issue having to do with the
24	suppression system being used in some of the
25	compartments, where they were using this

1 Intergen? Right. MR. WESCOTT: 2 MEMBER POWERS: -- Intergen gases. The 3 question was one really of rediffusation, and what-4 not. 5 MR. WESCOTT: Right. MEMBER POWERS: Have you looked at that at 6 7 all? Well, we had the Intergen 8 MR. WESCOTT: 9 people in and we were talking to them. I think 10 Intergen works very good on normal diffusion flames 11 like from hydrocarbons lot you get or οf 12 combustibles burning. They didn't completely address what it would do to a smoldering-type fire, which I 13 14 think is what you're concerned about. 15 In my opinion, and I don't know how Sharon is going to deal with this, but I think before we 16 17 really determine whether Intergen is proper or not, we have to know exactly what kind of combustible we're 18 19 talking about in the compartment. Intergen is still 20 probably going to be useful for knocking down the 21 initial fire. I mean, it may be very possible to 22 knock down the fire with Intergen and then go in there 23 manually and use other agents. 24 That gets into the pre-fire planning that is normally taken in a licensing stage. 25 So I don't

1	think it's a serious problem. Personally, I think
2	Intergen would probably work to knock down a
3	hydrocarbon fire
4	MEMBER POWERS: No question.
5	MR. WESCOTT: you know, quickly,
6	provided you take out all the delays and aborts and
7	that kind of thing that you normally find with the
8	gassing systems, but that can be done.
9	So there are solutions, but, yes, as far
10	as the inability to put out a smoldering, deep-seated
11	fire, we haven't resolved that yet with a gaseous
12	agent.
13	MEMBER POWERS: Okay.
14	MEMBER WALLIS: I'm sure we need to move
15	on. Did you resolve the soot, the soot in the
16	filters?
17	MR. WESCOTT: Yes, that's been resolved.
18	MEMBER WALLIS: Okay, thank you.
19	MR. WESCOTT: Is that it?
20	MEMBER POWERS: Steve, you didn't have any
21	other additional comments?
22	MEMBER ROSEN: No. I was going to ask
23	about the soot question as well.
24	MEMBER POWERS: Okay. We'll move now to
25	one of my favorite topics, Red Oil.

1	MR. MURRAY: Okay, thank you very much.
2	Good morning. My name is Alex Murray. My colleague
3	is Bill Troskoski. We have been working with other
4	members of the NRC staff reviewing chemical safety and
5	related issues. The one I'm going to talk about this
6	morning is Tributyl-Phosphate-Nitric Acid reactions,
7	often referred to as "Red Oil".
8	Next slide, please. On this slide I just
9	summarize a very quick description of what a Red Oil
10	is. It is a chemical reaction between Tributyl-
11	Phosphate and organic materials and Nitric Acid and
12	nitrate materials.
13	MEMBER APOSTOLAKIS: So the reaction
14	itself is the oil, Red Oil?
15	MR. MURRAY: Well, "Red Oil" as a term is
16	just, if you will, a nickname that was given to some
17	events, and in some experimental testing to try to
18	replicate the phenomena a reddish color has been
19	observed.
20	MEMBER APOSTOLAKIS: But when you say,
21	"Red-Oil," you refer to the reaction?
22	MR. MURRAY: Yes.
23	MR. TROSKOSKI: Yes, it's a Red-Oil
24	reaction
25	MR. MURRAY: Yes.

1 MR. TROSKOSKI: -- similar to many others 2 in the chemical processing industry. 3 MR. MURRAY: Yes, yes. It is a chemical 4 reaction. 5 One of the things about the reaction is, like many chemical reactions, it can generate heat, 6 7 thermal energy, and non-condensable gases, which can pressurize vessels and containers. 8 As with many chemical reactions, its rate 9 depends on a number of factors: the chemical species 10 11 which the concentrations, are present, and 12 temperatures and pressures, and so forth. Impurities can exacerbate the phenomena. Primarily, metal irons 13 14 tend to work in a way like a catalyst. 15 MEMBER POWERS: I have seen some speculate that, in fact, you have to have radiolysis or a 16 17 radiolytic decomposition products, in fact, to have that. 18 19 MURRAY: The phenomena has been 20 duplicated in tests without radioactive materials, but 21 definitely a radiolysis does exacerbate the phenomena, 22 Yes, no doubt about it. yes. 23 And in this particular MEMBER POWERS: 24 system, we don't have the kind of radiolysis you have 25 in fuel recovery systems?

1 MR. MURRAY: One does not have the gamma-2 type radiolysis and fission product, but one can have 3 the intense alpha radiolysis. 4 MR. TROSKOSKI: Which is why the applicant 5 has done a controlled residence time and exposure --MR. MURRAY: Right, right. 6 7 MR. TROSKOSKI: -- to limit that damage. 8 MURRAY: Yes, that was a proposed 9 control for the applicant on radiolysis. 10 The key concern about the Red-Oil 11 phenomena is it can be potentially explosive and cause 12 damage to system components. The next slide, please. This is just a 13 14 little summary of the background of why we are 15 concerned about Red Oil. There have been four reported accidents with equipment damage and release 16 17 of materials within a facility and/or on site. There been one accident where there has been a 18 has 19 significant offsite release, and that was in 1994 at Tomsk, in the former Soviet Union. 20 If you look at the historical record of 21 22 the reports of incidents where operators have noticed 23 pressure fluctuations or have heard odd sounds coming 24 from equipment, the conclusion has been that has been

a Red-Oil event that started but did not propagate

1 through to an explosion. 2 Now the applicant, DCS, has recognized the 3 Red-Oil phenomena as an explosion event or potential 4 explosion event, and they have proposed a prevention 5 strategy to protect the facility worker, the site at the DOE 6 site, the public, 7 environment. MEMBER WALLIS: Can I ask you, is there a 8 science for predicting these things? Is this chemical 9 kinetics and all that kind of stuff? 10 11 MR. MURRAY: There is some science to it. 12 There is a lot of empirical test data which is available as well. There are operating guidelines, if 13 14 you will, controls which are used by the Department of 15 Energy in their facilities. 16 MEMBER WALLIS: So a lot of it 17 empirical? 18 MR. MURRAY: Yes. 19 MEMBER WALLIS: Yes? 20 MEMBER POWERS: We should interject here 21 that in one of our Subcommittee meetings the licensee 22 brought forward its chemical staff who are undertaking 23 what I would say is one of the more mechanistic 24 assaults on the issue. I think that's more of a

longer-term effort than it is going to resolve this

1 particular design bases. 2 There have been episodic attempts to try 3 to develop an acute mechanistic approach. Ouite 4 frankly, the presentation that was made by the 5 applicant was one of the better ones I had seen in this effort, but you can't hope -- I think we would be 6 7 foolish to hope for mechanistic understanding of this 8 mysterious issue in the near-term. MEMBER RANSOM: Is this a reaction between 9 10 miscible or immiscible components? Is it like a solid-liquid phase reaction or liquid-liquid? 11 12 MR. MURRAY: Liquid-liquid-based reaction. MEMBER RANSOM: So they are miscible in 13 phases, basically? Maybe? 14 15 MR. MURRAY: There's some crosssolubility, but most of the reaction appears to occur 16 17 in the organic phase. And, again, there are a 18 MR. TROSKOSKI: 19 lot of intermediates that would be in the gaseous 20 phase. One of the things to 21 MR. MURRAY: Yes. 22 remember about the Red-Oil phenomena is it includes a 23 lot of intermediates of different types of species. 24 Their formation rates and their relative quantities

depend very heavily on the specific environment at the

1	time.
2	MR. TROSKOSKI: You have TBPs, butyls
3	MR. MURRAY: Yes.
4	MR. TROSKOSKI: and a whole host of
5	other characters that interact in different parallel
6	paths.
7	MR. MURRAY: Yes.
8	MEMBER RANSOM: Is the gas phase a product
9	of the reaction or does it participate in the
10	reaction?
11	MR. MURRAY: Yes.
12	MR. TROSKOSKI: Yes to both really.
13	MR. MURRAY: Exactly, exactly.
14	MR. TROSKOSKI: That's why it's so
15	complicated.
16	MR. MURRAY: Yes. At the gas phase,
17	reactions can actually exacerbate the consequence of
18	the phenomenon.
19	MR. TROSKOSKI: Some of the experiments
20	they have done, for example, if you have adequate
21	venting and you're pulling off the intermediates, you
22	will only get just maybe 10 or 15 percent of the
23	theoretical amount of heat generated because the
24	reaction doesn't go to completion because of the

contribution of the volatiles that are being pulled

off. That's why when we get to venting it's so important. It actually lowers the available energy of the reaction because it can't all go to completion.

MR. MURRAY: May I have the next slide, please? Okay, on this slide we have summarized the applicant's approach. The applicant has proposed three PSSCs, principal structure, systems, and components, with five safety functions to address and prevent the phenomena. The applicant has also made a distinction about open versus closed systems, which I will discuss a little more in a moment.

The PSSCs, the offgas system, the process safety control subsystem, and the chemical safety control system, which is an admin. control. I have listed the safety functions there.

Next slide, please. On this slide I have just put forth the definitions of open and closed systems that the applicant is using. For an open system, it is capable of fully venting the runaway if you will, Red-Oil reactions reaction, the themselves which generate these intermediates and flammable gases, and this is heavily based upon experimental results conducted for the Savannah River site. The safety factor is approximately 2.5 over the minimum required. It also assumes the presence of 100

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1 percent of organics in any of the vessels, which would 2 be categorized as open systems. 3 Closed systems, however, are defined a 4 little differently. Rather than being based on their 5 capabilities of venting, they are based on their abilities to mass-transfer material out, so that you 6 7 have evaporative cooling of the system. Evaporative cooling means you stay, remain at the nitric acid 8 9 water azeotrope temperature, or you do not exceed it, which is approximately 120 degrees Centigrade. 10 11 Now in a closed system the vessel can have 12 significant fractions of organic materials. The applicant just mentioned tens of a percent, but the 13 14 vessel itself cannot be 100 percent full of organic 15 material. They have proposed a safety factor, based 16 on essentially a heat balance, if you will, of 1.2 17 times the energy input into the system from external 18 19 heatings, such as via steam heating, plus the energy 20 generated internally by the Red-Oil reaction. 21 MEMBER WALLIS: This is a safety factor on 22 the energy balance --23 MR. MURRAY: Yes. 24 MEMBER WALLIS: -- to keep it cool? 25 MR. MURRAY: Yes, yes. And a key

1	distinction between a closed system as compared to an
2	open system is that, if a Red-Oil reaction starts
3	initiating in a closed system, the system itself is
4	not capable of fully venting the runaway reaction. So
5	it could pressurize.
6	MEMBER WALLIS: So runaway reaction is
7	different from just maintaining an energy balance?
8	It's like whether a fire initiates or not? So it's
9	the rate of change of energy production with
10	temperature and things like that?
11	MR. MURRAY: That's correct.
12	MEMBER WALLIS: You have to analyze that
13	whole thing?
14	MR. MURRAY: Yes. The chemical reactions
15	do increase their rates exponentially with
16	temperature. Usually, we use an Arrhenius type of
17	relationship, yes.
18	The next slide, please.
19	MEMBER WALLIS: This looks like a no-no,
20	this last bullet here.
21	MR. MURRAY: I'm sorry?
22	MEMBER WALLIS: This is a real no-no. I
23	mean, you're supposed to be able to vent a runaway
24	reaction, aren't you?
25	MP MIDPAY: That is the distinction

1	between an open and closed system. With a closed
2	system, the concept is that you have sufficient
3	evaporative cooling and mass-transfer of reactants
4	out.
5	MEMBER WALLIS: You stay away from the
6	runaway reactions?
7	MR. MURRAY: That is correct.
8	MEMBER WALLIS: If you did get it, it
9	would blow up the vessel?
LO	MR. MURRAY: If the venting becomes
l1	inadequate, you could overpressurize the vessel, yes.
L2	MEMBER ROSEN: Would you actually
L3	overpressurize the vessel or are there relief
L4	features?
L5	MR. MURRAY: At this time we're looking at
L6	this from more of a systems approach. At the ISA or
L7	operating licensing stage, we would look at specific
L8	components. It is likely there would be some form of
L9	relief devices.
20	MEMBER WALLIS: So you're working on that?
21	MR. MURRAY: Yes.
22	MR. TROSKOSKI: If you recall, they still
23	have committed to do a haz op as part of the ISA, and
24	for unit operations that's where you really get your
25	you nail down the safety of the system ops at that

1 stage. That's when they will determine whether or not they actually have to go back and change some of the 2 3 PSSCs; that's recognized in the regs. 4 MEMBER ROSEN: Well, that's a complicated, 5 convoluted answer to a simple question. The question is: Would you put on relief devices if you predicted 6 7 that under certain circumstances the system could 8 pressurize? 9 MR. TROSKOSKI: That would be one pathway 10 you could take. Another pathway would be cooling of some sort. 11 12 This is Mark Klosky, DCS. MR. KLOSKY: To address your question, our alternative 13 14 is to put additional features, IRFS, to further reduce 15 the frequency of that runaway reaction to the point that we meet the performance requirements. So I think 16 the NRC had alluded to our safety strategy as one 17 based on prevention of the runaway reaction, both in 18 19 the case where we have an open system and also even in 20 the event that the system is closed. Or I should say 21 it the other way around. 22 But the principal SSCs that we 23 proposed act towards preventing a reaction from the 24 point at which it would overpressurize the system. So

we have redundant temperature systems to shut the

1 system and basically never get to the point that the 2 runaway reaction is such that it accelerates. 3 In addition, we have a means to provide 4 the cooling, such that we don't exceed the boiling 5 point of the solution, and that is via the evaporative cooling. So in either case, we have multiple features 6 7 to preclude the runaway reaction. 8 MEMBER ROSEN: I guess you're one of those 9 people who doesn't believe in defense in-depth. MR. KLOSKY: No, I think we do. I think 10 11 our defense-in-depth feature, in fact, is -- we have 12 credited our filtration system as providing defense in-depth in fact. 13 14 MEMBER ROSEN: Filtration? 15 MR. KLOSKY: Our HEPA filters. So even if the event does occur, the radioactivity will be 16 confined. 17 MEMBER ROSEN: In other words, it will 18 19 explode the vessel? The vessel explodes --20 MR. KLOSKY: Correct. 21 MEMBER ROSEN: -- and into the cell? 22 MR. KLOSKY: Into the cell. 23 And probably ignites a MEMBER ROSEN: 24 fire, and then the HEPA filters ultimately control the 25 release?

1 MR. KLOSKY: That's correct. 2 MEMBER POWERS: I have to admit that, in 3 thinking about this issue, what you have outlined 4 there is a fairly classic approach to defense in-5 depth; that is, you've established one barrier. Ιf that fails, you have yet another independent barrier. 6 7 In thinking about it, Ι thought microscopically in terms of temperature control and 8 9 purity control on the Tributyl-Phosphate as defensein-depth measures. 10 11 MEMBER ROSEN: So what is this 12 extraordinary, even heroic, approach rather preventing explosion in the first place, preventing 13 14 pressurization by simply having a relief device? 15 mean, what is it about rupture disks or something like that that is an anathema to you, to the applicant, 16 17 and, presumably, to staff's acceptance of it? I mean all the time in 18 rupture disks are used the 19 industry for prevention of explosion of vessels that 20 are overpressurized. 21 MR. MURRAY: If I can continue -- well, I 22 think the applicant is going to address your question. 23 MR. KLOSKY: Yes. There are two aspects

the intermediates are volatile, butane, for example.

I think, as the NRC has discussed, some of

24

1 So might be able to accommodate the one 2 overpressurization, but previous events have, 3 essence, released quantities of butane. They didn't 4 overpressurize the system but they had subsequent 5 explosions. So the fact of the matter is you lead to 6 7 basically put the multiple layers of protection to preclude the event, and then, in fact, if the event 8 9 occurs, to have the means to filter any radiological 10 release. 11 So, in other words, simply making a vent, 12 you know, three inches larger doesn't get you out of the woods in all cases. We have very combustible 13 14 gases that are released as well that we have to 15 account for in any highly unlikely case where we do 16 have a runaway reaction. So that's our approach to defense in-depth. 17 MEMBER ROSEN: Okay. You're saying that, 18 19 if you release the contents of this vessel that's 20 running away, it would explode anyway? 21 MR. MURRAY: I'm not quite sure what you 22 mean by "release the contents," but if I can --23 MEMBER ROSEN: The vessel is pressurizing. 24 MR. MURRAY: MEMBER ROSEN: You insist on -- there's no 25

sort of rupture disk or relief valve because what I understand from this response is that, under those circumstances, if you did vent that vessel, the products that came through the vent, when they hit, presumably, the environment in the cell would explode anyway?

MR. MURRAY: It depends on many factors. It depends on the rates of generation, the back-pressure that exists before the relief or the device actuates, and so forth. It's a complex phenomenon.

MR. TROSKOSKI: It's the rate of reaction that you're worried about because you're always going to have that reaction going, a certain amount of it, at the lower temperatures and concentrations and pressures. But one of the things they found is that, if you have a back-pressure on it, you've got a controlled reaction going; you're removing the heat that's being generated, but if somehow you were to back-pressure it up to even two atmospheres, you would concentrate the gaseous face and increase the kinetics such that you would not take off and go to a runaway condition.

So to say venting to prevent overpressurization, that will not necessarily terminate the reaction once it starts if you've got a

1	critical back-pressure that's been built in there.
2	MEMBER ROSEN: So that's a much better
3	answer to me. It is that the rate of reaction is so
4	high under certain circumstances
5	MR. TROSKOSKI: Yes, and pressure, too
6	MEMBER ROSEN: a rupture disk would not
7	be able to sense it quickly enough to prevent the
8	destruction of the vessel in any
9	MR. TROSKOSKI: Exactly. That's why
10	you've got to prevent it from going over the edge to
11	begin with, yes.
12	MEMBER ROSEN: Now I have some sort of
13	physical understanding of what you're dealing with.
14	CHAIRMAN BONACA: We've got a problem
15	because we have right now four minutes left on the
16	agenda and we have almost half the presentation in
17	front of us.
18	MR. MURRAY: Actually, I'll go. The next
19	slide, please.
20	MEMBER WALLIS: This will be resolved by
21	September is really what we need to take away, is it?
22	MR. MURRAY: To help assist the staff in
23	evaluating this, the staff has conducted a top-level
24	fault tree analysis. I just have pulled two sections
25	from the tree. This shows the split between open and

closed systems.

For open systems, the staff has concluded that the control strategy proposed by the applicant gives adequate assurance. However, for the closed system, the staff still has a lot of questions and currently has not made a conclusion of adequate assurance.

If I could have the next slide, please? As part of this top-level fault tree analysis, we did develop a tree through for the closed system, and what we found was that there are essentially three reaction schemes or areas or types of reactions which seem to occur and contribute significantly to the phenomena.

There's a lower-temperature route, which becomes very significant about 90 to 100 degrees Centigrade. There's a middle-temperature route, which becomes extremely significant somewhere around 130 degrees Centigrade, and then there's a high-temperature group of reactions, which starts becoming significant at about 150 degrees Centigrade.

The staff has found that for the middle group of reactions, which becomes significant at about 130 degrees Centigrade, in closed systems that we have concerns about adequacy of meeting the prevention strategy.

The next slide, please. On this last slide, I'm just summarizing the staff conclusions and concerns to date. With an open system, the staff has found that the approach appears capable of meeting the highly-unlikely likelihood if such a system is designed and proposed at the operating license stage.

However, the closed system approach the staff does not currently accept. We're still doing some evaluations, and we are having discussions with the applicant about this. We are concerned that, at least based upon our analyses and our understanding of the phenomena and a look at analogies which are available that deal with facilities, for example, that the likelihood of the closed system of limiting or preventing this event is not highly unlikely.

We are concerned about some differences between this closed system approach as compared to existing facilities such as at the DOE Savannah River site. We have noted that a lot of the concerns seem to come down to some limitation on the reaction rates, such as limiting the temperature, if you will, the solution temperature that could be in the vessels or in the evaporative.

Now, currently, the applicant is to provide additional information based upon some reviews

1	and contacts they are making for existing facilities
2	which exist around the world.
3	And that concludes my presentation.
4	MEMBER POWERS: Any additional questions?
5	MR. MURRAY: Any questions?
6	MEMBER WALLIS: I know we want to move on.
7	I just hope that, when we do resolve this issue, there
8	is some information in there, so there's a place where
9	we can find it, so that we can look at it, if we have
10	questions about the runaway reaction, and so on.
11	Actually, a document would
12	MR. MURRAY: Yes, you are aware that the
13	staff has two draft Safety Evaluation Reports, and
14	those have
15	MEMBER WALLIS: But not just words, but
16	actually see some curves and analysis?
17	MR. MURRAY: Yes.
18	MEMBER WALLIS: Okay, thank you.
19	MR. MURRAY: Yes. You're welcome.
20	MEMBER POWERS: Drew, I suggest that we
21	move immediately to your concluding remarks on the
22	remaining open items.
23	MR. PERSINKO: One thing I do want to say
24	is I think I heard one of the members say that this
25	will be closed by September. I don't know if it will

be closed by September. It may; it may not.

All I can say is, as with all the open items, we are continuing a dialog with the applicant. In some cases I think the open items are closer to resolution than others, but I can't guarantee that they will be closed by September.

Okay, let's talk very briefly, then, about the remaining open items. Staff had a concern concerning titanium fires, the possibility of titanium fire igniting. Staff has adopted a prevention, has accepted a prevention strategy.

DCS proposes to use NFPA 70 regarding overcurrent protection ground faults in electrical system coordination. Staff is looking at that. Staff is discussing whether or not perhaps IEEE 242 would be a better standard for protective devices, and we are continuing to discuss that with the applicant.

The UO 2 burnback issue, MP-1, the issue here is that potentially UO 2 particles could be oxidizing and could travel through the ventilation system and potentially impact the HEPA filters. There are metal pre-filters. Staff is looking at the issue, but the issue that the staff is looking at is the metal pre-filters have a certain size -- I forget the number -- .05 microns below which it would not filter

out. The staff is looking at whether it thinks the size of the UO 2 particles could potentially go through the metal pre-filters.

I would like to point out, as with all these, we are discussing it with the applicant. I'll point out that in this case there was an NRC Information Notice 92-14 concern uranium oxide fires at fuel cycle facilities.

Hydroxylamine nitrate/hydrazine, the item is CS-2. This is another explosion event. The issue here is that HAN is used with nitric acid to strip plutonium from the solvent after the removal of the americium and gallium. Hydrazine is used to impede the reaction with the nitrous acid and, thus, increase the HAN availability.

This is another issue of the HAN is autocatalytic decomposition. There was an explosion that occurred at Hanford in the 1990s. As a result, DOE studied the phenomena. It developed what is known as an Instability Index to link the various parameters involved, such as chemical concentrations, molar ratio of nitric acid to HAN, temperature, concentration of metals, and pressure.

DCS has chosen not to use the Instability
Index because they feel that it doesn't accurately

represent their system, the reason being that they don't think it adequately takes into account the influence of plutonium. Instead, DCS has proposed a model that they feel better reflects their system. It's a series, I think, of five partial differential equations that need to be solved.

So the staff is looking at that proposed model. The staff is using commercial software currently to test the DCS model. Staff has done some runs of the DCS model. In some cases we were able to replicate the results obtained by DCS.

However, in some cases we still have some questions that we need to pursue about the model. I don't think we fully understand it yet, and that's an issue that we need to further discuss with DCS and perhaps visit the DCS offices in Charlotte to get a better hands-on feel for that model.

Another issue is the -- and this is really four issues. It has to do with design bases for hydrogen flammable gases. It has to do with the lower flammability limit. The applicant has proposed using a design basis of 50 percent for its lower flammability limit. Staff thinks that 25 percent is a better number.

It really comes down to an interpretation

1 of NFPA codes, NFPA 801 and NFPA 69. Staff has 2 interpreted it to mean certain things, and I think the 3 applicant has looked at it and I think they're 4 reaching different conclusions. This is one where we haven't had the most 5 recent discussion with the applicant yet. We need to 6 7 meet with the applicant. They are going to document their conclusions, and then I think we will follow it 8 up with a meeting with the applicant. 9 10 Emergency control room habitability, 11 CS-10, this is a matter of, what would be the proper 12 design bases for the emergency control room operators in order such that they would be aware of certain 13 14 chemicals entering the control room and be don 15 protective gear? 16 DCS has proposed TEEL-3. 17 should have talked about CS-5b first, but TEEL is a Temporary Emergency Exposure Limit. I will talk about 18 19 that in a minute, but they have proposed TEEL-3s 20 initially. 21 They have subsequently discussed -- staff 22 has discussed the issue with the applicant. 23 thinks that an IDLH value is perhaps a better one, an

Immediately Dangerous to Life and Health value. Where

the IDLH values are not available, DCS will rely on

24

1 TEEL-2 values. I think that the applicant has -- I think we're very close to resolving this issue, based 2 3 on what I understand the applicant will be proposing. 4 The last issue is CS-5b. This has to do 5 with the TEELs, Temporary Emergency Exposure Limits. TEELs were developed by the Department of Energy's 6 7 Subcommittee on Consequence Assessment and Protective 8 Actions. It was not done as part of the MOX Project. 9 The purpose was to serve as a temporary quidance until the American Industrial Hygiene Association publishes 10 11 emergency response planning guideline concentrations 12 for various chemicals. There's various TEEL levels: 13 TEEL-0, 14 TEEL-1, TEEL-2, TEEL-3. They all have a qualitative 15 effect associated with them, such as mild transient health effects or no irreversible serious health 16 17 effects, et cetera. There are two concerns the staff have with 18 19 One is that TEELs are really not an NRC-20 developed item or term. They were developed by a 21 committee of various DOE and DOE consultants from 22 across the complex and elsewhere. 23 But it's not cast in stone. Once you say 24 it, I mean it can be easily changed the next day, 25 actually, too. So that was one concern the staff had

1 with TEELs. That could be overcome by committing to 2 a value rather than a TEEL. 3 The other issue staff had concerns with 4 was the actual values proposed by DCS staff, thought 5 that these were, some of these were too high. where we are on this one is the staff has taken this 6 7 item. Staff recognizes that this issue is broader than the MOX project. It has implications across 8 other fuel cycle facilities as well. 9 Staff has assigned this to a senior NRC 10 11 technical individual not associated with the MOX 12 project to look at this on a broader basis. action at this point. 13 14 What I have here is my concluding slide: 15 Where were we and where are we today? Back in April of '02, we issued our draft Safety Evaluation Report. 16 We had approximately 56 open items. As you can see, 17 through the discussions, they actually went up a 18 19 little bit afterwards. The total went up, but at the 20 same time some of them were being worked off. So you 21 can see --22 But did they go up CHAIRMAN BONACA: 23 because there were new items or because you went back 24 and --I'm trying to recall now 25 MR. PERSINKO:

1 They went up in the course of the discussion why. 2 with the applicant in trying to resolve certain 3 issues. 4 CHAIRMAN BONACA: Right. MR. PERSINKO: But it's been level at 66 5 since January of '03, and there's been a 6 7 progression to resolving the issues. There are currently 12 open items, 10 of which are with DCS for 8 9 DCS action and two are with NRC. Like I said, we plan to continue to dialog 10 11 with the applicant up to a point. We will continue to 12 dialog as long as we can and then some, but there's going to be a point where we're going to have to say 13 14 -- I mean we'll continue to dialog, but if we don't 15 resolve it, we will be writing our Safety Evaluation 16 Report, and we still intend to issue a Safety 17 Evaluation Report in September right now, but it may include open items in the FSER right now. 18 19 MEMBER POWERS: What's driving putting out 20 the Safety Evaluation Report in September? 21 MR. PERSINKO: It's a commitment we made 22 from day one, from a very long time ago, and I think 23 the staff feels an obligation to meet its schedule. 24 CHAIRMAN BONACA: Regarding issues such as

the Red Oil, for example, are you looking for insights

1	on what took place in the licensing of the French
2	facility?
3	MR. PERSINKO: We have contacted some of
4	the French facilities. We're also looking for what's
5	done at DOE. We're looking for that for insight,
6	though. I mean we are not using the French facility
7	to license this plant. We do look at information from
8	the French, as well as what's done at DOE.
9	MEMBER POWERS: Any other questions to
10	pose to Drew?
11	(No response.)
12	We have some challenges right now. My own
13	intention is to proceed along on the same imperative
14	that staff feels that they have. We have an
15	imperative to report back to the Commission. So we'll
16	be writing a letter to the Commission in association
17	with this SER wherever it stands, and we'll do it for
18	the September meeting.
19	CHAIRMAN BONACA: I would suggest that it
20	would probably be when the SER is issued.
21	MEMBER POWERS: Yes.
22	CHAIRMAN BONACA: Keep it on the open
23	items
24	MEMBER POWERS: Yes, we'll have to write
25	to the Commission at that point and intend to do so.

My feeling is that I'm still very optimistic. I'm naive and stupid. I say everything is going to get resolved or resolved enough.

(Laughter.)

But, regardless, we'll write at that point.

I think it is important to remember two things in thinking about this facility. One is it is governed by Part 70, which is governed by, contains a rather different approach, and it is not our intention in this letter to address the wisdom of that regulation or any revision to that regulation, but, rather, to speak to this facility as it stands relative to that regulation.

The other thing to bear in mind is, as I said earlier, we're doing one MOX facility. We don't have on the books 5, 10, 15 of these. That may happen in some future time, but not now. I'm not interested in charting a new approach to the regulations of these facilities and new approaches to criticality safety.

CHAIRMAN BONACA: Looking at the issue of the open/closed system for Red Oil, if I remember, the philosophy that you applied for explosions was, or the applicant applied, was that they would focus on prevention rather than mitigation. So you're looking

1	there for assuring that the event of an explosion is
2	low enough that you would be comfortable with it, and
3	they're pursuing the same path, but you're not
4	convinced that the process right now allows you to
5	reach that conclusion?
6	MR. PERSINKO: That's correct. We have
7	the same goal: to prevent it with adequate margin.
8	I think it's a matter of technical/professional
9	judgments on when is enough enough and what are the
LO	right temperature values.
L1	CHAIRMAN BONACA: Do you feel that it
L2	depends too much on administrative guidelines? That's
L3	another issue of
L4	MR. PERSINKO: Do you mean the Red Oil?
L5	CHAIRMAN BONACA: Yes.
L6	MR. PERSINKO: I'm going to defer that to
L7	the chemistry folks.
L8	MR. MURRAY: We're still trying to
L9	complete analyses, if you will, a fault tree analyses
20	on the closed systems. One of the concerns in a
21	closed system is some of the admintype controls
22	cannot respond in enough time.
23	CHAIRMAN BONACA: So it's an issue of
24	defense in-depth in part, whether they rely on these
25	controls?

1	MR. KLOSKY: Mark Klosky, DCS.
2	I want to just follow up on that point.
3	I think you're correct in the statement that the
4	preventative strategy pertains to both systems, open
5	and closed. With respect to the administrative
6	controls, our controls on the steam temperature are
7	engineered controls and do not rely administrative
8	features.
9	CHAIRMAN BONACA: Okay, thank you. That's
10	good clarification.
11	MEMBER POWERS: Well, in addition, you
12	have purity control/temperature control, and now we're
13	discussing venting controls.
14	MR. KLOSKY: Right.
15	MEMBER POWERS: Now these are all pretty
16	much design and operation issues.
17	CHAIRMAN BONACA: Right, yes.
18	MEMBER POWERS: Any additional comments,
19	Drew?
20	MR. PERSINKO: No, I don't think so. I
21	mean, I guess I like the regulation was written, it
22	is a fairly recent regulation, within the last few
23	years. The Commission, during the Part 70 regulation
24	rulemaking proceeding, was very clear to the staff
25	that a quantitative analysis was not required. So, I
1	I and the second

mean, that's clear by the Commission. So we have this regulation which sort of has a quantitative, you might think a quantitative underpinning, but, yet, it does not require that there has to be quantitative analysis performed.

MEMBER POWERS: In addressing this issue,

I'm not willing to take that -- advise the Commission
on the wisdom or lack of wisdom of their decisions on
that. We may want to do that but separately from
this. I mean we want to stay within what the
constraints are here. I mean that has always been the
purpose.

Subsequently, we will be looking at the ISA on this at some point. One can imagine at some point we'll be looking at the ISA. Again, I'm not interested in taking on the issue of whether ISA or PRA is the appropriate thing in connection with the facility, but we may want to take that issue on and advise the Commission separately.

CHAIRMAN BONACA: Although, I mean, this is a facility which is quite different from a nuclear reactor. It's, in fact, a series of shells, of areas, and so on and so forth, and it even lends itself better to this approach than we would have on the normal reactor, I think.

1 MEMBER KRESS: Our sister Committee, ACNW, 2 took that issue up and advised the Commission that the ISA is a good way to go at this time, but eventually 3 4 they might want to think about going to full PRA, as 5 best I remember their advice. That's exactly right. MEMBER POWERS: 6 7 I'm, again, not interested in taking that issue on. I think we work within the constraints of regulation 8 9 in connection with this facility. I simply comment that, by and large, the 10 11 chemical industry has not gravitated toward the kind 12 of PRA that we are looking at, and I have to believe that you have to give some credence to the fact that 13 14 they have elected not to do that. I mean you have to 15 understand you can't automatically assume that we 16 This ISA approach looks attractive. 17 MR. PERSINKO: I think when you do a PRA is also a function of the hazard or the risk of the 18 19 facility. That has to be taken into account, too. 20 think, was sort of alluded to as 21 earlier, I look at a reactor as a close-coupled 22 system. What I mean by that is an event occurs and a 23 whole series of events happen right after that. 24 Automatically, a lot of things happen. 25 materials facility, it's In more

1	distributed throughout the plant and things can happen
2	at different points. It's not like you're trying to
3	prevent one thing like, say, a core melt. So I think
4	it's a different type of animal.
5	MEMBER ROSEN: Can I get away from the
6	philosophy questions for a moment and just talk about
7	closure of this open-versus-closed, this closed system
8	discussion?
9	I continue to be mechanistically
10	interested in how that's resolved. I presume that we
11	will follow this as we go forward?
12	MEMBER POWERS: Count on it.
13	(Laughter.)
14	Thanks, Drew, and thank you, people from
15	DCS. Your comments were valuable to us, and good luck
16	on your work to resolve all these issues.
17	I'll turn it back to you, Mr. Chairman.
18	CHAIRMAN BONACA: Okay. With that, we
19	will take a break now until five after 11:00.
20	(Whereupon, the foregoing matter went off
21	the record at 10:50 a.m. and went back on the record
22	at 11:07 a.m.)
23	CHAIRMAN BONACA: Let's get back to the
24	meeting and the next item on the agenda is proposed
25	criteria for treatment of individual requirements in

regulatory analysis, and Dr. Kress will take us through this presentation.

MEMBER KRESS: The title is a little bit cryptic. What this is about is when the staff has to do a regulatory analysis to see if some regulation can be put into place that causes the requirements to be put on a licensee.

The regulatory analysis calls for cost benefit and the analysis cost benefit criteria, and it is possible when you put together a rule that the rule could have several requirements in it. And now all the requirements may be fully necessary that the rule solve, and in fact some meant requirements may be just supportive of the whole rule. Now the question is for such a possibility that you may end up if you bundle all of these requirements together in one requirement the whole system may be able to pass the cost benefit criteria.

But one or more of these parts may by themselves fail a cost benefit if you just used it as a separate requirement. So the question is how do you deal with that situation, and how do you prevent just sticking in requirements in a bundled thing that overall meets the cost benefit.

But we may have some in there that should

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1 not be in there. So the staff has developed a way to 2 deal with this, and that is what this is all about. 3 CHAIRMAN BONACA: Well, the hydrogen rule 4 was a catalyst behind --5 MEMBER KRESS: Yeah, the hydrogen was, because there was several parts to it, like whether to 6 7 keep the fans powered, as well as the igniters, and so 8 that I think was the catalyst. 9 CHAIRMAN BONACA: So we may want to keep 10 that in mind as we go to the presentation, and it will 11 help us understand. 12 MEMBER KRESS: Right. Okay. With that, I will turn it over to whoever. 13 14 MR. RICHTER: Thanks, Dr. Kress. I am 15 Brian Richter, in NRR, and as Dr. Kress mentioned, we are here to discuss bundling, what it is, the concerns 16 that it has raised, what the staff has done 17 response to these concerns, what cementers have said 18 19 about what has been done, what the Commission has 20 done, and finally what the staff is proposing to do in 21 the future on this. 22 The objective for us being here today is, and at your invitation, of course, and we are 23 24 interested in getting your consent on the approach 25 that we are proposing on the bundling issue.

1 Given that this guidance we are proposing 2 is better than the existing guidance and addresses 3 issues that have not been raised before, we are hoping 4 that contained consent would allow us to get quicker 5 use by the staff in the regulatory analyses. However, if the staff is able to obtain 6 7 comments to improve the approach, and if needed to obtain additional information, it could be inserted in 8 a new revision that would be coming down the road to 9 the Guidelines 0058, which would be Revision 5. 10 Right now, of course, Revision 3 is out 11 12 there and what we are hoping to do is include some of these approaches in Revision 4. 13 14 MEMBER KRESS: What is this -- have you 15 released this proposal to public comment? 16 MR. RICHTER: Yes, correct. 17 MR. SNODDERLY: Excuse me, Brian. Brian, this is Mike Snodderly. Is it true that -- and as 18 19 stated in the Federal Register notice, that the public 20 comment period ended July 2nd? 21 MR. RICHTER: That's correct. 22 MR. SNODDERLY: Okay. Could you also give 23 the committee some idea of the number of comments you 24 received and the schedule that you think it will take 25 to resolve those?

1 MR. RICHTER: So far we have received one 2 comment that, and that was from NEI, and I will go Dr. Kress basically 3 into that in the slides. 4 explained the issue that we are dealing with. 5 The background also was mentioned dealing with combustible gas control. 6 There were three 7 actions in correspondence, in SECY papers, and SRMs, that related to the bundling issue. 8 The combustible gas control 50-44 was one, 9 and in the SRM that came down on that one the 10 11 Commission agreed with the staff's recommendations, 12 but they challenged the staff to establish a process solution. 13 14 MEMBER WALLIS: So we are dealing with a 15 process here in this discussion? Well, in the regulatory 16 MR. RICHTER: The second item of course was 17 analysis process. fitness for duty, and that was one another one that 18 19 got -- that was controversial, and the industry came 20 in expressing concerns. 21 The staff suggested that the OMB package 22 be rescinded and the Commission agreed to that, and 23 the SRM that the Commission came down with directed 24 the staff to ensure that the individual rule changes

are integral to the purpose of the rule, and cost

1 justified or qualified as back fit exceptions. 2 And then with SECY 01-0162. again with 50.44, and the SRM that came down on that, 3 4 Commission agreed with the staff's proposal and 5 directed the staff to implement a disciplined, meaningful, and scrutable methodology for evaluating 6 7 the value impact of any new requirements that could be added by a risk-informed alternative rule. 8 9 MEMBER KRESS: Let me ask you a question 10 about that. 11 MR. RICHTER: Sure. 12 I recall MEMBER KRESS: As in t.he combustible gas problem that they did sort of a 13 14 sensitivity uncertainly analysis, and it was more of 15 a sensitivity, but they had -- when you took the high end of the sensitivities, and the low ends of the 16 sensitivities, and did subtractions of the costs and 17 benefits on those, that it was indeterminate, in the 18 19 sense that you crossed over the line. 20 Now, how do you plan -- suppose that 21 happens again in some other back fit. Have you got a 22 way to deal with that issue now, or is that part of the guidelines that you are going to put together? 23 24 MR. RICHTER: I think basically the idea

for the Reg analysis is always meant to be as a tool

1 for the decision makers at the Commission, and to 2 provide them with that information I think is very 3 helpful for them to have to decide which way they want 4 to go with any given action then. 5 MEMBER KRESS: But when you have it in these places where it is hard to decide what to do 6 7 because the ranges of the sensitivity are such that you really have on both sides of the thing is that 8 there is no way to provide some guidance on what to 9 do, or is that just left up to the judgment of the --10 11 MR. RICHTER: Correct. I think you show 12 the best estimate, but then you show what occurs with the ranges and it is up to the Commission then to 13 14 decide. Ι mean, the staff might make 15 recommendation, but it is the Commission's final choice. 16 17 Brian, Frank Gillespie. MR. GILLESPIE: I am going to add a complication into the example, 18 19 because I am the only one that raised my hand on 20 50.44, because it gets to some of the other proposals, 21 and it was wasn't just stretching the limits if you 22 will in the gray area. 23 There are also two completely different 24 phenomenological questions which were discreetly

There was igniters which were generally

separable.

1 focused on early containment failure, and then there 2 was recombiners which were focused on late containment 3 failure. 4 And then mixed, because it was all the 5 hydrogen rule that had a phenomenological cost overlap and used the cost overlap to try to justify the 6 7 igniters, because if you didn't have the recombiners, 8 you would save so much. 9 think the separability of Ι technical issue is also in question here. It is not 10 11 just the cost part of it, and I think that is 12 important I think for where Brian is going with this. Does that sound familiar? 13 14 MEMBER KRESS: Yes. 15 MR. GILLESPIE: I think we had that 16 discussion. Do you remember that? 17 MEMBER KRESS: Yes, I remember it. MEMBER LEITCH: Can you help me with the 18 19 document that we are dealing with here, the regulatory 20 analysis? Is that -- I have not heard that term. 21 that a document? 22 Yes, it is a back-fit MEMBER KRESS: 23 document. This guideline, this regulatory analysis 24 quidelines, the NUREG, that is an extremely 25 interesting report to read, and each one of us ought

1 to get a copy of it and read it. 2 It tells us how to do these back-fits, and it is very well done I think. 3 It is well worth 4 reading. 5 MEMBER LEITCH: And that is the document that 6 7 we are relying on here? 8 MEMBER KRESS: Yes. Well, it is the 9 guidance that they are modifying. MR. MIZU: This is Gary Mizu in the Office 10 11 of the General Counsel. I just wanted to add a little 12 We have back-fitting guidance and we bit to that. also have the regulatory analysis guidance, which is 13 14 what we are talking about here. 15 And although there is an overlap, there are aspects of backfitting which are not covered by 16 17 the regulatory analysis guidelines. And just to give you a little bit of history why these regulatory 18 19 analysis quidelines exist, it is because early on in the Reagan administration the President issues an 20 21 executive order directing Executive Agencies to do 22 regulatory analyses. 23 And even though that executive order 24 didn't bind an independent commission like the NRC,

the Commission voluntarily agreed to do regulatory

1 analyses. And I think in the late 1990s, Congress 2 passed a law which actually made regulatory analyses 3 binding upon all components of the Federal Government, 4 including the NRC. 5 So now we are required to do these 6 regulatory analyses, and so our guidelines are 7 intended to -- I mean, they are part of 8 continuing effort to allow agencies to analyze potential activities and determine whether they make 9 10 sense. 11 I mean, that is what we are fundamentally 12 trying to do here. These guidelines are to help an agency understand whether proposed actions, whether 13 14 they be rule making or the issuance of orders, or 15 whatever it may be, whether it makes sense. Are the benefits justified and are the costs justified. 16 17 MEMBER WALLIS: Well, I was going to say that I am glad that Frank spoke up, because we don't 18 19 usually get involved with the regulatory process per 20 se, but he says that it is an issue of separability of mechanical issues, and if the mechanical issues are 21 22 tangled up, then there seems to be something that the 23 ACRS should be concerned with. 24 MEMBER KRESS: Well, we used to. They are

always dealing with some safety issue.

1	MEMBER WALLIS: Well, if it is just some
2	kind of bureaucratic process, we don't usually get
3	involved.
4	MEMBER KRESS: Yes, but we do get involved
5	in regulatory analysis, because that is sort of
6	MEMBER WALLIS: Because the technical
7	issues have to be sort of weighed, in terms of
8	economics, and reasonableness.
9	MEMBER KRESS: Well, when we get involved
10	with any kind of rule making in there, and that is
11	always associated with rule making.
12	MR. RICHTER: This slide goes over quickly
13	the activities that the staff has undertaken so far
14	basically for the formation of a working group. We
15	had a preliminary policy published for comment and
16	called for an open meeting. That meeting was held and
17	we revised our approach based on comments received,
18	and
19	MEMBER WALLIS: Were these comments from
20	industry?
21	MR. RICHTER: Correct.
22	MEMBER WALLIS: A typical public meeting
23	in other words?
24	MR. RICHTER: Exactly, yes. You have been
25	there? We went before the CRGR and received their

1 endorsement, and received approval from the Commission to go forward with it, and that was published. 2 3 It went out for public comment and it was 4 mentioned in April, and we got one comment on the due 5 date from -- or one letter from NEI on that date, and that is all that we are aware of having received so 6 7 far. 8 These are the criteria as they were 9 published on the most recent FRN on that. First, if 10 an individual requirement is necessary, and that is needed in order to the objectives of the rule, and 11 12 contain consistency with Commission policies, it does not need to be analyzed separately. In other words, 13 14 you could bundle it. 15 MEMBER KRESS: And how do you decide on 16 whether something is necessary or not? Do you have 17 some criteria? 18 MR. RICHTER: We went over -- let me try 19 to find the exact words. 20 (Pause.) 21 MR. RICHTER: The NRC maintains that if an 22 individual requirement is integral to the purpose of the rule, then that fact alone is a sufficient basis 23 24 for its conclusion. And in fact a decision on its 25 inclusion or exclusion is not discretionary.

1	However, if the NRC finds that if a
2	requirement is not deemed integral, it should be
3	included if it is oops, I am going ahead into some
4	else. But basically it is judgment based on whether
5	it is integral and necessary, or whatever, and words
6	that one feels more comfortable with.
7	I think that there is mostly agreement,
8	except in the example that Frank brought up, and which
9	was a technical difference really. But we hope
10	spelling this out covers that issue.
11	MEMBER LEITCH: If I understand then to
12	pursue Frank's hydrogen example, since the igniters
13	and the recombiners deal with separate phenomena, at
14	least phenomena that occur at different times, we are
15	saying that they should be stand alone analysis to
16	justify those?
17	MR. RICHTER: Correct.
18	MEMBER LEITCH: Okay.
19	CHAIRMAN BONACA: So in the case of the
20	rule, if it had been shown that you needed monitoring
21	of the hydrogen as a fundamental element of the rule,
22	then you would not have to analyze its value
23	separately?
24	MR. RICHTER: Right.
25	CHAIRMAN BONACA: And in the rule itself

1	we found that it wasn't justified. But that is really
2	the criteria that you are using?
3	MR. RICHTER: Yes.
4	MEMBER WALLIS: So this second part here
5	really is equivalent to saying that this individual
6	requirement is cost beneficial per se within the
7	context of the whole thing.
8	MEMBER KRESS: Yes, it has to be cost
9	beneficial by itself is what they said.
10	MEMBER WALLIS: So this is a roundabout
11	way of saying it, is that it adds cost benefit to the
12	whole bundle.
13	MEMBER KRESS: Yes, but that is what it
14	means, that it has to be cost beneficial by itself.
15	MEMBER WALLIS: All right. Now, more cost
16	beneficial is simply in terms of plus and minus cost
17	and benefit, and it is not a question of ratios or
18	anything?
19	MEMBER KRESS: No. That was the debate
20	that we had a long time ago, of whether using ratio or
21	the difference, and they came down on using the
22	difference.
23	MR. RICHTER: And hat is OMB guidance as
24	well.
25	MEMBER KRESS: Yes.

1	MR. RICHTER: I mean, you can use the
2	ratio of on a
3	MEMBER KRESS: Yes, that is sort of
4	additional information.
5	MR. RICHTER: Yes.
6	MEMBER KRESS: And then when we talk about
7	cost benefit here, we are talking about the
8	difference.
9	MEMBER WALLIS: That is clear?
10	MEMBER KRESS: It is pretty clear in the
11	guidance.
12	MR. RICHTER: The next bullet on Slide
13	Number 10, if an individual requirement is unrelated
14	to the overall regulatory action, and it should be
15	included only if it makes the bundle requirements more
16	cost beneficial, and it passes the back-fit test, if
17	applicable.
18	CHAIRMAN BONACA: By itself, or bundled?
19	MR. RICHTER: By itself.
20	CHAIRMAN BONACA: By itself. So you have
21	to then
22	MEMBER KRESS: Well, you have to almost
23	analyze these things separately anyway.
24	CHAIRMAN BONACA: You're right.
25	MR. RICHTER: This aggregation is only
Į	1

1 appropriate if it produces substantively different alternatives with potentially meaningful 2 result implications on the cost benefit results. 3 4 And while this -- and while not directly, 5 but it is sot of the same guidance that we are looking at in terms of uncertainty, and to point out to where 6 7 the Commission or the decision makers, where this line might be where on one side it was cost beneficial and 8 the other isn't. 9 individual 10 Τf requirement in 11 voluntary rule is justifiable under back-fit criteria, 12 the NRC should consider imposing this as a mandatory back-fit. 13 MEMBER WALLIS: I am not quite sure about 14 15 this produces substantially different alternatives. Does that mean that you get more possible tanical ways 16 17 of resolving whatever the question is? 18 I'm sorry, what --MR. RICHTER: 19 MEMBER WALLIS: The second bullet, the 20 substantially different alternatives, this aggregation 21 per say doesn't produce does it? It allows them 22 consideration. 23 I think in terms of the MR. RICHTER: 24 analysis, the results. 25 Then it permits. This MEMBER WALLIS:

aggregation then permits alternatives. It does not by
itself produce anything.
MR. RICHTER: Yes, I see your point. Yes.
MEMBER WALLIS: So it allows more
flexibility.
MEMBER SHACK: What does this aggregation
cover that isn't in the first three criteria? I mean,
the first criteria covers all requirements that are
necessary, and the next one covers those that are
supportive, and the third one covers those that are
unrelated. What am I going to disintegrate to a
different scale than that?
MEMBER KRESS: Good question.
MEMBER WALLIS: Maybe it is a
reaffirmation of the first three.
MR. RICHTER: I guess the emphasis there
would be on
MEMBER KRESS: On alternatives.
MR. RICHTER: Yes, substantively different
alternatives.
MEMBER SHACK: Well, if something is
absolutely necessary, then maybe it isn't dependent,
but I just have a hard time seeing where I would use
it, versus the first three. The first three I can

1 MR. RICHTER: I don't remember way back 2 when as to how this particular bullet was derived, but 3 at least we are consistent. 4 MEMBER SHACK: Redundancy is a major NRC 5 flaw. MR. RICHTER: And lastly mandatory back-6 7 fit. As I mentioned, NEI were the only cementers that we are aware of so far, and it is has been a little 8 9 And their comments were similar or over a week now. with 10 identical the comments received on the preliminary proposal criteria, and those were the ones 11 12 published before the public meeting. NEI stated that they did not feel that 13 14 their comments had been addressed in preparing the 15 proposed criteria. Basically their concerns are that 16 they feel that the criteria is necessary to evaluate the bundling of individual requirements into a single 17 regulatory analysis. 18 And that the distinction on risk informed 19 20 voluntarial alternatives should be cost justified and 21 integral or necessary, and not cost justified or 22 integral, which is what the staff had been proposing. 23 And in the second bullet, they claim there 24 is a lack of scrutinable guidance by the NRC.

related to that is saying there is too much use for

1	objective judgment in making bundling decisions, and
2	we are requesting another public meeting on the issue.
3	MEMBER KRESS: So you have not resolved
4	these.
5	MR. RICHTER: We think we did, but not to
6	their satisfaction.
7	MEMBER KRESS: I see.
8	CHAIRMAN BONACA: Could you go back a
9	moment. On the first bullet or sub-bullet
10	MR. RICHTER: Which is that? I'm sorry.
11	CHAIRMAN BONACA: Well, the one that says
12	not cost justified or integral.
13	MR. RICHTER: Okay.
14	CHAIRMAN BONACA: I mean, I don't
15	understand when integral would not be cost justified.
16	I guess I don't understand. I thought the integral
17	here in this context meant necessary.
18	MR. RICHTER: Yes.
19	CHAIRMAN BONACA: And by necessary, you
20	have already provided the definition which said that
21	it was cost beneficial. Oh, no, I see. I see. It
22	says necessary, meaning that the objective of the
23	rule, and it does not require a test of cost
24	effectiveness.
25	MR. RICHTER: Correct.

1	MR. GILLESPIE: Let me give you an
2	example, 50-69. The industry might say that if you
3	separate out the need for a quality PRA that that in
4	and of itself, that the cost of that is not justified
5	necessarily if you separate it.
6	But the staff used a quality PRA as being
7	integral to being able to meet the mission of the
8	rule. Now, that is kind of an extreme example and it
9	is not that we are fighting with
10	MEMBER KRESS: That is a good one though.
11	MR. GILLESPIE: NEI on that, but that
12	is the rule that is a cost beneficial alternative rule
13	that is risk-informed, and the quality of PRA is a
14	point that they are making. They are pushing too high
15	for a high quality PRA. There is costs involved.
16	And it is not integral to the purpose, and
17	we are saying that it is integral to the purpose of
18	the rule. And that is where you get to the end of the
19	order.
20	MEMBER WALLIS: I would be inclined to
21	support you folks.
22	MR. RICHTER: Great.
23	MEMBER KRESS: And what do they mean by
24	this lack scrutable guidance thing? It seemed pretty
25	scrutable tome. What guidance were they talking

1	about?
2	MR. RICHTER: The proposed guidance in the
3	Federal Register notice.
4	MEMBER KRESS: I see.
5	CHAIRMAN BONACA: But the cost benefit
6	approach is still the same, and it has not changed.
7	MEMBER KRESS: Oh, no, that has not
8	changed.
9	MR. RICHTER: And at some point it does
10	involve the judgment and the staff's position is that
11	if one tries to spell out every possibility as to when
12	to do this or that
13	MEMBER KRESS: If things come down clearly
14	to cost benefits, you won't have a problem.
15	MR. RICHTER: That's right.
16	MEMBER KRESS: It is when you are getting
17	close to the border of the criteria, and the
18	uncertainties are pretty large, they become murky
19	then, and that may be where the
20	MR. RICHTER: But our position is that as
21	long as that is spelled out in the analysis to give
22	the decision maker the opportunity
23	MEMBER KRESS: The decision makers know
24	what they are dealing with if you tell them what that
25	is.

1 MR. RICHTER: Correct. 2 MEMBER KRESS: Okay. MR. RICHTER: So the working group --3 4 unfortunately, most of the working group is on leave 5 right now, but as soon as we come back, we will get 6 together and try to resolve the comments. 7 present what we have agreed with to management, and 8 see if management agrees that another public meeting 9 is worth it or not. Hopefully then we can draft the revised 10 11 guidelines input, and submit it to the Commission. The revision will also include additional information 12 on the handling of uncertainties. Ashok Thadani wrote 13 14 to Bill Travers on October 1st of 2002 on the, quote, 15 revision to NRC's regulatory analysis guidelines in RES Office Letter 1, to conform to OMB's information 16 quality guidelines. 17 In it, Research wanted to the Reg analysis 18 19 quidance to more closely conform to the treatment of 20 uncertainties as prescribed in OMB's information 21 quality guidelines. 22 There was an attachment to that which 23 contained Research's review and recommended revisions, 24 which are consistent with the general discussion of

COM SECY-02-0037, which was approved by the Commission

1	on July 31st, 2002.
2	MEMBER SHACK: What was that SECY?
3	MR. RICHTER: It was a COM SECY-02-0037,
4	July 31st of 2002.
5	MEMBER KRESS: I am interpreting the fact
6	that these are the only comments that you got back to
7	mean that the industry in general is not too unhappy
8	with.
9	MR. RICHTER: I would like to interpret it
10	that way.
11	MEMBER KRESS: Usually when they are not
12	too pleased, you get lots of comments from
13	MR. GILLESPIE: Yes, I think you are
14	right. I think that these comments reflect the
15	ongoing discussion about quality PRA and risk informed
16	alternatives, and the cost of doing a high quality
17	complete PRA, versus the alternative.
18	And the other one is a residual one from
19	the first example, which was the fitness for duty
20	rule. The drug testing case and the quality of drug
21	testing was separable from some of the other issues in
22	it.
23	And they are still reeling from that, but
24	I don't think you could set up guidelines that would
25	identify, and other than highlight, you should look

1	for that.
2	And also this idea that you have got two
3	different phenomenological effects on hydrogen control
4	that we ended up looking at. Well, not that we are
5	kind of consciously aware of it, I think that is
6	probably the best that we can do, which means that I
7	a not sure that another meeting is going to solve
8	these questions.
9	MEMBER KRESS: It doesn't seem like
LO	another meeting would.
l1	MR. GILLESPIE: I am leading a little bit
L2	there.
L3	CHAIRMAN BONACA: The first bullet from
L4	NEI really refers only to the fifth criterion that you
L5	had provided. I mean, that is the one on voluntary
L6	alternatives.
L7	MEMBER SHACK: No, I think it really goes
L8	to the second one.
L9	MEMBER KRESS: Yes, it goes to the second
20	one.
21	MEMBER SHACK: Where it is supportive.
22	MR. RICHTER: Yes, very much so.
23	CHAIRMAN BONACA: But it speaks of risk-
24	informed voluntary initiatives.
25	MEMBER KRESS: I know that.

1 CHAIRMAN BONACA: And if you look at the 2 fifth criterion, it requires a voluntary rule. MEMBER SHACK: You see, they only want you 3 4 to have an interval. 5 MR. GILLESPIE: Right. CHAIRMAN BONACA: But I wonder if it is 6 7 again applicable to the fifth criterion or the first 8 one. 9 MEMBER KRESS: Or the second. 10 CHAIRMAN BONACA: Or the second. 11 MR. MIZU: The thing about that first sub-12 bullet, where they talk about risk-informed voluntary alternatives, judging from what NEI had previously 13 14 argued in the 50-69 meetings, it is not so much that 15 they are concerned about it being risk informed. 16 They are concerned about it bering a voluntary 17 alternative. 18 CHAIRMAN BONACA: Voluntary. 19 MR. MIZU: And the reason why is because 20 the way that the Commission or the way that the staff 21 has previously evaluated both from a back-fitting 22 standpoint and from a regulatory analysis standpoint 23 a voluntary alternative, is that you are not required 24 to do it. You make your own judgment whether it makes

sense to you from a technical and a cost beneficial

standpoint for you to implement this alternative.

And the industry is coming back and saying, well, look, you are going to waste a lot of time and you are going to waste our time, and no one is going to use an alternative that you develop if you in fact -- even if it was voluntary, presumably you are developing it because you think you want people to use it.

But no one is going to use it if it in fact contains non-cost justifiable provisions, which I think on its face seems reasonable, and I guess that part of the analysis that we are trying to do here would in fact take into account those kinds of considerations, but not necessarily in the way that the industry wants us to do the evaluation.

I mean, we understand that you develop an alternative which pulls this inordinate cost, and contains minimal benefits. No one is going to use it and the Commission's regulatory objective is not going to be achieved.

But if no one is going to use this 50-69, then what is the whole purpose of wasting 5 years and multi-million dollars worth of staff FTEs to develop this alternative.

And we understand that. The problem is

1 that I think they are fixed to ensure that we have a 2 good cost beneficial alternative would probably not be 3 a good approach of doing it, and we think that this is 4 a better approach. MEMBER KRESS: Well, when I look at that, 5 I see, well, you are not going to have a voluntary 6 7 alternative in your set of alternatives unless it is first all integral, and if this is all parts of an 8 9 integral, because you have already said that you are 10 not going to have a necessary integral. 11 You also are not going to have it in there 12 as an alternative unless it is cost justified on the So I don't understand -- I really don't 13 14 understand their comment. 15 MR. RICHTER: Our response in the FRN reads that they NRC maintains that if an individual 16 requirement is integral to the purpose of the rule, 17 then that fact alone is a sufficient basis for its 18 inclusion. 19 20 MEMBER KRESS: Yes. 21 MR. RICHTER: And in fact a decision on 22 its inclusion or exclusion is not discretionary. 23 However, the NRC finds that if a requirement is not 24 deemed integral, it should be included if it is cost

justified. This alone is a sufficient basis, because

1	cost benefit methodology directs one to select the
2	alternative with the largest net benefit.
3	MEMBER KRESS: Sure.
4	MR. RICHTER: This is clearly stated in
5	OMB guidance, and guidance contained elsewhere in
6	NRC's Regu analysis guidelines.
7	MEMBER KRESS: Yes, I think that is a good
8	reply. The only problem I might have with it is
9	deciding whether something is critical or necessary,
10	and that takes that judgment. I mean, there is not a
11	clear cut thing, but you have always got to deal with
12	that.
13	MEMBER WALLIS: But that is what they are
14	after isn't it, is this Criterion 1, which is that by
15	requiring something that isn't necessary, you can get
16	away from cost benefit.
17	MEMBER KRESS: Yes.
18	MEMBER WALLIS: And they are worried about
19	that, because the agency will how say, well, all these
20	things are necessary.
21	MEMBER KRESS: Well, you don't get away
22	from the cost benefit. You just you have to
23	remember that this is bundling.
24	MEMBER WALLIS: IT's bundling, and you
25	iust don't do it separately.

1 MEMBER KRESS: Yes. But there is another 2 part of it, which says that the regulatory analysis --3 MEMBER WALLIS: So you don't et away from 4 cost benefit. 5 MR. MIZU: You don't get away from it, but I think to understand what the industry is talking 6 7 about, and how this bundling can hide things, let's 8 suppose you have an element which is integral, okay, 9 but it is very close to the line, okay? The costs are relatively high and the 10 11 benefits are perhaps just a little bit higher than 12 that, okay? And then you have another benefit which is not integral, but cost beneficial. But this cost 13 beneficial element is very high. I mean, you have a 14 15 very low cost, and very great benefit. 16 And you throw it into the mix. 17 have these two things, and that when you do the overall aggregated analysis, you are going to show a 18 19 very big benefit, and that very big benefit is sort of swamping or obscuring if you will the fact that the 20 21 integral method is kind of close. 22 And that is what the entry is saying. 23 need to be aware of that, and that is where the --24 when we talk about the judgment of the reviewer to say

perhaps this is a situation where this aggregation is

1	necessary to present the true nature of what is
2	happening.
3	MEMBER KRESS: And that goes to this
4	aggregation wouldn't it?
5	MR. MIZU: Yes, and in that case, this
6	aggregation would likely be a better thing to do.
7	MEMBER KRESS: But this aggregation means
8	that you identify separate components and count them
9	as one?
LO	MR. MIZU: Right. And NEI complained that
l1	the that we didn't provide them sufficient guidance
L2	or we did not provide the NRC sufficient review so
L3	that that process of deciding when to disaggregate is
L4	"scrutable."
L5	Well, I just gave you an example. How do
L6	you write down judgment in a way that would allow the
L7	NRC reviewer to take into account all of the potential
L8	different ways that these different requirements could
L9	be bundled together.
20	MEMBER KRESS: Well, we just have to fess
21	up that you can't get judgment completely out of it.
22	You have to got to rely on your good judgment.
23	MR. MIZU: Exactly.
24	CHAIRMAN BONACA: But it seems to me also
25	that the fact itself that now in the benefit analysis

1	that you have to disaggregate and evaluate both sides
2	good, and so why not. I mean, the analysis become
3	much more clearer than it was before.
4	I mean, that already answers the concerns
5	of NEI.
6	MEMBER KRESS: And you generally do this
7	aggregation anyway when you are doing the cost
8	benefit, because that is the way you decide on the
9	different policy efforts, and so it generally shows
10	up.
11	CHAIRMAN BONACA: That's right.
12	MEMBER KRESS: Are there any comments or
13	questions?
14	MEMBER SHACK: Doesn't Bullet 2 still
15	slightly scrape the back-fit rule? The back-fit rule
16	says that you not only have to have a cost beneficial
17	thing, but you have to have a substantial
18	MEMBER KRESS: Oh, that is still in there.
19	MEMBER SHACK: Well, doesn't Bullet 2 get
20	you
21	doesn't it sort of scrap that substantial part?
22	MEMBER KRESS: No, I think that would
23	still be there.
24	CHAIRMAN BONACA: Okay.
25	MEMBER KRESS: Which page are you on?

1	MEMBER SHACK: Page 9.
2	CHAIRMAN BONACA: Page 9, the second
3	bullet.
4	MR. MIZU: You have to remember that not
5	everything is redacted and so you may have situations
6	where I mean, you assumption is that every new
7	requirement has a back-fit, and that is not necessary
8	true.
9	For example, 50-69 would in fact not be a
10	back-fit.
11	MEMBER KRESS: That's right. Any other
12	comments or questions?
13	MEMBER WALLIS: What do we have to do,
14	Tom, about this?
15	MEMBER KRESS: Well, I was struggling with
16	this, and they would like a letter, particularly if we
17	think that this is a good fix or a good set of
18	guidance, and I am considering having such a letter.
19	I think that this addresses the issue that was brought
20	up by the Commission and it addresses it in a pretty
21	good way, and I can think of no other way to do it
22	actually.
23	So I am thinking about just a simple
24	letter that
25	MEMBER WALLIS: A simple letter?

1	MEMBER KRESS: Yes, that says something
2	like that. But we can talk about it when we get to
3	the letter writing session.
4	CHAIRMAN BONACA: Okay.
5	MEMBER WALLIS: I think it should be
6	simple, and should not get embroiled in all sorts of
7	legalistic
8	MEMBER KRESS: Right, I don't want to do
9	that.
LO	MEMBER SHACK: That is a cost benefit
L1	itself, and I think you would love to weigh in on
L2	this.
L3	MEMBER KRESS: Yes, that is one of your
L4	themes throughout here.
L5	MEMBER WALLIS: All rules of cost benefit,
L6	all regulations based on cost benefit?
L7	MEMBER LEITCH: I really have sort of an
L8	unrelated question, but the other side of the coin
L9	really. Let's say that industry I guess it is
20	really related to risk.
21	Let's say that industry comes in with a
22	change that they want to make in a plant that has
23	several different components to it. One of them
24	increases the risk, but several others are included,
2.5	and perhaps my example unrelated, that decrease the

1	risk. So that the net reduction is a very small
2	change in risk.
3	MEMBER KRESS: That is a very interesting
4	observation because that relates to 1.174.
5	MEMBER LEITCH: Yes.
6	MEMBER KRESS: And how you deal with
7	bundling there.
8	MEMBER LEITCH: Yes.
9	MEMBER KRESS: And I think that is a good
10	question.
11	MEMBER LEITCH: And I don't have any
12	you know, does this raise the issue of do we need to
13	clarify what our position is in that matter, or is it
14	already clear? I'm not sure.
15	MEMBER KRESS: I think that issue has been
16	before the staff and I am not sure if they have come
17	up with any guidance or not.
18	MR. GILLESPIE: I have been involved with
19	meetings that have wrestled with the question, but I
20	have never been involved in a meeting that wrestled
21	with the answer.
22	So I think that is a good point. That
23	causes us then to jump into discussions to defense in
24	depth and saying that I am changing my initiating
25	frequencies, and so I am giving up mitigation, and at

1 that point the discussions usually get so complex that 2 we never actually gone to a resolution. 3 time to revisit it in the 1.174 space. I think that is a real 4 MEMBER KRESS: 5 interesting question that we ought to have on our table to think about. 6 7 MEMBER LEITCH: You will recall that we had a licensee come in with an application for power 8 9 uprates a few months ago, and they were doing a number 10 of things. 11 But of them was improving the one 12 reliability of the stand-by liquid control system by I think using enriched boron or I forget exactly how 13 14 they were doing it. 15 And they were making the case that this power uprate was actually decreasing risk, because the 16 17 slick changes more than offset the other changes, although it was not a fully risk-based analysis. 18 19 it is not really a perfect example, but it shows how 20 one can play with the modifications a little bit and 21 get some strange things going on. 22 MEMBER ROSEN: But in that case that 23 brings up the question of whether the slick capacity 24 increase was integral to the change.

CHAIRMAN BONACA:

25

That's right, and are

1	they related.
2	MEMBER ROSEN: And should in fact be
3	credited.
4	MEMBER LEITCH: Well, it seems to me
5	MEMBER ROSEN: If they had not asked for
6	an upgrade, would they have done the slick change?
7	And the answer is no, and so it seems to me
8	MEMBER LEITCH: But it is independent of
9	it. I mean, you could do the slick with or without
10	the
11	MEMBER ROSEN: That is arguable.
12	MEMBER LEITCH: Well, the slick is really
13	independent of the power
14	MEMBER ROSEN: But it is arguable.
15	MEMBER LEITCH: Well, it is arguable.
16	MR. GILLESPIE: I think you would end up
17	in this kind of condition that we probably would not
18	have approved the upgrade if the increased margin
19	wasn't there, because we have got a new fuel design
20	and some other things that are going on.
21	So it may in fact be integral to the
22	ability to have sufficient shutdown margin and some
23	other things. And that is the difficult part. You
24	have to get the system and the fuels people over here

to say how did you guys interact on that question.

1 I don't know that it is obvious that it is 2 not integral or it has set the conditions up such that 3 the upgrade could be approved. MEMBER KRESS: Well, let me tell you how 4 5 I feel about that issue since we are just on the subject. Now 1.174 allows Pat to come in and request 6 7 a risk-informed change of any type if he wants to. 8 Now, let's take one where we have got a bundle for the 9 them together, and pass all the two of 10 quidelines. 11 Now if I take the slick one, for example, 12 what that does is lower the risk. I could have had a 1.174 just for that change alone without anything 13 14 else. All right. That put me in a status of CDF and 15 LERF down there. Now I say I have got a new condition. Now 16 17 I am going to do the power uprate. Now if the power uprate fits the rules from that point, then that ought 18 19 to be allowed, too. 20 So if you bundle them together and you end 21 up there, that is the same thing as doing them 22 separately. So it ought to be allowed if you end up 23 with the bundle making you meet the criteria, because 24 you could have done it separately in a risk informed 25 change.

1	You could have done them separately and it
2	would have taken just twice as much business, that's
3	all.
4	MEMBER ROSEN: But the more difficult
5	situation is that the power uprate would not have
6	passed by itself.
7	MEMBER SIEBER: That's right.
8	MEMBER LEITCH: But that's all right then,
9	because you have a new plant, and then it passes.
10	MEMBER SHACK: But 1.174 disagrees with
11	you, I believe. They discuss bundling and I don't
12	think you are allowed to
13	MEMBER KRESS: Well, that is not
14	surprising that 1.174 disagrees with me.
15	MEMBER WALLIS: Well, I think the slick
16	really was integral to the power uprate application.
17	It really reassured us that this was okay. That they
18	were tied together.
19	MEMBER KRESS: I don't think that is what
20	integral means though. But anyway I think that this
21	is probably a good fix, and I thank you guys. You did
22	as good as you can, and so we thank you.
23	MR. RICHTER: Thank you.
24	MEMBER KRESS: And I turn it back to you,
25	Mr. Chairman.

1	CHAIRMAN BONACA: Any other questions? If
2	not, we will take a recess until 10-of-1:00.
3	(Whereupon, a luncheon recess was taken at
4	11:51 a.m.)
5	
6	
7	
8	
9	
10	
11	
12	
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	
25	

1	A-F-T-E-R-N-O-O-N S-E-S-S-I-O-N
2	(12:55 p.m.)
3	CHAIRMAN BONACA: All right. The meeting
4	is back and we have now a presentation about the ESBWR
5	Pre-Application Review. Since Dr. Kress is on some
6	official mission, we will start and Dr. Wallis will
7	lead us into this presentation.
8	I would like to just point out that the
9	Dr. Ford?
10	MEMBER FORD: I have a conflict of
11	interest because I am a GE retiree.
12	CHAIRMAN BONACA: Okay. So you are not
13	allowed to say anything.
14	MEMBER FORD: You can still ask about
15	materials.
16	CHAIRMAN BONACA: You can ask questions,
17	but you can't answer any.
18	MEMBER FORD: You can ask questions of
19	fact.
20	CHAIRMAN BONACA: Okay.
21	MEMBER POWERS: And here comes Dr. Kress
22	so we can walk through this properly.
23	MEMBER KRESS: And we will get through it
24	a lot faster. I guess you guys have already
25	introduced this and started.
ļ	I

1 MS. CUBBAGE: I am Amy Cubbage, and I am the project manager for the ESBWR Pre-Application 2 I just found out my new organization's new 3 4 reactor section in NRR. 5 I just wanted to give a couple of minutes overview of what the staff is doing in association 6 7 with the pre-application review, and then I will turn the bulk of the presentation over to General Electric. 8 9 The pre-application review scope is listed here, and we are looking at the TRACG application for 10 11 ESBWR LOCA and containment analyses, and qualification 12 of the TRACG code; the test and analysis program description and PIRT, and we are also looking at the 13 14 SBWR and ESBWR test programs, as well as the SBWR 15 scaling report. The product of the pre-application review 16 will be a safety evaluation report on the TRACG 17 application and testing program. Although the scope 18 19 of the pre-application review is very limited, GE has submitted extensive volumes of documentation 20 21 support of the review. The staff has reviewed this information 22 23 and has generated over 300 requests for additional 24 information. All of these questions have been

discussed with GE in telecons and meetings that have

1	taken place over the last six months.
2	GE understands the staff's questions and
3	they have been very responsive to the issues. They
4	are in the process of preparing their responses to the
5	questions and those will be due back to the staff in
6	August.
7	MEMBER WALLIS: I am a little puzzled.
8	I'm sorry. I didn't ask you this question at the
9	subcommittee meeting, but how can you write a safety
LO	evaluation report on a code? A safety evaluation
L1	report has got to be on a substantial thing like a
L2	reactor isn't it?
L3	MS. CUBBAGE: We write safety evaluation
L4	reports on topical reports that describe the analysis
L5	methodologies.
L6	MEMBER WALLIS: Then maybe when you do it,
L7	we will ask you what the criteria have to be or
L8	something, because this just sort of seems anomalous
L9	to write about the safety of a code.
20	MR. LANDRY: If I may, Graham.
21	MEMBER KRESS: Safety evaluation reports
22	is just a name.
23	MEMBER WALLIS: It is just a name? Okay.
24	All right.
25	MR. LANDRY: Graham, this is Ralph Landry

1 from NRR from the staff. The safety evaluation report 2 on the code is a document that will define whether or 3 not the code adequately represents the phenomena that 4 we anticipate occurring in an accident or transient 5 condition in this particular design. And the way in which we do that is review 6 7 the modeling in the code, and the correlations in the code, and compare the code with the testing program 8 9 which has been testing phenomena in features unique to 10 this design. 11 And we look at those comparisons and 12 determine, yes, the code adequately represents the phenomena that are anticipated to occur in this 13 14 design, and then write an SER which says that the code 15 is applicable to them, the ESBWR design. MEMBER WALLIS: So the word safety is sort 16 17 of analogous, because there is no safety criterion applied to this. 18 19 MR. LANDRY: Not at this time. 20 MEMBER WALLIS: Because as we all know, 21 you don't have safety criteria that apply to codes and 22 the way in which they represent data. 23 MR. LANDRY: The safety criteria come into 24 play when we do the design certification review. 25 MEMBER WALLIS: Right. That's right.

1	MEMBER SIEBER: Your SER though is limited
2	to the transients that you test it against, as opposed
3	to just saying that TRACG is good code for everything.
4	It is limited to ATWS and LOCA, and abnormal
5	MR. LANDRY: Yes, that has always been the
6	case, that when we write an SER that we specify that
7	this particular version of the code is applicable to
8	these particular plants or these particular events.
9	MEMBER SIEBER: That's right.
10	CHAIRMAN BONACA: Thank you.
11	MEMBER SIEBER: And my notes say that you
12	had three of those, right; ATWS, LOCA, and abnormal
13	occurrences?
14	MS. CUBBAGE: For the pre-or-current scope
15	of the preapplication review, we are looking at LOCA,
16	ECCS, and containment. My next slide here for design
17	certification, the scope will include the other
18	applications.
19	However, transients, ATWS, and stability,
20	will likely be covered in a later phrase of the
21	preapplication review when we receive additional
22	submittals from GE. The schedule has not been set for
23	those yet.
24	MEMBER SIEBER: Thank you.
25	MS. CUBBAGE: And also

1 MEMBER WALLIS: I am still a bit confused 2 about -- I'm sorry, but at the subcommittee we heard 3 a lot about why this is a good reactor and so on, and 4 really that is not part of the scope of this at all. 5 MS. CUBBAGE: That's right. The design thoroughly reviewed during the 6 will be 7 certification basis. MEMBER WALLIS: So does that mean that we 8 9 should ask GE to focus more on the experiments and why they are good tests of the code, or should we hear all 10 11 the other material? 12 Well, I think that the MS. CUBBAGE: design just provides the context for understanding the 13 14 testing and analyses that have been done, and so they 15 provided that as background information to you, as well as to the staff, okay? 16 17 Well, that concludes my presentation. you have no other questions, I would like to introduce 18 19 Atambir Rao, who is the project manager for General 2.0 Electric. 21 MR. RAO: Good afternoon. We wanted to 22 make things absolutely clear so we brought our own 23 projector. Some of the questions on why 24 presentation on the design. The approval of the code 25 is based on an application to a design, and so the

1 design forms the background for the basis for the 2 approval. 3 And also one of the key aspects of the 4 approval process is that we are relying on the fact 5 that this plant has a lot of margin in the responses. So we believe that should make it easier for the staff 6 7 to find --8 MEMBER WALLIS: Well, that's true, but 9 that should not influence our assessment about whether or not TRACG is applicable, and the fact that it 10 predicts a big margin should not influence our 11 12 evaluation of TRACG. 13 MR. RAO: That's true. 14 MEMBER WALLIS: If we like the plan or not 15 is irrelevant. Well, that is -- yes. 16 MR. RAO: will be covering a little bit about what we are doing 17 in the overall program, and give you a design 18 19 overview. As far as the overall program is concerned, 20 our approach has been to follow a step-wise program, 21 where technology closure or preapplication of PRA as 22 it is called is the first step towards certification of the plant. 23 24 I believe the pre-application review is 25 more specific than this plant's application compared

1 to some of the others, where we are asking for a 2 safety evaluation report on the technology issues. 3 The overall design, I will assure you that 4 we have a lot of margin, and the margin is there by 5 design, and that we have also done a comprehensive testing and analysis program. 6 7 The bulk of the presentation will focus on 8 the technology program, where we develop а 9 comprehensive plan and we completed have implementation of that plan, which includes both 10 11 testing and qualification, and the use of a single 12 integrated computer code for analysis with a welldefined application methodology. 13 14 And what we are looking for from the staff 15 technology closure program is a safety evaluation report for TRACG. And this is all part of 16 our overall plan to basically try to minimize the 17 regulatory risks. 18 19 When we started the SBWR program we 20 submitted the safety analysis report, and the design 21 certification application, and the computer codes, and 22 testing, were all being reviewed in parable. 23 was a little bit messy in that sense, and it was not 24 a productive use of resources.

So this time we felt that it was better to

follow a step-wise approach to both the design development and the regulatory approval. In terms of the design development, we over the last 15 years have developed passive safety systems, which were then integrated into a plant design for the SBWR.

And where we completed a detailed system designs, PRAs, and looked to the building design. We also as part of that effort did an extensive testing and analysis program.

First we started the testing program, and then we went back and defined it. A new program, which was starting from scratch, which was a rigorous process that we followed for defining what would be the best needed to quality the TRACG computer code.

Then we went back and completed that test program, and at that stage we concluded that the SBWR was not economic at the 670 megawatts it was at. We marked on this program for the ESBWR, which where the E has now been defined as economic SBWR, and the program started off about 10 years ago.

It was a one person operation, and it was to improve the plant economics, and the design, and we focused on optimizing the design, and we relied on the economies of scale. We incorporated utility requirements.

1 We had a utility steering committee that 2 has been and are still providing guidance ont he design of the plant. And the overall program was a 3 4 market oriented program, and so we used the ABWR 5 experience basically using the same components. 6 Ιt was our overall plan for 7 commercialization of this plan has been based on 8 building one plant at a time. We are not looking for 9 a six-pack. We will take one if it comes, but it is based on the first plant has to be economical, and has 10 11 to meet all the commercial requirements. 12 So we are utilizing a lot of the ABWR components in the design. So that is what we did on 13 14 the design, and we realized last year that it was now 15 time to come back to the NRC and start the regulatory 16 improvement process. 17 And again on this one, we focused on a step-wise approach, and because the most fundamental 18 19 thing here is the design margin, and that is the most 20 important thing. That is what we made sure of, that 21 the design had plenty of margin and was simple. 22 And also to make sure that we had a solid 23 technology program, and I will describe what we did in 24 the technology program. What we are looking for a

safety evaluation report for TRACG, and we are using

a simple activity report, and I will show you a lot of the details and some of the testing.

In fact, I will give you an overview of the typical details and what they will be. It is too hard to go over in a meeting like this. After that, after we get closure on the technology, and a good feel that there is no additional testing needed and that the big part of the effort, the big uncertainty regarding the computer codes is over, we will then submit the safety analysis report for design certification.

GE is committed to develop a license for the ESBWR. The goals for the technology closure as Amy had mentioned is basically approval of the use of TRACG for analysis, and for vessel response to a pipe break, and the containment response to a pipe break.

And the vessel response to anticipated operational occurrences, and the submittals have covered those areas. The AOO has been slightly delayed because there is some additional information required by the staff, and it will take us a little more time to fill in that information.

The ATWS and stability area was also deferred in the original sets of submittals just because of timing. We wanted to make sure that the

1 first two especially, since those are the areas where there is a significant change in the technology, that 2 3 we get those off the table, and that is why we focused 4 on those two. 5 Even though I use the words significant change in the technology, I will also end up by saying 6 7 it is the same as standard BWR technology by the end 8 of the presentation. So that was something that was significantly new and different, at least in terms of 9 10 what people had seen in the past. 11 And of course one of the elements of the 12 approval of TRACG is the confirmation that qualification base of TRACG is adequate. Just to put 13 14 it in perspective, it is a 15-plus year comprehensive 15 technology program, and the question is whether that 16 is enough. 17 This is on TRACG or on MEMBER WALLIS: BWRs? 18 19 MR. RAO: On all the passive systems. And 20 10 years ago, the ESBWR started and the SBWR started 21 more than 5 plus years before that. 22 MEMBER ROSEN: Can Ι ask for 23 clarification of your question? Is that enough for 24 licensing, or enough forever, or what is the intent of 25 that question?

1	MR. RAO: The intent of the question is
2	more rhetorical, and that they have been at this for
3	15-plus years. We would like to have some closure on
4	that. That is more of a rhetorical question.
5	MEMBER POWERS: Were Professor Apostolakis
6	here, he would say that you could have been wrong for
7	15 years.
8	MR. RAO: Could have been doing what?
9	MEMBER POWERS: You could have been doing
10	it wrong for 15 years.
11	MR. RAO: Yes.
12	MEMBER ROSEN: And also what I was going
13	at was that it is never enough. I mean, there will be
14	technology questions that come up once the plant is in
15	service, and you will be back to doing you know, it
16	is an ongoing thing.
17	MEMBER KRESS: I think that this is not
18	for certification.
19	MEMBER ROSEN: That's what I thought you
20	meant.
21	MR. RAO: Well, right now we have the
22	first step of certification to get approval of the
23	TRACG, and we need to close out the testing program.
24	It is a practical thing, you know, a countless
25	researching effort that

1 MEMBER WALLIS: This is sort of like the 2 cry from Job is what it really is, isn't it? 3 MEMBER SHACK: Не is in the wrong business. 4 MR. RAO: I would like to finish it before 5 I have to retire. I am still young enough and still 6 7 have the energy. This just gives you an overall of what has happened in the evolution of the BWRs. 8 9 the top you will see that on the earlier BWR designs, BWR-4 and BWR-6, and BWR-3, et cetera. 10 11 And on the top part, you will see some of 12 the key parameters of the design, and in the lower part, you will see some safety related issues. And on 13 14 the last line, it will also give you a feel for the 15 overall economics. 16 What you see is that some of 17 parameters are pretty much -- they have stayed in the range where we have got experience. One of the things 18 that we wanted to make sure of was that he last 50 19 20 years worth of experience that we got from the BWR 21 technology when it comes to transients. 22 And as we have learned over the years is 23 that it is not the physics, and it is not the thermal 24 hydraulics. It is the materials that are the things

that are the biggest challenges.

1 In fact the chairman of our utilities 2 steering committee refers to those people who work in the thermal hydraulics area as that we need to get rid 3 4 of the thermal-hydraulic mafia. These are not my 5 It is the chairman of the steering committee's 6 words. 7 MEMBER POWERS: Could we invite him for a talk to assist the ACRS in its complaints. 8 9 MR. RAO: So the essence of --10 MEMBER WALLIS: He has been trying to do 11 it, too. 12 So what we have done in MR. RAO: Yes. the overall design out here is to make sure that we 13 14 use, and we do minimum extrapolations from operating 15 plants, because what you learn from the operating 16 plants, you want to make sure that you use it. 17 What you will see out here is, example, some of the big components, like the vessel. 18 19 The vessel diameter is the same as the ABWR. not want to use the same factories that we have for 20 21 the reactor vessel for the ABWR. We wanted to build 22 a new factor, because you have got to get a plant 23 order one at a time. 24 So the vessel height is about 6 meters 25 taller than the ABWR, and it is just an extra ring in

fact. The number of bundles is one row extra over the ABWR, and the fuel height is 3 meters, a little shorter than the standard BWR fuel.

The power density is in the range of the power density where we have got experience without the power uprates. The power uprate have gone up even higher than this, and some of the power uprates I think for BWR-6, I think the highest one is about 62 kilowatts per liter.

So this thing is still well within the range of where we have got experience. But what we have done int his plant is to reduce the number of components. We have gotten into the recirculation pumps, and we have simplified the safety systems and got rid of the pumps, the safety diesel generators, heat exchanges that you have in safety systems.

And that shows up in the last two lines. This is an interesting thing that has happened. The evolution of BWRs over a period of time, and when you go from left to right, you will see that the core damage frequency as we evolved the designs basically kept coming down, and the ABWR is down to about the level to as low as you are going to get to practically.

And that is a modest, best creditable,

core damage frequency that you are going to calculate.

Anything lower than that starts ending up in the range of it being not credible.

The ESBWR is in the same range as the ABWR, even though it has got a passive system. But the reason to going to passive systems is shown on the last line, which is that you have done it with a lot less.

As we went from left to right, you can see some of the earlier plants, the safety buildings were much smaller than those for the BWR-6s and the ABWRs. Now the reason for that is we added redundancy, more divisions, more pumps, heat exchanges, to get an improvement in the core damage frequencies.

But you pay a price for that, for the complexities. What we have done in this plant is that you get the same core damage frequency, but with less stuff. So it is basically like I said a simplified design , and the place to start is in the normal operation.

The wa that we did that is to get rid of the recirculation pumps. It is hard to imagine anything simpler than that. The feedwater comes in out here and flows up through the core, and it goes up through the chimney, to the separators, and to the

1	dryers.
2	All that you do is pull the rods, and the
3	thing reduces 1,400 megawatts without any moving
4	parts. No balls bouncing around, and things like
5	that. The only thing that moves is bubbles.
6	MEMBER WALLIS: What is the flow regime in
7	the chimney? What is the lowest void fraction?
8	MR. RAO: It is about 80 percent.
9	MEMBER WALLIS: So it is a pretty high
10	void fraction.
11	MEMBER KRESS: That is dispersed droplet
12	regime, I think?
13	MR. RAO: Yes. Okay. So the drive and
14	separator, and the standard BWR drives and separators.
15	Again, the biggest challenge for BWRs is the
16	materials, and so we made sure that the pressure, and
17	temperature, and other conditions were either or the
18	same as that for any of the operating plants.
19	We didn't go and increase the operating
20	temperature or any other conditions. We were just
21	keeping it within the range of what we got experience
22	with. In fact, the fact that we are relying on
23	natural circulation, and the flow rates are a little
24	less, or the stresses would be a little less in most

of the components down in the core region.

1 There is one new compliment, which is 2 called the chimney out here, and there were some questions in the subcommittee, and we will provide 3 4 answers later on at the next meetings. 5 Basically what we have done out here is that we have got a much bigger vessel, 6 meters taller 6 7 than what the ABWR is. There are some advantages to that. What it does is that it puts more water in the 8 vessel, which makes the operation of the passive 9 10 safety systems much better. 11 You will see that plant performance is 12 very benign, but we also need a bigger vessel to enhance the flow during normal operation and natural 13 14 circulation. 15 So if you get rid of one or the other, you still need a larger vessel, and the vessel does not 16 17 get much smaller. The passive safety and natural circulation in a boiling water reactor is sort of a 18 19 natural combination. You see a significant reduction in the 20 21 components, and this is an actual reactor system for 22 the ABWR, and we have eliminated all of that. We are 23 doing (inaudible) with controlled lower drives. 24 MEMBER LEITCH: Atam, I can't quite make

out what is going on in that power flow map down at

1	the bottom. How do you vary the power in this? In
2	other words
3	MR. RAO: The power is controlled by
4	controlled lower drives, and there is no flow control.
5	This power flow map is plotted this way, but it is a
6	little confusing in the sense that in this plant the
7	power is what is controlled, and so that is what
8	should be on the X-axis.
9	MEMBER WALLIS: Well, those lines are
LO	control rod settings aren't they?
L1	MR. RAO: Okay. Those are ABWR. The
L2	green is ABWR, and the red is BWR-5, and that is MELA
L3	Plus.
L4	MEMBER LEITCH: Okay.
L5	MR. RAO: And the blue is the ESBWR. So
L6	what we do in this, and you have to remember that the
L7	power is the variable that you control, and you get
L8	water flow coming from that.
L9	MEMBER WALLIS: So you really control your
20	control rods setting, which is at that angle, and the
21	constant control rod setting is an angle line about 60
22	degrees or something, or 30 degrees.
23	MR. RAO: Right. Now, this one, what you
24	will do is that when you pull the parts out, you will
25	basically get a certain flow, and it is a fixed flow

1 that you will get. And you do that all the 2 MEMBER LEITCH: way up to a hundred percent, right? You just keeping 3 4 pulling the rods out. 5 MR. RAO: Yes. MEMBER ROSEN: The feed water system is 6 7 just making things level. 8 MR. RAO: Right. It is a very simple 9 machine. No moving parts, and people are worried about stability in a boiling water reactor, and there 10 11 is matching circulation, and the reason for that is 12 that this is what the natural circulation flow line is for. The BWR-4 is this and this is what it is for the 13 14 ABWR. 15 And this is where you get the instability region. You can see that there is about 3 to 4 times 16 17 as much natural circulation flow in this plant compared to those for the operating plant. And very 18 19 simply what we did was that when you get -- it is not 20 really hi-tech. It is single phase flow. 21 You get rid of the restriction out here 22 and the downcomer, and that in itself enhances the 23 natural circulation flow for a standard BWR by a 24 factor of two.

MEMBER WALLIS:

25

Are you going to argue

1	that you cannot get into the instability region with
2	this?
3	MR. RAO: Right.
4	MEMBER WALLIS: That would be very
5	reassuring.
6	MR. RAO: There is no way to get out here,
7	you know.
8	MEMBER WALLIS: And you are going to show
9	us that in the future?
10	MR. RAO: In the future, yes.
11	MEMBER LEITCH: So the line I'm sorry,
12	but I can't quite make it out, but the blue line there
13	is the ESBWR?
14	MR. RAO: Yes.
15	MEMBER LEITCH: And at that point that is
16	a hundred percent?
17	MR. RAO: Yes. This plot is the average
18	power per bundle, and average flow per bundle. This
19	is not the standard power flow map, and we tried to
20	put it on to something that made sense.
21	MEMBER LEITCH: It looks like that line
22	bends back a little bit on itself there?
23	MR. RAO: Yes.
24	MEMBER LEITCH: So what is the
25	significance of that?

1 MR. RAO: This is what I am saying. 2 gives people concern over questions that you have an 3 unstable situation here, and you have got to remember 4 that the thing that it is controlling is the power, 5 and not the flow. So this should be the X-axis for the 6 7 ESBWR, the power. So you keep pulling the rods out and you will get some flow, and that is what this is 8 9 showing. 10 MEMBER LEITCH: And what are you plotting 11 along the bottom there? I can't quite see it. This is the average flow per 12 MR. RAO: bundle. 13 14 MEMBER LEITCH: Average flow per bundle? 15 Okay. I've got you. Just to put it in perspective, 16 17 the power flow ration is sort of a simple measure of whether you get stable or unstable. It is just one 18 19 measure, and it is not the total measure. It depends 20 on the power shape and all the other things, okay? 21 So the power flow ratio, when you draw a 22 line from here up through that for the BWR-5 there, 23 you can see the power flow ratio is about the same at 24 the hundred percent power per bundle. This is the 25 power flow ratio per bundle.

1	MEMBER WALLIS: But of course the chimney
2	affects the stability of the circulation, too, and so
3	you are going to have to tie all of this together.
4	MR. RAO: Right.
5	MEMBER WALLIS: You can't just translate
6	the stability area from one rack to the other. But
7	that is not today's discussion.
8	MR. RAO: Right. I was just trying to
9	give a simplistic description of that.
10	MEMBER ROSEN: Atam, you said one thing
11	that puzzled me. You said that the only new component
12	is the chimney, but the chimney is not a component.
13	It is just a great big open hole. What do you mean by
14	component?
15	MR. RAO: Well, it is a big piece of
16	blueprint out there. It is just a channel.
17	MEMBER ROSEN: Is it one big open
18	MR. RAO: No, it is .6 by .6 meters, the
19	partitions in there.
20	MEMBER ROSEN: So there are partitions?
21	MR. RAO: Yes, partitions in there.
22	MEMBER WALLIS: You have to lift the thing
23	out to refuel.
24	MR. RAO: No, you don't have to move it
25	out.

1	MEMBER WALLIS: You don't? You just sneak
2	around?
3	MR. RAO: You just go in and out through
4	that.
5	MEMBER SHACK: How much of the internals
6	could I remove in case I had a materials problem?
7	MR. RAO: All of them. They are designed
8	to be removable.
9	MEMBER FORD: So they are bolted?
10	MR. RAO: Yes, they are bolted. So what
11	we tried to do is that we have been learning over the
12	last 15 or 20 years, and one of the advantages of
13	having the 10 years to design it is that you pick up
14	all of the things that have happened in the last few
15	years.
16	MEMBER LEITCH: Could you get back to that
17	for just a second? Does the dryer go up into the head
18	as shown on that cartoon?
19	MR. RAO: I don't know whether there was
20	an actual vessel this is a cartoon, okay?
21	MEMBER LEITCH: Yes.
22	MR. RAO: I did not draw to scale on some
23	of the charts.
24	MEMBER LEITCH: I mean, I think that if
25	one should take the head of the dryer, the dryer is

1	still down below you is it?
2	MR. RAO: I don't know the exact location.
3	We might be able to see it in some of the later ones.
4	MEMBER LEITCH: Okay. There are some
5	actual drawings, and those that are drawn to scale,
6	and all the others are not to scale.
7	MEMBER LEITCH: You know, just one
8	problem. I had and this is a housekeeping thing,
9	but I had a problem opening that CD, and I could not
10	get the drawings. I don't know if the other committee
11	members had that same problem or not.
12	MEMBER WALLIS: I had some problem with
13	it.
14	MEMBER LEITCH: A proprietary CD from
15	General Electric, and I couldn't open it.
16	MEMBER WALLIS: It was mysterious. There
17	is no pdf, but some of them open and some of them
18	don't. I guess we can sort that out somehow.
19	MR. RAO: We can make some more different
20	ones, or we can make this one available, too. This is
21	not proprietary. The other thing that is kind of
22	interesting in this design is that we have combined to
23	reduce systems, and this is my personal favorite,
24	because what we did is that we got rid of the RHR
25	system.

1 There is no RHR system, and the major 2 innovation of this was that we took the standard 3 reactor water cleanup, which is the red line, and we 4 have given it a dual function now. It can perform 5 normal shutdown cooling. Basically, a reactor water cleanup system 6 7 is pumps and heat exchanges, and that is what a water shutdown cooling system is. So it takes it from the 8 vessel and puts it back into the vessel. 9 So what we did is for (inaudible) is that 10 11 we bypassed the regenerative heat exchanges and 12 removed the heat from these heat exchangers, and we used the same pumps to bypass the defamilizers, and 13 14 put it back into the vessel. 15 So that reduces and makes it a simpler. And it makes the operation also simple. It 16 17 is not just a complex system. What we have got now is a full pressure shutdown cooling system. 18 19 When you shut down a normal BWR, the RHR 20 only kicks in at 400 psi. So this is a little 21 innovation. 22 MEMBER WALLIS: So the nozzle sizes are 23 small, and so that the break is not a great disaster. 24 MR. RAO: Right. The nozzle sizes here on 25 the bottom are 2 inch nozzles. So it is a very small

1	nozzle there.
2	MEMBER LEITCH: And those pumps, aren't
3	they much larger than the present design?
4	MR. RAO: Yes. You have two pumps there,
5	one for the high flow an done for the low flow.
6	MEMBER LEITCH: Oh, i see. Okay.
7	MR. RAO: So what we did on the design was
8	basically make the heat exchanger is bigger by a
9	factor of four. And the heat exchanger bigger by a
10	factor of four is not a big deal. So that heat
11	exchanger got bigger and we added a paddle and pump.
12	MEMBER ROSEN: And you also designed the
13	system for full pressure?
14	MR. RAO: Yes.
15	MEMBER ROSEN: But the shutdown system was
16	not.
17	MR. RAO: Yes. Well, the shutdown system
18	was not. So now you have got a full pressure shutdown
19	cooling system.
20	MEMBER LEITCH: But you got it essentially
21	free because you had the reactor water cleanup system
22	as a full pressure system anyway?
23	MR. RAO: That's right. That was the
24	innovation here. I mean, it is not rocket science.
25	MEMBER LEITCH: You have to make reactor

1	water cleanup have more pumping capacity, because it
2	is only like a 10 percent success rate.
3	MR. RAO: You can't do it on the operating
4	plants because it didn't make sense, because the
5	operating plants, the RHR system needed a safety grade
6	for decayed heat removal following an accident.
7	Now, this one, the safety grade decayed
8	heat removal system is a passive system. So now the
9	question is what do you do for normal shutdown.
10	That's why it works out here than on the standard
11	active plant.
12	MEMBER WALLIS: This could be a safety
13	system, too.
14	MR. RAO: But it adds to the costs.
15	MEMBER WALLIS: I mean, it could be used
16	in an emergency.
17	MR. RAO: It could be used in an emergency
18	and we use it in the PRA. It is identified in the
19	PRA. This is what passive safety systems are.
20	Basically everything is right here in the containment.
21	And it is very simple. What you have is the standard
22	BWR pressure suppression system.
23	MS. CUBBAGE: Adam, you need to use the
24	microphone.
25	MR. RAO: Sorry. So what you have got

here is that the reactor vessel, and then we went up front he ESBWR in power, and the ESBWR had two steamlines and they are both steamlines in this, and we increased the number of steam lines.

We don't have to add a steam generator. Just increase the number of steamlines. These are the two feed water lines, and water comes in, and goes up through the core, and comes out through the steamlines.

These are the safety release valves, which perform the same depressurization function that we have on the standard BWRs for ADS function, automatic depressurization system. They blowdown into the depressurization system, and these are the quenchers for that standard.

The only difference is that this pool of water is down and raised off the base mat, and you could provide water in the vessel back to the vessel by gravity.

We added these pools up here, about a thousand cubic meters, and the ones that you would call the ECCS systems for this plant. It is a pool of water with a thousand cubic meters in total. It is not a big pool, and it provides water make up following a s loss of pool density.

1 So this replaces all the ECCS systems 2 makeup, and the only other thing left is the decayed 3 heat removal, and that is removed through heat 4 exchanges mounted on the top of the drywell. 5 I show you another picture what is there. So the containment is about the same size as an ABWR, 6 7 and all the safety systems are right in there. So that is an overall simplification of the design. 8 9 And all we have is a low pressure water 10 makeup system, and no accumulators like in other high 11 that could pressure systems give your system 12 This is not to scale, and -interactions. MEMBER LEITCH: Could you go back to that 13 14 previous one for just a moment? 15 MR. RAO: Yes. So in a loss of coolant 16 MEMBER LEITCH: 17 accident the drywell pressurizes and is there pipes like the Mark-II blown down into the suppression pool, 18 19 or what is the flow pattern there? 20 MR. RAO: Right there. If you have a pipe 21 break here, it flows down through here like the ABWR. 22 MEMBER LEITCH: That is an annulus is it? 23 Yes, that is an annulus, and MR. RAO: 24 there are 10 or 12 of these off the top of my head. There are 10 or 12 of these very large pipes, and they 25

1 go down into the suppression pool, and the horizontal 2 lines, like the Mark III and it is covered like a Mark 3 II. 4 So the initial blowdown was in the vector 5 suppression system. The only thing that is different 6 is after that the water make-up after that 7 pressurizes, and the water flows by gravity from these 8 pools in the vessel. And after the water flows into the vessel, 9 and this is not to scale, and please note that this is 10 11 just in order to show how all the systems fit 12 These are the pools that I was talking together. about and this is the vector suppression pool. 13 14 There is an isolation condenser which 15 takes care of removing the energy following a reactor isolation and in this plant the release valves are not 16 open following the reactor isolation. 17 So it is a much milder transient than 18 19 those in other operating plants. So not only have we made the accident response better, we have made the 20 21 plant transient response a lot better. 22 This line out here is the major innovation 23 of the old design, which is that this is the heat 24 exchanger for removing the decayed heat that goes into

the containment following a pipe break.

25

The steam

1 goes up here and it is condensed in that heat 2 exchanger similar to an isolation condenser. 3 But since there is non-condensables in the 4 containment, they have to be removed from that 5 condensing heat exchanger. And those get removed through this pipe that is here, which blows into the 6 7 wetwell, and that is all done by the pressure difference between the drywell and the wetwell. 8 9 moving parts, no valves, nothing. 10 It is always open, and so the decay heat removal for this plant is --11 12 MEMBER ROSEN: No vacuum breakers? MR. RAO: No, there are no vacuum breakers 13 14 between the drywell and the wetwell. 15 MEMBER LEITCH: Now, how do you get high pressure injection? Now, let's say you have a small 16 17 break LOCA. MR. RAO: We don't have a safety grade 18 19 high pressure engagement system anymore. If you have 20 a small break LOCA, some of the energy initially will 21 be removed from the isolation condenser system. 22 We have a non-safety grade system that 23 controls our drive system, which provides water 24 makeup. We have actually increased the capacity of 25 that compared to that for operating plants.

1	So they are non-ECCS systems which can
2	handle small break LOCA from a realistic point of
3	view.
4	MEMBER LEITCH: So the drive system pumps
5	become safety grade then?
6	MR. RAO: No, no. I said they are non-
7	safety. We just made them bigger actually. What we
8	did was that we added a line which injects through the
9	feedwater alignment and it is hard to show that in all
LO	of this.
L1	MEMBER WALLIS: But if you don't
L2	depressurize, none of this other water helps you.
L3	MEMBER KRESS: That's right.
L4	MR. RAO: Yes, you have to depressurize
L5	for this other water. It does
L6	MEMBER LEITCH: The only method of
L7	depressurizing is through the safety release valves
L8	then?
L9	MR. RAO: Normally because
20	depressurization is a very important factor in this
21	design, we went through a diverse depressurization
22	system. This is the standard ADS system for the SREs,
23	and we added another system on the depressurization
24	valves, and so there are different kinds of valves,
25	and they are very different than the standard ADS

	172
1	valves.
2	MEMBER ROSEN: How big are they?
3	MR. RAO: The DPVs, I think it is about a
4	12 inch line.
5	MEMBER ROSEN: And they are squib
6	actuated? Have you ever tested one?
7	MR. RAO: We have tested a lot of them,
8	and I can show you an actual test of those.
9	MEMBER ROSEN: Wow.
10	MR. RAO: We have done a lot of testing.
11	MEMBER KRESS: Isn't that novel.
12	MEMBER SHACK: When you say you can make
13	a small break LOCA with either your control rod drive,
14	how big a LOCA are we talking about here?
15	MR. RAO: A 2-inch line.
16	MEMBER SHACK: A 2-inch line. The CRD
17	system is designed to handle a 2-inch line. We
18	increase the capacity over that for the operating
19	BWRs. We did a lot of things to improve the core
20	cooling, and that is shown up here.
21	But the biggest thing is we have got a
22	bigger vessel, and there is more water in the vessel,
23	and so you start off with more water, and so the loss
24	of coolant accident response is a lot better. You
J	

don't have to rely on other systems.

1	And we keep the core covered following a
2	loss of coolant accident. I already mentioned some of
3	these things out here. So basically we improved the
4	plant response by design features, and very simple
5	design features, and nothing really fancy, you know.
6	It is just like of level of safety, you
7	know, and you put it together right and you end up
8	with a design which is a lot simpler. The same thing
9	with the decay heat removal area. Like I mentioned,
10	we added the full pressure normal shutdown cooling
11	system regarding the isolation condensers.
12	The major new system is a passive
13	containment cooling system.
14	CHAIRMAN BONACA: Could I ask you to go
15	back to number nine. I have a question.
16	MR. RAO: Sure.
17	CHAIRMAN BONACA: You have that bottom
18	line there which says increase security. I mean, did
19	you mean security or safety?
20	MR. RAO: I really do mean security,
21	because everything is inside the containment which is
22	(inaudible), and anyone who wants to get in there is
23	not going to last too long.
24	It is all inside the containment. I mean,
25	that is really a neat feature of this thing.

1 MEMBER How thick are the RANSOM: 2 containment walls? 3 MR. RAO: Two meters, 1-1/2 to 2 meters 4 thick. 5 MEMBER RANSOM: And I don't know if you mentioned it, but you can show shore up the lower 6 7 containment and still keep the coolant covered. That is an interesting 8 MR. RAO: Yes. 9 feature and it does not show up out here, but the lower containment is about 700 cubic meters, and I 10 11 mentioned that these pools are a thousand cubic 12 meters. So it is a closed system now, and water 13 14 does not leave anywhere, and so we looked at all of 15 the different scenarios and combinations, failures, and all the rest of it. So what you do is you can 16 easily plug the lower driver. 17 Now, when you end up with a closed system, 18 19 everything is finely tuned, because you are dealing 20 with -- you know, you have to make sure that you have 21 got the right amount of volumes everywhere, and we looked at all the different combinations and different 22 23 failures. 24 So it is a finely tuned system in that 25 sense, and that is what it prepares for.

1	MEMBER KRESS: Does it
2	MR. RAO: Yes, it is not as expensive.
3	MEMBER LEITCH: Those larger reactor water
4	cleanup pumps, how are they sealed? We used to have
5	all kinds of trouble with backing on reactor water
6	cleanup pumps. Are they can pumps or
7	MR. RAO: Yes, I think they are the can
8	pumps. I don't know offhand, but I think they are the
9	can pumps.
LO	MEMBER LEITCH: And that could be a real
L1	maintenance problem.
L2	MR. RAO: This is what the system looks
L3	like. We got rid of a lot of the water systems in
L4	this plant, but we still have enough of the water
L5	systems that there is a number of non-safety water
L6	makeup systems, okay?
L7	So we have simplified them, and what is
L8	shown here is the reactor water cleanup system that
L9	fits in. This is the reactor vessel, and this is the
20	suppression pool, almost to scale.
21	This is the pool of water up on the top
22	where the heat exchanger is and the isolation
23	condenser, and the decay heat removal sit. This is
24	the containment boundary up here.
25	And you can see the core compared to the

1 suppression pool, and water can flow regularly down in 2 there. The only water systems (inaudible) is we have 3 reduced them substantially, because the reactor water 4 cleanup nozzles is in this part of the building, and 5 you have got the hydraulic control units there. 6 And you have the field pool and an 7 auxiliary cooling system which is out here. 8 cool all the pools and also clean up all the pools 9 that are existing in the plant. And the rest of it is all gone. We have six floors of ECCS system in all of 10 11 that. 12 MEMBER KRESS: These heat exchangers that are in the pools, are they completely separate in the 13 14 sense that each of them has its own line coming? 15 There is not a header? MR. RAO: Each has its own line, and each 16 17 has its own separate compartment. The pools are not 18 connected. 19 MEMBER KRESS: The pools not are 20 Of course. connected. 21 Are there any problems MEMBER RANSOM: 22 with isolation with the reactor water cleanup system 23 and the feedwater systems? How are those isolated? 24 MR. RAO: They are just like standard

One of the things that we have done now as

plants.

1	far as the reactor water cleanup system is concerned,
2	we put it in this part of the building, which is
3	actually structurally better than the standard reactor
4	building, because structurally this lower part out
5	here is going to be part of that structure, and it
6	part of the containment boundary. So in a sense it is
7	a pressure bearing.
8	MEMBER RANSOM: I am wondering if those
9	are squib closed valves, or redundant values, or
10	MR. RAO: They are redundant valves, but
11	not squib valves for the reactor water valves.
12	MEMBER SHACK: Since I don't have pumps
13	any more how do I heat up the vessel before I start to
14	go critical?
15	MR. RAO: You just pull the rods and you
16	get heat i[after ==
17	MEMBER SHACK: Did you get the staff to
18	agree to that?
19	MR. RAO: After the first one, and we also
20	have we have both.
21	MEMBER ROSEN: What do you mean after the
22	first one? You mean after you got some decay heat on
23	the coil?
24	MR. RAO: Yes.
25	MEMBER ROSEN: After the first neutron you

1	mean?
2	MR. RAO: After that, you can just do
3	(inaudible).
4	MEMBER SIEBER: Now, it seems to me that
5	since you don't have any pumps for ECCS that the
6	importance of accuracy in TRACG is pretty high,
7	because everything is driven by a thermal head, and so
8	the demand on the code would be more than it would be
9	for a pump system. Is that correct?
LO	MR. RAO: No, the answer to that is please
L1	wait and I will answer that question. But the answer
L2	to that question is most of this stuff can be done on
L3	the back of an envelope. So hear me out and
L4	MEMBER WALLIS: Which is why you want to
L5	approve a very complicated code, right?
L6	MEMBER SIEBER: Yes, I have some envelopes
L7	here.
L8	MR. RAO: You have to keep the thermal-
L9	hydraulics guys.
20	MEMBER KRESS: That is the reason for
21	keeping us though.
22	MR. RAO: The evolution of the containment
23	in the reactor building is shown out here, and you can
24	see that all the BWRs have suppression pools, and all

of them were on the base mats, BWRs raised off the

1	base mats.
2	This hash mark is the bar code for the
3	Mark I and Mark II, and the spent fuel pool. You can
4	see on the Mark III that we moved it down to grade
5	elevation. One of the advantages of having delayed
6	this program post-911 was the high spent fuel was an
7	issue that came up I believe in Connecticut and other
8	places. So one of the advantages
9	MEMBER ROSEN: To put it down lower.
LO	MR. RAO: Down lower, and in fact it was
L1	actually a trade-off, in terms of costs and we don't
L2	think that high pools are a problem, but in terms of
L3	costs, ending up in those separate fuel buildings like
L4	Mark III, it was sort of the thing to do.
L5	MEMBER KRESS: Is it below grade?
L6	MR. RAO: You will see some actual
L7	sketches of grade. It is two-thirds below grade.
L8	MEMBER KRESS: Two-thirds?
L9	MEMBER ROSEN: You mean the whole plant is
20	two-thirds below grade or just the pool?
21	MR. RAO: The elevation of the spent fuel
22	pool.
23	MEMBER WALLIS: But it could be lower.
24	MR. RAO: It could be lower, but it is
	1

just that this is the optimum design. I mean, you

1	have got to remember that you have got two meter thick
2	walls. I mean, there is nothing that can really do
3	any damage to any of these plants, and all the studies
4	have shown that. That is not a real issue. It is
5	just more feels good.
6	MEMBER LEITCH: So there is really no
7	what we might have called reactor building in previous
8	BWRs. In other words, everything is inside
9	containment here.
10	MR. RAO: Well, no, if you want to use the
11	terminology reactor building and reactor water cleanup
12	system, this part out here is the reactor building.
13	MEMBER LEITCH: But it is in containment
14	though, right?
15	MEMBER WALLIS: No, it is not a
16	containment.
17	MEMBER LEITCH: It's not in containment.
18	MR. RAO: The different boundaries go up
19	like this.
20	MEMBER LEITCH: Okay.
21	MR. RAO: So that is the outside
22	containment there, and hydraulic control units and the
23	reactor water cleanup system outside.
24	MEMBER KRESS: That's so you don't have to
25	work that region?

1 MR. RAO: Pardon? 2 MEMBER KRESS: Is that so that you don't 3 have to inert that region? 4 MR. RAO: Well, we kept it outside -- yes, 5 that region is not inerted. You do maintenance on the hydraulic control units and reactor water cleanup and 6 7 that;s it. A couple of other things is that we have 8 added an entire fuel transfer system, which should 9 make the utilities life a lot easier, because you can 10 11 move fuel up and down with a spent fuel pool, and 12 during operation it takes it off the critical path. The reason that you can do that in this 13 14 plant compared to the Mark III is the top of this 15 thing is outside the containment now. In the Mark IIIs that is part of the containment. So you have got 16 17 to move during an outage. In this one, you can move it and what we 18 19 have done is we have reduced the safe buildings. 20 can see that we got rid of 6 floors of safety grade 21 ECCS, and heat exchangers, and heat controls, and all 22 of that. 23 We have on this plant shown something on 24 the outside called an external event shield. We have

not defined what requirements are there. We can make

1 it probably a revolving requirement on what 2 required for us to do in that area. 3 So the design is flexible in that sense. 4 This is actually to scale and Graham has left, and he 5 claimed that the drawings are not according to scale, but this is an actual section of the plant. 6 7 And you can see that it is actually a 8 fairly simple plant. The reactor vessel, and fuel 9 pipes, and reactor water cleanup system, and hydraulic control units, and pools of water. 10 MEMBER ROSEN: And grade is again -- show 11 12 me. Grade is right here. 13 MR. RAO: MEMBER ROSEN: Right there? Okay. 14 15 MR. RAO: This is the spent fuel pool, and this is the inclined fuel transfer system, and this is 16 the fueling machine, and this is the fuel cooling 17 So that is all of the systems, and the 18 system. 19 accumulators for the standby liquid control are 20 somewhere out there, and you can see them in a 21 different section. 22 MEMBER ROSEN: And this external event 23 shield that you talked about, is it talking about how 24 big or how thick the walls are on the rectangular

cross-section part of the vessel or part of the

1	plant?
2	MR. RAO: This one, we have not defined
3	the thickness, no.
4	MEMBER ROSEN: Of the external event
5	shield. Oh, it is that piece?
6	MR. RAO: It goes over
7	MEMBER ROSEN: But it doesn't go over the
8	other piece?
9	MR. RAO: No, it doesn't go over this
10	piece.
11	MEMBER ROSEN: Because all the fuel is way
12	down low?
13	MR. RAO: Yes, the fuel is way down low.
14	CHAIRMAN BONACA: One thing that I noticed
15	in this design is that you have a lot of bundles, a
16	thousand bundles. How long will it take you before
17	you have to begin to off-load spent fuel from that
18	pool?
19	It seems to me like you have almost a
20	permanent operation to dry storage.
21	MR. RAO: The size of the spent fuel pool
22	right now is good for 8 years. One of the advantages
23	of having a separate fuel building is you can increase
24	the size and make it part of the initial investment
25	cost.

1	Standard fuel, you can move about 5 or 6
2	years, and if you go to MOX fuel, it is a little
3	longer. Ten years is what the Europeans require. So
4	if this were built in Europe, and they had MOX fuel,
5	they could end up with a slightly bigger fuel
6	building, but it would not affect the rest of the
7	design of the rest of the plant. So it is kind of
8	flexible in that sense.
9	MEMBER ROSEN: And Graham, you are going
10	to tell them that it is to scale?
11	MEMBER KRESS: You might let him know.
12	MR. RAO: To scale.
13	MEMBER WALLIS: Do I get to applaud?
14	MEMBER SIEBER: Let me ask a question that
15	will demonstrate my failure to fully understand. When
16	you have an accident or a transient in the plant,
17	ultimately the decay heat from the reactor is up in
18	the PCC pool, right, through the heat exchangers that
19	ar up there?
20	MR. RAO: That's right.
21	MEMBER SIEBER: How do you remove the heat
22	load from the PCC pool outside the building?
23	MR. RAO: Okay. If you get a normal
24	vector isolation, you can remove it with the active
25	fuel pool cooling system.

1	MEMBER SIEBER: Okay.
2	MR. RAO: You can do that. That is an
3	active, non-safety fuel pool cooling system. So the
4	pool doesn't really have to boil. It takes about 3
5	hours or 4 hours before
6	MEMBER SIEBER: And if that fails, then
7	you are relying on the boil over?
8	MR. RAO: Then it just boils off.
9	MEMBER SIEBER: It boils off. Okay. And
10	how long does that last?
11	MR. RAO: For 72 hours.
12	MEMBER SIEBER: So you have got to put
13	more water in there.
14	MR. RAO: All you have to do is provide
15	MEMBER SIEBER: Call the fire truck,
16	right.
17	MR. RAO: 200 or 300 gallons per
18	minute, and that's all you have to provide. It is not
19	big, and it is low pressure, and it is outside
20	containment, and we have got a connection to that, and
21	that's all you do.
22	MEMBER SIEBER: Okay. Thank you.
23	MR. RAO: This is the spent fuel refueling
24	floor, and it controls the building size, and you can
25	see that this is a pool for storage of either spent or

1 new fuel, and there is not enough time to cover all of 2 these issues. This is the reason that we are here. 3 TRACG. 4 Now that was just an overview of the 5 design. I am notorious for exceeding my time, and I will keep watching my watch out here. 6 7 MEMBER WALLIS: Well, it is a matter of doing it full-scale and not distorting it are you? 8 You distort the dimensions of time as well. 9 MR. RAO: What we have done in this plant, 10 11 and what this shows is these are the codes that we 12 used for the operating BWRs, and for doing the different analyses. 13 14 For the ESBWR, we are using some of the 15 same, but we are switching using TRACG for most of the application. This is a proven code, and for those of 16 17 you who have worked with codes know that it takes 15 or 20 years before people start feeling comfortable 18 19 with some of these codes, you know, and to take all 20 the bugs out. 21 So this one has been around for 25 years. 22 I remember going to Los Alamos for the first time 23 almost 20 years ago, or 17 years ago, and talked to 24 the people there who are using such codes.

MEMBER WALLIS:

25

the

That is one of

1 problems with these codes, of course. They all have 2 the same roots. They all came from Los Alamos? 3 MR. RAO: 4 MEMBER WALLIS: That's part of 5 problem, yes. MR. RAO: But we are taking the bugs out. 6 7 That is why G is our last initial up here. The overall technology program is shown up here. It is a 8 9 very comprehensive program. What we did was that we started with a program, and we looked at the PIRTS and 10 11 looked at what the important phenomena were, and 12 developed what the board called the test and analysis 13 plan. 14 Then we ran some tests were used to 15 qualify the computer code. We did model bias and uncertainties, and we did a scaling report, and to 16 17 make sure to test for scale drive, and on the side out here we first developed the TRACG code, and learned 18 all the creations and made sure that it could do the 19 20 analysis for both the reactor vessel and the 21 containment, and that was in your application. 22 And after that, you get a validated code, 23 and then you define an application methodology for 24 using that code, and the code can't be used just

generally.

1	I mean, you can use it, but it has to make
2	sense. So we have defined an application methodology.
3	Now that is what we are asking the staff for an SER
4	on, on the approval of the code, along with the
5	application methodology of that code.
6	Then we will do the safety analysis report
7	up here. So these are all the different elements of
8	the technology program, and I will give you a feel for
9	some of these so that you get a feel for how complex
10	and comprehensive this has been. There is not enough
11	time to go into detail, but
12	MEMBER WALLIS: So part of this
13	application is this model bias and uncertainty part,
14	where you show how you take care of that?
15	MR. RAO: Right.
16	MEMBER KRESS: Didn't we hear that tone
17	before?
18	MEMBER WALLIS: In association with
19	something like the AOO transients or something for
20	different reactors?
21	MEMBER KRESS: Yes, for the AOO transients
22	we heard about.
23	MR. RAO: Yes, that is for the AOO
24	transients, but we went beyond that. Now, this is a
25	LOCA applications and for the containment analysis

1	also.
2	MEMBER RANSOM: It is interesting that you
3	mentioned bugs, and one bug that we found in TRACB and
4	TRACG came from TRACB, was when they attached a line
5	to the vessel at somewhere other than the center of
6	the node, they had not accounted for the hydrostatic
7	pressure difference between the center of that node
8	and the line attachment.
9	And I am wondering was that corrected in
10	TRACG?
11	MR. RAO: I am not knowledgeable enough to
12	answer that.
13	MEMBER RANSOM: Is Bharat here?
14	MR. RAO: Bharat had to take an earlier
15	fight and he is gone for the day.
16	MEMBER RANSOM: I am wondering if well,
17	you didn't bring Bharat?
18	MR. RAO: We did bring him, but he was on
19	an earlier flight. The meeting was in the morning,
20	and he had planned to be at the morning meeting. In
21	fact, one of the reasons that I am looking at my watch
22	is not only that I have to not exceed my time, but I
23	have a flight to catch. I will finish on time.
24	MEMBER KRESS: Could you tell us just a
25	little more about the application methodology.

1	MR. LANDRY: From what we have seen, yes,
2	our understanding that has been corrected. But we
3	will look just to be further just to be sure. Our
4	understanding of it right now is that it has been
5	corrected.
6	MEMBER KRESS: Just a few words by what
7	you mean by the application method on it.
8	MR. RAO: Okay. I have a few more charts
9	to describe, but basically you take a computer code,
10	and how do you account for the uncertainties.
11	MEMBER KRESS: Oh, that sort of thing?
12	MR. RAO: Yes, that sort of thing. This
13	is a realistic code. How do you account for the plant
14	parameters, for example.
15	CHAIRMAN BONACA: And the nodalization and
16	sensitivities, and all of that.
17	MR. RAO: The nodalization, yes, and what
18	we did and so what I am going to do is just go over
19	some of these boxes, and give you a feel for what we
20	have done. It will just give you a feel.
21	If you want me to cover all of these
22	charts in detail, they are in your handouts. First,
23	we developed an overall test and analysis plan, which
24	consisted of going over the governing phenomena, and
25	doing PIRT, to bottom-up, and top-down processes. We

1	looked at the highly ranked phenomena, and
2	MEMBER KRESS: Where did you get your
3	experts for the PIRT?
4	MR. RAO: The PIRT experts came from BWR
5	experts who have been working with us over the years
6	on
7	MEMBER KRESS: They are GE employees?
8	MR. RAO: It was GE employees, but we had
9	other people also.
10	MEMBER WALLIS: You even had a professor.
11	MR. RAO: We even had a professor.
12	MEMBER ROSEN: Which just shows that they
13	are not excluded.
14	MR. RAO: He used to teach at Berkeley.
15	MEMBER KRESS: That makes it a academic
16	exercise, I guess.
17	MR. RAO: So we followed a rigorous
18	process to define the technology plan. It is very
19	extensive, and I have taken out all the tables that we
20	had prepared for that.
21	That was initially done for the ESBWR, and
22	then when we came to applying it to the ESBWR, we said
23	let's look at the differences between the ESBWR and
24	SBWR. This is a summary of the differences between
25	the ESBWR and SBWR.

1 We basically increased the power, which has affected several things, and we did change the 2 3 plant systems and the buildings. Like I mentioned, we 4 increased the number of steam lines from 2 to 4, and we increased the number of bundles. 5 We changed the height also. The SBWR was 6 7 2.7 meters, and we have gone to 3 meters on this one. We have added more isolation condensers. As you were 8 told before, we did not just go up in power. We added 9 10 more decay heat removal systems to the plant, and it 11 was not just a power uprate. 12 We increased the -- the fashionable thing is to get another 5 or 10 percent, or 20 percent more, 13 14 out of the same system. We added capacity. We 15 increased the isolation condenser capacity by 50 16 percent. 17 increased the decay heat removal capacity by 80 percent. We basically now have four 18 19 units, and we previously had three units, and we increased the size of the units. 20 So one of the good things about this 21 22 design is it is fairly easy for us to add more decay 23 heat removal capacity, because we are not removing it 24 from the containment boundary, or from the vessel

boundary like some of the liquid metal or

1	reactors. We are removing it through heat exchanges.
2	And those heat exchangers are they are
3	not cheap, but we increased the size of the units.
4	MEMBER KRESS: Let me ask you a question.
5	In your test and analysis program that you did for
6	SBWRs to qualify the TRACG, you developed a scaling
7	process using PI groups.
8	Was your PI group acceptance criteria the
9	same for SPWR as it is for the ESPWR?
LO	MR. RAO: We have the scaling expert here.
L1	MR. GAMBLE: Hi, Bob Gamble from GE.
L2	There was actually a very subjective criteria used on
L3	the SPWR. There was no quantified value.
L4	MEMBER KRESS: You didn't use from 5 to 2?
L5	MR. GAMBLE: No, that kind of developed I
L6	think through the AP-600 program. Prior to that, no
L7	one had really come up with the idea of a quantified
L8	criteria.
L9	So seeing that, we adopted it, and ours is
20	slightly different than theirs. So now we have
21	MEMBER KRESS: Now you have on-third to
22	three.
23	MR. GAMBLE: Correct.
24	MEMBER KRESS: But my question is whether
25	that is different than what you used for SPWR?

1 MR. GAMBLE: In SPWR, we just looked at 2 the PI groups and subjectively argued whether they There was no criteria. 3 were close enough or not. MEMBER KRESS: So you had no criteria? 4 5 MR. GAMBLE: Correct. MR. RAO: What we did on the plant systems 6 7 and buildings was we did increase the system sizes and capacities, but we did not increase the numbers. For 8 9 example, the reactor water cleanup system was a two-10 train system, and it is still a two-train system, and 11 the fuel cooling system was a two-train system. It is 12 still the same, except that it is bigger pumps, and bigger pipes. 13 14 We did utilize a little innovation, and 15 again not hi-tech stuff, but innovation. We used the pools when they empty out, it opens up air space, and 16 17 that can help us reduce the containment pressure following an accident. 18 19 So we basically are taking credit for 20 that, which gave us an additional 15 percent increase 21 in retro volume, which then translates into 15 percent 22 lower containment pressure following an accident, 23 which then allows us to reduce our design pressure by 24 about 15 percent, and make it the same as the ABWR

now.

1 So we are now in the same range, and there 2 is a whole trust out here to make us the same as ABWR, 3 because we use everything the same. And that was one 4 of the advantages of what we did out here. 5 We did do a major building optimization, including transferring non-safety systems out of the 6 7 safety grade buildings. So that is one of the reasons that we reduced the size of the safety grade building, 8 and we also ended up in a different building for the 9 10 spent fuel storage. 11 But the bottom line of all of this is that 12 the differences do not affect the governing phenomena for normal operation transients and accidents. It is 13 14 pretty much the same as the SBWR when you look at it 15 from a hydraulics point of view. So that program that I mentioned earlier 16 17 which defined what was needed to qualify the code for all the different phenomena, resulted in a test 18 19 This shows you the results of the test 20 program, and there is not enough time to cover all of 21 them. 22 You can see that they were best done at 23 different scales and at different facilities, and by

different organizations, and a very extensive test

program all over the world.

24

1	MEMBER WALLIS: Well, a thousand scale
2	doesn't mean that it is something like using a little
3	matchbox car model and a model Cadillac. It means
4	that it was pretty well full height isn't it?
5	MR. RAO: Exactly. When you see the last
6	one, the PAMDA is the biggest test facility that we
7	have got. It is a full high test facility, and it is
8	1/50th
9	MEMBER WALLIS: It is a thousandth in
10	cross-sectional well, what is the one-thousandth
11	part? Is it the thousandth in cross-sectional area?
12	Because the thousandth in linear dimension is sort of
13	absurd.
14	MR. RAO: That is the full height, and
15	power also. It is power and you can look at it at
16	one-thousandth power. This facility is a huge
17	facility. I think it is the biggest test facility for
18	testing safety systems, and it is full height, which
19	is about 27 meters I think from top to bottom.
20	CHAIRMAN BONACA: Is it a GE facility?
21	MR. RAO: No, it is owned by Paul Sheridan
22	Steel in Switzerland.
23	CHAIRMAN BONACA: Oh, I see.
24	MR. RAO: This is the depressurization
25	valve.

1	MEMBER WALLIS: Which one is it, that big
2	one?
3	MR. RAO: This one.
4	MEMBER SHACK: Oh, this is the promise
5	that you made before.
6	MR. RAO: This is the squib valve. This
7	is the actual valve, and in a sense it is a rupture
8	disk. Well, rupture disk gives the wrong impression.
9	It is sheared off.
10	MEMBER ROSEN: Do you in some place use
11	the reliability of that in the PRA?
12	MR. RAO: Of course. We have done a test
13	program.
14	MEMBER ROSEN: And have you got the data
15	for how reliable this valve is from that?
16	MR. RAO: Yes.
17	MEMBER LEITCH: How many did you do, one
18	tests, two tests, 10 tests, a thousand tests?
19	MR. RAO: Ten.
20	MEMBER LEITCH: And they all passed, I
21	assume? Then you extrapolated from that.
22	MR. RAO: Yes, there is a whole test
23	report on that, a 500 page report that has been done,
24	and we can share that with you. I know that you asked
25	the other guys the same questions.

1	MEMBER LEITCH: It seems like a pretty
2	good question to me. If you are going to build a big
3	break LOCA into your system, you ought to make sure
4	that when you want it, you get it; and when you don't,
5	you don't.
6	MEMBER LEITCH: And how many of those are
7	there?
8	MR. RAO: Six.
9	MEMBER LEITCH: Six conventional relief
10	valves?
11	MR. RAO: Well, 12. So this is the full
12	scale DPV, and that was done somewhere in Southern
13	California, I believe. This is the facility in
14	California which was tested and it shows that water
15	flows down in California by gravity also.
16	This was the vacuum breaker full-scale
17	test, and this is the test facility in Switzerland for
18	the integral testing of the DPV systems. This is a
19	full-scale decay heat removal condenser.
20	MEMBER ROSEN: When you did the reactor to
21	the depressurization test, you gave out ear plugs to
22	everyone?
23	MR. RAO: Yes, I think it was out there
24	somewhere.
25	MEMBER WALLIS: Now, Atam, this is nice to

1 know that these exist. Now the real question is 2 whether or not this program is adequate enough to support the future licensing of the plant like this, 3 4 and the only way we can determine that is to go into 5 details, which you are not going to present today. MR. RAO: 6 Right. 7 MEMBER WALLIS: So this is very much an overview. 8 9 MR. RAO: It is an overview. The details, like you said, the reports are, oh, 5,000 pages. 10 11 MEMBER WALLIS: But the justification of 12 why this is adequate would take us some time to evaluate, I think. 13 MR. RAO: That is definitely the case, and 14 15 that is why the staff is reading them and they are doing a yeoman's job of going through them. I mean, 16 the number of pages of the reports, it is extensive. 17 I am just trying to give you an overview. 18 19 But it is a lot of pages. These days it now fits on 20 CDs, and so it a lot of CDs. 21 MEMBER WALLIS: But is there some sort of 22 executive summary that says why these number of tests is adequate, and these facilities are adequate? 23 24 there some sort of concise argument that would satisfy 25 us, or do we have to read through all these reports?

1 MR. RAO: You will probably have to read 2 the TAPD, which is the --3 MEMBER WALLIS: Which is the central thing 4 to go to? 5 MR. RAO: Yes. That is the one that gives the overall plant and lays out the road map. That is 6 7 a fairly comprehensive document. It is not that long, 8 300 or 400 pages. There were additional tests done that we 9 10 have qualified the TRACG computer code against, and in 11 fact some were performed after the SPWR program was 12 terminated, and we recall the PAMDA P-Series test, and there was some done also in Japan at a test facility 13 14 run by CRIEPI. 15 But this is an Ontario MEMBER WALLIS: hydro test isn't it, which is rather important for the 16 17 chimney? Or is that the CRIEPI? MR. RAO: Well, we list all of them there. 18 19 MEMBER WALLIS: Okay. You did not list 20 them on that previous slide. 21 MR. RAO: So this shows some of the tests 22 that were done showing the same test program. The 23 listed all the tests, previous chart and the 24 qualification report is about a thousand pages. It is 25 two volumes.

1 So it is a huge report. And it covers a 2 lot of tests. You can see the circulation of the vessel, and we looked at separate performers, and 3 4 chimney wide fraction, and this was the testing done 5 in Canada. And the start-up flow oscillation, and 6 7 mixing, and it is an extensive test program, and we went about it systematically trying to fill in the 8 holes that we had found. 9 I can tell you the history about the 10 11 chimney design also. Initially, we started off with 12 an open chimney, and no partitions, and all that we had at that time was some published Russian data. 13 14 We had to read it off a little report 15 paper, and we said, gee, that is not enough, and so that is when we went with partitions, and that's when 16 17 we initiated the testing in those many items. 18 went about it systematically. 19 Whether it was natural circulation, or the containment 20 and safety system technology, you can see that we did 21 a lot of testing. Individual fuel condensation, and 22 look at all the test facilities that were involved. 23 Some were at MIT, U.C. at Berkeley, and 24 GIRAFFE was in Japan, and PANTHER was in Italy; and

We

Switzerland.

PAMDA

in

was

25

the

looked at

1 performance of the heat exchangers, and looked at 2 system interaction, and we looked at suppression pool 3 stratification, and stratification of the drywell and 4 looked at quenching. 5 We supplemented these. No, there were tests that were done in other organizations which 6 7 extended the database that was done for the SPWR, 8 which covered even more severe conditions than had 9 been tested before. 10 MEMBER WALLIS: So you had systems that actually simulated entire transients? 11 12 MR. RAO: We covered -- there was no one test that covered it all from zero to the end, but we 13 14 had a level that has given us confidence, and we 15 covered all the bases. Atam, did you find that 16 MEMBER RANSOM: 17 the chimneys were really necessary, the partitions in the chimney to overcome geysering or slugging in the 18 19 open arrangement? 20 MR. RAO: No, we didn't add the chimneys 21 for the geysering concerns. We added them just 22 because of the uncertainties associated with an open chimney during --23 24 MEMBER RANSOM: So you don't really know 25 whether you need them or not then?

MR. RAO: Right. In fact, there was a
long debate when we were deciding to put in the
partitions, and we said that we would put them in and
be conservative with that, and if you don't need them
after some time, then we can take them out.
MEMBER WALLIS: I would think that you
would need them.
MR. RAO: We put them in because that area
is
MEMBER RANSOM: Well, you mentioned the
Russian data. What did that concern? I mean, did it
concern the need for them, or
MR. RAO: No, no, that was just a void
fraction in general. It was very small. It was much
smaller than the interior hydro channels.
MEMBER WALLIS: Now, were these short big
vessels where the steam tends to go up one side and
get a non-uniform flow?
MR. RAO: Well, we put the channels in
there.
MEMBER WALLIS: We don't need to discuss
it.
MR. RAO: Then what we did was we ran
these tests, and then we compared the TRACG computer
code, and this shows the next couple of plots. It is

1 hard to read all of this, but I just wanted to give 2 you a feel for it. What we did was that we compared the TRACG 3 4 against several test data and this was a component 5 data, and Patsy did a dam good job. You can see how 6 different tests out here, and this high 7 condensables, and this is only with steam. Again, not enough time to go into all of 8 9 these, but what you can see is that TRAC does a dam 10 good job. It helped us define the bias of the 11 uncertainties and the predictions using TRAC as a 12 realistic code. There is no tuning of 13 MEMBER WALLIS: 14 TRAC? 15 MR. RAO: No tuning of TRAC. These were TRACG predictions of integral tests, and a prediction 16 17 of the drywell and the wetwell pressure, and the dashed line is TRACG. It is hard to see that in the 18 19 actual pictures. 20 It does a dam good job of that. Another 21 figure of merit is this calculation of the amount of 22 energy removed in this integral test, and that is 23 measured by the pool level in the PCCs, and you can 24 see that it does a dam good job of that.

It misses a few details shown out here.

1	This is the flow into each of the three PCCs. In this
2	particular test facility, there were three PCCs, and
3	two of them removed more energy than the other one,
4	and one actually sort of went to sleep is what we call
5	it.
6	But the integral performance is pretty
7	good. So in summary we had a comprehensive, well
8	efficient program, and like you said, it is a thousand
9	page report, and what we call the base qualification
10	of the capacity systems.
11	We did another qualification report, which
12	is about another 400 or 500 page report. So this is
13	about 1,500 or 2,000 pages worth of qualification that
14	the staff is reading.
15	They are fast readers and they are on a
16	tight schedule, and they have done a great job on
17	that.
18	MEMBER WALLIS: But you have not replied
19	to the RAIs?
20	MR. RAO: We are doing it. We are working
21	together.
22	MEMBER WALLIS: Since you are saying all
23	the good things that you have done, I had to remind
24	you of that.
25	MR. RAO: No, we will reply to the RAIs.

We provided draft responses to some of those questions, and we provided draft responses to about a hundred I think out of those 300, and so it is now just a question of formalizing the responses. So it is doing well, believe me. Trust me.

MEMBER WALLIS: Fatal words.

MR. RAO: We want the staff SER on October 15th, and so we will do whatever it takes to make that happen. We want closure, okay? This shows the effective scale of different test facilities, and again it is hard to see. These are different test facilities, and they are at very, very different scales.

They are 1-by-1,000, and 1-by-50, and some with helium and some without helium. This was -- you can't see any of the details out here, but what you can see is that they all follow along this line out here, which shows that they are pretty close to what we expected them to show. This was the components for the --

MEMBER WALLIS: Now, what we said at the subcommittee was that it would really be nice since TRACG is what is in question here, if you had TRACG predictions with all of these results, and that comparison is going to be very well made in your

1 application, right? 2 We are focusing right now on MR. RAO: 3 answering the RAIs, and after that we will put that on 4 the things to do. So these are tests at different 5 scales. You know, very different scales. These components, you know, these were the 6 7 heat exchangers, and some of these were full-scale, 8 and some of them were a slice, some of them were just 9 three cubes. So you can see that the performance 10 is --MEMBER WALLIS: Scaling works is what you 11 12 are saying. MR. RAO: Yes, scaling does work. 13 14 summary, for the technology program, what you see is 15 that we have improved the performance by design 16 features, and we have used qualified methods basically. 17 What we are doing -- and this is where I 18 describe what we are doing in the application 19 methodology. It is basically used for calculations and 20 21 this is something that we have already reviewed. 22 are using realistic calculations and with simplified accounting of uncertainties. 23 24 Until 2 days ago, we were using bounding

-- no conservative calculations for the containment

1 and the LOCA. So what we have done is that we are 2 accounting for the uncertainties. 3 And we can use a simplified accounting of 4 the uncertainties of this design, because we have got 5 lots of margin. Remember that the core, the minimum water level is about 9 feet above the top of the 6 7 active fuel. The core is not even uncovered in a loss of coolant accident. There is a lot of margin in this 8 9 plant. And that is what I was talking about. Why 10 11 does the core remain covered? As is shown on this 12 chart, this is the ESBWR vessel and this is ABWR vessel, and in the core, you can see that it is lower 13 14 in the vessel of this plant. 15 And when you have a bigger vessel, you 16 have got actually more water. What you want to do is have a lot of water above the top of the active fuel. 17 So one of the reasons that you have got water by the 18 19 top is that it is going to be less. MEMBER LEITCH: One of the features of the 20 21 present design, the present fleet with the jet pumps is that you have two-thirds core coverage even with a 22 23 LOCA. 24 Now in this situation, you don't really 25 have any ensuring of core coverage with a LOCA, just

1 depending on the fact that you have few and smaller 2 lines below the core? 3 MR. RAO: No, this one is a lot better 4 than any other plant, period, because you can fill up 5 -- let me go back to a question from before. that one is a new one. This is as good as any, and it 6 7 shows the answer. What happens is that you can fill up the 8 lower drywell in the vessel to the top of the active 9 fuel, about two-thirds correct, to the top of the 10 11 active fuel. It is a closed system, and so you will 12 always keep that core covered. It doesn't take any fancy calculation. 13 14 You just take all the breaks and the water flows from 15 there, and what has happened in this plant is this lower drywell volume is only 700 cubic meters, okay? 16 17 The lower drywell volume in all these plants is huge. You can't flood the outside, okay? 18 19 So you can talk about filling it up to two-thirds of 20 core height, but the outside is empty. 21 On this one, not only is the inside full, 22 but the outside is all full of water. So you are 23 assured of core coverage on this one. 24 MEMBER WALLIS: As long as you remove the 25 heat?

1	MR. RAO: Yes, decay heat removal goes out
2	through those passive heat exchangers. I mean, there
3	is no moving parts there. I know that I am not giving
4	you a convincing answer.
5	MEMBER LEITCH: I have to think about it
6	for a little bit. Go ahead.
7	MR. RAO: You know, if you just look at
8	this, this is drawn to scale. This is only 700 cubic
9	meters down here to the top of that. And that is a
10	thousand cubic meters over there and that pool is not
11	showing up there.
12	MEMBER LEITCH: Yes, but you are relying
13	on a safety system to fill it up?
14	MR. RAO: Well, that is how you keep two-
15	thirds core in the operating plants, too. You have a
16	safety system. The safety system is the gravity
17	driven pool. That's all it is. It is not anything
18	more complex than that.
19	So what you see in this plant is the water
20	volume that is a true measure of how well this plant
21	behaves, you have got about 2=to-2-1/2 times as much
22	water as any of the operating plants.
23	MEMBER LEITCH: In the vessel.
24	MR. RAO: In the vessel, yes. And the
25	other thing is that not only do you have more water.

1 but you have got a larger steam volume. Remember that 2 I mentioned this, that you have and 80 percent void in 3 the chimney. 4 So when you get a reactor isolation, the 5 transient response is a lot better. You have got twice as much steam volume, and so you have got about 6 7 half the pressure rate in the standard operating 8 plant. 9 This shows what happens to the water. 10 Initially, the water -- this is from a 11 nodalization, and initially the water is on the 12 outside of the stand pipes, and the downcomer, and in the core region. 13 14 The chimney is voided, and when you get to 15 reactor isolation, this water basically comes down and fills out the downcomer, and fills up the chimney 16 region. And that fills up the water level to about 8 17 18 meters. 19 So that's how much water there is in the There is a lot of water. 20 This shows the vessel. 21 plant response, comparing different plants. You can 22 see that the ESPWR has a lot more margin than past 23 plants. 24 This is the water level above the top of

the active fuel following a pipe break. The jet pump

plants, I was more generous to them, and showed them recovering from the top of the active fuel, rather than two-third core height.

And the ABWR doesn't uncover, because it does not have any large pipes, and recovers because you inject water. And these have to be done in the 100 or 120, or 200 seconds. Very fast. Some of the earlier plants were a lot faster than that.

In this plant, the water level initiative drops because the water comes from outside the shroud and into the core region, and so that is why you see a drop in the water level.

Then you get flashing and depressurization, and then the water level slowly -- it takes about 600 seconds before you get to the minimum water level, and that is when the water starts flowing in by gravity. The pressure is lower enough in the vessel and it starts running water makeup, and it does not recover as fast. These ones come back really fast.

This one, because the gravity flow is not as fast, it doesn't need to come up any faster, but the core is still covered. So what it shows is that this plant is a lot more forgiving, and the other thing to notice is that when we went out from SBWR to

ESPWR, we actually improved the response.

So it is not just a power uprate where you lead into the margins. We have actually retained them the margins that we had, and maybe got a little better.

So this is a picture of some of the hundreds of pages that I keep mentioning that we submitted to the staff to basically give us approval that we know how we calculate the plant response out here. It is reasonable, and some of this stuff can be done in the back of an automobile.

But this does give us confidence that what we are getting out the code is good. Where we are on the overall status, and I am down to my last two charts, is we had made extensive submittals to the NRC in 2002, and we had several meetings and conference calls interactions, and in fact we met yesterday and we met this morning.

The NRC staff has done an extensive and thorough review of about 300 plus RAIs, and a few more that are coming fairly shortly. According to the plan, final responses by GE are due by August 15th, and we will meet those dates.

The draft DSER is due mid-October, and I believe it will come back to the ACRS and the thermal

1	hydraulics committee before we get the final safety
2	evaluation report.
3	And we are trying to work out a schedule
4	for additional application submittals governing ATWS
5	stability, and the AOO is sort of in between this
6	submittal and additional RAIs.
7	MEMBER WALLIS: So the big date for you is
8	sometime in October is it? When is the big date for
9	you when we are going to see you again?
10	MEMBER WALLIS: Sometime after October
11	15th, after the draft SER. I think they are trying
12	for sometime in November.
13	MS. CUBBAGE: We are planning for the
14	subcommittee.
15	MEMBER WALLIS: So we have got plenty of
16	time to do our homework haven't we?
17	MR. RAO: It is good summer reading.
18	After that, we will do the preparation of the SAR, and
19	the certification, and we are expecting FDA approval
20	in 24 months after the submittal.
21	And Dana challenged me when I came to the
22	ACRS a few years ago, he says make your submittals and
23	see what the new NRC will do. And by the time that we
24	make the submittal they become 12 months.
25	The charges for the coming month is to

1 make sure that GE responses are timely and complete, and that we get -- they are looking for complete 2 3 technology closure with no open items. 4 We believe that we have done an extensive 5 program, and we have been responsive to the RAIs, and we believe it is a good complete program. 6 7 plus year technology and design program, and this is 8 a BWR with less components that you need to analyze. 9 is easy to understand the safety The analysis is simplified and basically 10 11 our goal is that this is a program that is made and 12 run by industry and it is not funded by the government or any other organizations. 13 14 is an industry-run program, and 15 minimizing the regulatory risks is one of the key factors in going forward with this. 16 And both the company is committed to this, and interested parties 17 are really interested in this design. So, thank you. 18 19 MEMBER LEITCH: You have not discussed any 20 ventilation systems here. Is that on GE's scope of 21 supply? No, we didn't discuss 22 MR. RAO: 23 ventilation system. I focused primarily on the stuff 24 that is related to the TRACG approval, and things that

were on the table. There is a whole lot of stuff that

1 we did not discuss, such as structures, and materials, 2 and others. 3 MEMBER LEITCH: But when you say there is 4 no diesel, some of those ventilation systems are 5 safety grade systems that need diesels? Remember that the ECCS 6 MR. RAO: No. 7 systems are all inside and they need no cooling. Nothing is needed for those. 8 9 MEMBER ROSEN: No stand-by gas treatments? 10 MR. RAO: No stand-by gas treatments, and 11 so none of those -- that is the advantage of greater 12 passive systems. You get rid of the whole HVAC, and you get rid of all the water systems. It really does 13 14 simplify the plant. 15 It is hard to imagine getting something simpler than this. When we did our cost estimate, you 16 17 will see -- well, we won't share that obviously, but if you order a plant, we could provide you one. 18 19 you can see, and I would like to say that we have 20 essentially got the safety systems for free, because 21 what it is, is a few tanks of water, and a few valves 22 connecting them to the vessel. 23 And when you look at the design of the 24 containment, and in fact we were actually planning to

reduce the design threshold to even lower than that

1	for the ABWR.
2	But our structure people told us that you
3	don't save anything by reducing the design pressure
4	any further. So we kept it the same as the ABWR,
5	because there are other considerations, like
6	shielding, and just holding up the equipment of the
7	building.
8	MEMBER ROSEN: It would be good to hold it
9	up.
10	MR. RAO: Yes, you have got to hold it up,
11	and so in a sense we have got the containment, and the
12	safety systems for free.
13	MEMBER RANSOM: What is the regulatory
14	risk that you refer to? I mean, just getting it
15	through the process?
16	MR. RAO: Getting it through the process.
17	You can see how long
18	MEMBER RANSOM: Is there any reason why
19	you think that would be unusual?
20	MR. RAO: Well, we got burned in the
21	earlier days on the SPWR, and I am not trying to find
22	fault with anyone. Like you said, there is enough
23	fault for us, and there is enough fault on the NRC
24	side, or even our sponsor's side, okay?
25	So there we did things in parallel. We

1	have adopted a step-wise approach, which has minimized
2	what we are doing out here. We don't go to the next
3	step until we have a draft SER, and that is what we
4	are trying to do.
5	We won't go to the SAR and certification
6	until we know that we have got testing and the core is
7	approved. We won't go to the COL stage until we have
8	got the draft SER, and the SAR, or the certifications.
9	So that is what we are talking about when we say we
10	want to make sure that we can get closure.
11	MEMBER ROSEN: What about the fuel? Is it
12	the same?
13	MR. RAO: It is the standard fuel. It
14	will be standard. It will keep changing, and the way
15	it works is that basically you use the latest fuel
16	design that is developed. And it has a much shorter
17	cycle life than the vessel in the plant.
18	CHAIRMAN BONACA: Shorter bound.
19	MR. RAO: Yes.
20	MEMBER ROSEN: What do you foresee in
21	terms of plant orders? I mean, or the possibility of
22	plant orders.
23	MR. RAO: We can't get into plant orders,
24	but what we want to do is to be sure that we are ready
25	when the issue comes up, and that is the reason that

1 we started this process obviously, because our feeling 2 was that we need to start getting ready because thee 3 is a lot of stirring and people are showing interest, 4 and we want to make sure that this is the plant of 5 choice. But again you might have heard some 6 7 presentations at the ANS meeting, where a utility 8 person stood up and plotted a chart of costs versus 9 this. The cost of the X-axis is this, and Y-axis, and made a 9-by-9 block thing, and he put different plants 10 on that. 11 12 And the ESBWR was on the low cost block, but he had the risk high because we didn't have some 13 14 of the regulatory approvals. And so that is one that 15 is easy to do. Costs sometimes cannot be fixed, and 16 to come down and you can reduce the risk. So the way the utilities make a decision 17 is cost and risk. 18 We are talking about 19 MEMBER KRESS: 20 economic risk. 21 MR. RAO: Yes, commercial risk. You start 22 on the process --23 MEMBER KRESS: And you may not every get 24 over it. 25 MR. RAO: But definitely not a safety

	240
1	risk.
2	MEMBER KRESS: I knew that couldn't be
3	right.
4	MR. RAO: An economic risk, a commercial
5	risk.
6	MEMBER KRESS: Yes, commercial.
7	CHAIRMAN BONACA: Okay.
8	MEMBER WALLIS: And this is no letter or
9	anything like that involved?
10	MEMBER KRESS: I can't see any point for
11	a letter at this point, at this time. I think we are
12	just getting our feet wet on this certification
13	process, and it is a good start.
14	I think we know a lot now and know what
15	the process is, and I don't know when the right time
16	for a letter from us is, unless you guys have heard
17	something that you think is pathological about this.
18	MEMBER WALLIS: Well, the thing is, this
19	is a very optimistic and impressive presentation, and
20	it is also that the time scale has not been distorted,
21	and you stayed within your time.
22	And the thing that I just don't know yet
23	is if there are technical issues. If there are some
24	sort of major things that we are going to have to
25	think about. We just don't know yet.

they would lie in the realm of has there been enough testing to qualify TRACG, and does TRACG do the job. MEMBER WALLIS: That's right. MEMBER KRESS: And I don't think we know enough about the test results. We know a lot about the program now to make a judgment. MEMBER WALLIS: We don't know the quality of the documentation yet. MEMBER KRESS: We have not looked at it very closely. MEMBER WALLIS: And if the quality is too bad, we just won't read beyond page 2 or something. MEMBER SIEBER: Well, the road map is going to be the SER. MEMBER KRESS: I think the SER is it. MEMBER SIEBER: So whatever we do, we are going to do after we see a draft SER. MEMBER WALLIS: Well, we are going to have to look at some documentation before we see the SER. MEMBER SIEBER: That's right. MEMBER KRESS: Oh, yeah, we will have to read some of this, but at this point I see nothing pathological that requires us MEMBER WALLIS: It is conceivable that	1	MEMBER KRESS: Well, clearly if there are,
MEMBER WALLIS: That's right. MEMBER KRESS: And I don't think we know enough about the test results. We know a lot about the program now to make a judgment. MEMBER WALLIS: We don't know the quality of the documentation yet. MEMBER KRESS: We have not looked at it very closely. MEMBER WALLIS: And if the quality is too bad, we just won't read beyond page 2 or something. MEMBER SIEBER: Well, the road map is going to be the SER. MEMBER KRESS: I think the SER is it. MEMBER SIEBER: So whatever we do, we are going to do after we see a draft SER. MEMBER WALLIS: Well, we are going to have to look at some documentation before we see the SER. MEMBER SIEBER: That's right. MEMBER KRESS: Oh, yeah, we will have to read some of this, but at this point I see nothing pathological that requires us	2	they would lie in the realm of has there been enough
MEMBER KRESS: And I don't think we know enough about the test results. We know a lot about the program now to make a judgment. MEMBER WALLIS: We don't know the quality of the documentation yet. MEMBER KRESS: We have not looked at it very closely. MEMBER WALLIS: And if the quality is too bad, we just won't read beyond page 2 or something. MEMBER SIEBER: Well, the road map is going to be the SER. MEMBER KRESS: I think the SER is it. MEMBER SIEBER: So whatever we do, we are going to do after we see a draft SER. MEMBER WALLIS: Well, we are going to have to look at some documentation before we see the SER. MEMBER SIEBER: That's right. MEMBER KRESS: Oh, yeah, we will have to read some of this, but at this point I see nothing pathological that requires us	3	testing to qualify TRACG, and does TRACG do the job.
enough about the test results. We know a lot about the program now to make a judgment. MEMBER WALLIS: We don't know the quality of the documentation yet. MEMBER KRESS: We have not looked at it very closely. MEMBER WALLIS: And if the quality is too bad, we just won't read beyond page 2 or something. MEMBER SIEBER: Well, the road map is going to be the SER. MEMBER KRESS: I think the SER is it. MEMBER SIEBER: So whatever we do, we are going to do after we see a draft SER. MEMBER WALLIS: Well, we are going to have to look at some documentation before we see the SER. MEMBER SIEBER: That's right. MEMBER KRESS: Oh, yeah, we will have to read some of this, but at this point I see nothing pathological that requires us	4	MEMBER WALLIS: That's right.
the program now to make a judgment. MEMBER WALLIS: We don't know the quality of the documentation yet. MEMBER KRESS: We have not looked at it very closely. MEMBER WALLIS: And if the quality is too bad, we just won't read beyond page 2 or something. MEMBER SIEBER: Well, the road map is going to be the SER. MEMBER KRESS: I think the SER is it. MEMBER SIEBER: So whatever we do, we are going to do after we see a draft SER. MEMBER WALLIS: Well, we are going to have to look at some documentation before we see the SER. MEMBER SIEBER: That's right. MEMBER KRESS: Oh, yeah, we will have to read some of this, but at this point I see nothing pathological that requires us	5	MEMBER KRESS: And I don't think we know
MEMBER WALLIS: We don't know the quality of the documentation yet. MEMBER KRESS: We have not looked at it very closely. MEMBER WALLIS: And if the quality is too bad, we just won't read beyond page 2 or something. MEMBER SIEBER: Well, the road map is going to be the SER. MEMBER KRESS: I think the SER is it. MEMBER SIEBER: So whatever we do, we are going to do after we see a draft SER. MEMBER WALLIS: Well, we are going to have to look at some documentation before we see the SER. MEMBER SIEBER: That's right. MEMBER KRESS: Oh, yeah, we will have to read some of this, but at this point I see nothing pathological that requires us	6	enough about the test results. We know a lot about
of the documentation yet. MEMBER KRESS: We have not looked at it very closely. MEMBER WALLIS: And if the quality is too bad, we just won't read beyond page 2 or something. MEMBER SIEBER: Well, the road map is going to be the SER. MEMBER KRESS: I think the SER is it. MEMBER SIEBER: So whatever we do, we are going to do after we see a draft SER. MEMBER WALLIS: Well, we are going to have to look at some documentation before we see the SER. MEMBER SIEBER: That's right. MEMBER KRESS: Oh, yeah, we will have to read some of this, but at this point I see nothing pathological that requires us	7	the program now to make a judgment.
MEMBER KRESS: We have not looked at it very closely. MEMBER WALLIS: And if the quality is too bad, we just won't read beyond page 2 or something. MEMBER SIEBER: Well, the road map is going to be the SER. MEMBER KRESS: I think the SER is it. MEMBER SIEBER: So whatever we do, we are going to do after we see a draft SER. MEMBER WALLIS: Well, we are going to have to look at some documentation before we see the SER. MEMBER SIEBER: That's right. MEMBER KRESS: Oh, yeah, we will have to read some of this, but at this point I see nothing pathological that requires us	8	MEMBER WALLIS: We don't know the quality
MEMBER WALLIS: And if the quality is too bad, we just won't read beyond page 2 or something. MEMBER SIEBER: Well, the road map is going to be the SER. MEMBER KRESS: I think the SER is it. MEMBER SIEBER: So whatever we do, we are going to do after we see a draft SER. MEMBER WALLIS: Well, we are going to have to look at some documentation before we see the SER. MEMBER SIEBER: That's right. MEMBER KRESS: Oh, yeah, we will have to read some of this, but at this point I see nothing pathological that requires us	9	of the documentation yet.
MEMBER WALLIS: And if the quality is too bad, we just won't read beyond page 2 or something. MEMBER SIEBER: Well, the road map is going to be the SER. MEMBER KRESS: I think the SER is it. MEMBER SIEBER: So whatever we do, we are going to do after we see a draft SER. MEMBER WALLIS: Well, we are going to have to look at some documentation before we see the SER. MEMBER SIEBER: That's right. MEMBER KRESS: Oh, yeah, we will have to read some of this, but at this point I see nothing pathological that requires us	10	MEMBER KRESS: We have not looked at it
bad, we just won't read beyond page 2 or something. MEMBER SIEBER: Well, the road map is going to be the SER. MEMBER KRESS: I think the SER is it. MEMBER SIEBER: So whatever we do, we are going to do after we see a draft SER. MEMBER WALLIS: Well, we are going to have to look at some documentation before we see the SER. MEMBER SIEBER: That's right. MEMBER KRESS: Oh, yeah, we will have to read some of this, but at this point I see nothing pathological that requires us	11	very closely.
MEMBER SIEBER: Well, the road map is going to be the SER. MEMBER KRESS: I think the SER is it. MEMBER SIEBER: So whatever we do, we are going to do after we see a draft SER. MEMBER WALLIS: Well, we are going to have to look at some documentation before we see the SER. MEMBER SIEBER: That's right. MEMBER KRESS: Oh, yeah, we will have to read some of this, but at this point I see nothing pathological that requires us	12	MEMBER WALLIS: And if the quality is too
going to be the SER. MEMBER KRESS: I think the SER is it. MEMBER SIEBER: So whatever we do, we are going to do after we see a draft SER. MEMBER WALLIS: Well, we are going to have to look at some documentation before we see the SER. MEMBER SIEBER: That's right. MEMBER KRESS: Oh, yeah, we will have to read some of this, but at this point I see nothing pathological that requires us	13	bad, we just won't read beyond page 2 or something.
MEMBER KRESS: I think the SER is it. MEMBER SIEBER: So whatever we do, we are going to do after we see a draft SER. MEMBER WALLIS: Well, we are going to have to look at some documentation before we see the SER. MEMBER SIEBER: That's right. MEMBER KRESS: Oh, yeah, we will have to read some of this, but at this point I see nothing pathological that requires us	14	MEMBER SIEBER: Well, the road map is
MEMBER SIEBER: So whatever we do, we are going to do after we see a draft SER. MEMBER WALLIS: Well, we are going to have to look at some documentation before we see the SER. MEMBER SIEBER: That's right. MEMBER KRESS: Oh, yeah, we will have to read some of this, but at this point I see nothing pathological that requires us	15	going to be the SER.
going to do after we see a draft SER. MEMBER WALLIS: Well, we are going to have to look at some documentation before we see the SER. MEMBER SIEBER: That's right. MEMBER KRESS: Oh, yeah, we will have to read some of this, but at this point I see nothing pathological that requires us	16	MEMBER KRESS: I think the SER is it.
MEMBER WALLIS: Well, we are going to have to look at some documentation before we see the SER. MEMBER SIEBER: That's right. MEMBER KRESS: Oh, yeah, we will have to read some of this, but at this point I see nothing pathological that requires us	17	MEMBER SIEBER: So whatever we do, we are
to look at some documentation before we see the SER. MEMBER SIEBER: That's right. MEMBER KRESS: Oh, yeah, we will have to read some of this, but at this point I see nothing pathological that requires us	18	going to do after we see a draft SER.
MEMBER SIEBER: That's right. MEMBER KRESS: Oh, yeah, we will have to read some of this, but at this point I see nothing pathological that requires us	19	MEMBER WALLIS: Well, we are going to have
MEMBER KRESS: Oh, yeah, we will have to read some of this, but at this point I see nothing pathological that requires us	20	to look at some documentation before we see the SER.
read some of this, but at this point I see nothing pathological that requires us	21	MEMBER SIEBER: That's right.
pathological that requires us	22	MEMBER KRESS: Oh, yeah, we will have to
	23	read some of this, but at this point I see nothing
25 MEMBER WALLIS: It is conceivable that	24	pathological that requires us
	25	MEMBER WALLIS: It is conceivable that

1	some of us in reading the documentation may come up
2	with significant points.
3	MEMBER KRESS: Yes.
4	MEMBER WALLIS: I mean, we don't want to
5	just wait until November.
6	MEMBER KRESS: No, the sooner they know
7	this, the better, if there is such a thing.
8	MEMBER WALLIS: But if we did have points
9	that we need to delve into, can we communicate with
10	the staff?
11	MEMBER KRESS: Yes, definitely. I think
12	it is incumbent on us to get started reviewing the
13	TRACG documentation.
14	MEMBER ROSEN: And how about the test
15	documentation?
16	MEMBER KRESS: And the test documentation.
17	MEMBER ROSEN: How do we get this stuff?
18	Do you make it available to the staff?
19	MEMBER KRESS: We have a CD of it.
20	MEMBER ROSEN: Does it contain all the
21	test reports?
22	MEMBER KRESS: Well, I don't know if all
23	of them are there, but there were a lot of them there.
24	MR. CARUSO: Steve, this is Ralph Caruso.
25	I believe that includes everything. Everything that

1	the staff has, all the members have. It is all on
2	that CD.
3	MEMBER ROSEN: Okay.
4	MR. CARUSO: I understand that there are
5	some members that have a problem opening some files,
6	and we will talk to you about that. We will figure
7	out how to deal with that.
8	MR. RAO: And that is a 400 page report on
9	that valve.
10	MEMBER ROSEN: And it is on the CD, Ralph
11	tells me?
12	MR. RAO: Yes.
13	MEMBER ROSEN: I have not opened the CD or
14	even tried yet. But I will.
15	MEMBER SIEBER: I did.
16	MEMBER KRESS: Unless you guys have got
17	more to say, I guess I will turn it back to you.
18	CHAIRMAN BONACA: Thank you. All right.
19	Thank you very much for the presentation. It was very
20	informative. With that, we will now take a break
21	until 3:00 p.m.
22	(Whereupon, at 2:41 p.m., the meeting was
23	recessed and resumed at 3:05 p.m.)
24	CHAIRMAN BONACA: The meeting is called
25	back to order. The next item on the agenda is the

1 Expert Elicitation in Support of Risk-Informing 10 CFR 2 50.46, and that is -- I see here Dr. Shack. Well, as most of you are 3 MEMBER SHACK: 4 aware, there was certainly an effort to develop a risk 5 informed alternative to the present maximum LOCA break size, and the staff is looking at ways to characterize 6 7 LOCA frequencies. I think eventually we will have an SRM 8 9 that directs you to a reconciliation of LOCA frequency distributions based on service data, probablistic 10 11 fraction mechanics. 12 And since one has a very, fortunately one has a very weak database for large 13 14 break LOCA events, expert elicitation to somehow 15 converge the results and get some handle on it. they are in the midst now of their expert elicitation, 16 17 and Robert Tregoning is going to give us an update of how they are going about the expert elicitation. 18 19 And we have a number of very elicit 20 members who are highly experienced in this arcane art. 21 MR. TREGONING: That is what I am banking 22 on. 23 MR. NEWBERRY: Before Rob gets going, I am 24 Scott Newberry from the Office of Research, Risk Assessment staff, and Rob's presentation, like Dr. 25

1 Shack said, is focused on the expert elicitation of a 2 much larger activity to risk-informing 10 CFR 50.46. 3 And as was indicated, there is a recent 4 March SRMs which many of you may have read. 5 quite an SRM, and I think I just wanted to put some context on the briefing here. 6 7 There is considerable activity wrapping up now as a result of the SRM. Eileen McKenna is here in 8 9 case you have questions or thoughts on the rule making, which is beginning to pick up as I said. 10 11 So there are staff on the NRR working on 12 all aspects of the rule, as is my staff in research. And all three divisions are thinking about what a rule 13 14 would look like. 15 The industry is working as well. was a meeting just here this last month with licensees 16 17 and NEI, where they are thinking of submitting material that would relate to other aspects of the 18 rule, and considerations of the loss of off-site power 19 20 requirement in the rule. 21 And these interactions will proceed. 22 I just wanted to comment that there is a lot of aspects going into 50.46. Eileen and Hossein are here 23 24 in case the committee wants to ask a question that

might be outside of Rob's area. He is focusing on the

1 expert elicitation and I am sure that we are going to 2 be here quite a few times talking about all of these 3 aspects. So we are glad to be here. 4 MR. TREGONING: Thanks, Scott. As both 5 Scott and Bill mentioned, it is a very broad and challenging effort that the Office of Research and NRR 6 7 are undertaking, and today we are really looking at a piece of that effort. 8 It is a piece that we have been looking at 9 for quite some time, and so technically we have been 10 11 thinking about it for a while, and we have been 12 planning and developing issues and frameworks, and things like that, to deal with the specific issues. 13 14 So this seemed like a really opportune 15 time given where we were in the schedule, and given people's interest, to come in and discuss at least one 16 17 very important technical phase in the project. Certainly not the only, but one of the 18 19 necessary technical phases in the process, and this is 20 an expert elicitation that we are conducting 21 of this broader effort look support to at 22 redevelopment of a full spectrum of LOCA frequencies 23 that we would use to support this risk-informed 24 reevaluation effort.

So I don't want to forget Lee, who is also

here. So any messy statistical or elicitation questions, I am just going to cede the floor at that point, and maybe duck into the hallway get Lee up here to answer those.

So I will be fielding any easy and general questions and any specific questions, Lee is back here to handle the really tough ones. Just an update of

The last time we came in to talk about this was a little over a year ago, May of 2002. This was a combined subcommittee meeting, Materials Thermal hydraulics and the PRA folks, and we told you about the interim LOCA frequency elicitation effort that we had recently finished.

what you all have heard just to refresh everyone's

memories, and what's happened since the last briefing?

This first effort was in support of the ECCS reliability-feasibility study that was really one of the initial components that kicked off the 10 CFR 50.46 effort. So we focused primarily on this interim solicitation, and how we conducted it, and what the results were.

But we also gave you some of the broader plans that we had at the time for redefining the LOCA break size. We discussed conceptually at least the elicitation, and I got some good feedback from ACRS at

the time.

We certainly tried to incorporate and implement as much of that feedback as had been possible. So this was really a good fundamental building meeting that we had last year.

But really even prior to last year, we have been talking about and thinking about this all the way back, a couple of years back, back in March of 2001, when I think we were first here talking about the technical reasons of why we needed to go about doing this LOCA reevaluation.

So what has happened since May 2002, and I am just going to highlight a couple of the milestones right now, and we will certainly go into much more detail about all of these milestones throughout the presentation.

But some of the more significant things. We have actually selected our expert panel and facilitation team that are going to be conducting and participating in the elicitation.

We have had the kick-off meeting for the elicitation effort. This was February 2 through 4 of this year. Again, these are roughly chronological order. So this was done in about November, and this was in February.

As Scott mentioned, in March, we had the SRM issued on the Option 3 plan for risk informing 10 CFR 50.46, Appendix K and GDC-35, of which the LOCA redefinition was one of four pieces of that.

And certainly a focus of the SRM, if you look at the SRM, as many of you have, even though LOCA redefinition is only again 1 of 4 of the areas that is being evaluated in this risk-informed reevaluation, it occupied about 80 to 90 percent of the SRM, with a lot of very specific direction from the Commission.

So the Commission has obviously some very strong view points and very detailed view points on how we needed to proceed in this area. So this was an important milestone, and it focused to reevaluate the plans that we have up until now, and to make sure that we have incorporated the Commission's direction within those plans.

After that, we have had a second meeting with the expert panel and the facilitation team, where we reviewed some interim results that we had, and this was really a final meeting before we go into the elicitations themselves.

We had this meeting -- this was a two day meeting that was held last month, the first week in June, and then finally since then, and this is again

a broader meeting, and we had a broader public meeting
to discuss the 10 CFR 50.46 effort.
This was a little bit a couple of weeks
after this meeting, and the elicitation was also
discussed there. So a lot has happened since the last
time that we were here.
MEMBER WALLIS: This public meeting, did
you have many representatives other than industrial
people?
MR. TREGONING: We had one didn't we?
Anybody other than industry at the public meeting;
didn't we have one? It was primarily NEI and the
owners groups.
MEMBER WALLIS: Because I would think that
any revision of the LOCA definition would be of
interest to certain sectors of the public.
MR. TREGONING: That public meeting was
broader than that. It was the 50.46 effort in
general. So with that meeting, we only briefly
touched on the elicitation effort. Maybe a couple of
minutes in the meeting.
It dealt more with the SRM in general, and
what the framework of
MEMBER WALLIS: So the timing isn't right
for the public to get involved?

251 1 MR. TREGONING: Well, once we get a little 2 bit further on the elicitation, there will certainly be some more public meetings dealing specifically with 3 4 that. 5 So let me summarize where we are at, and again we will get into more detail on all of these, 6 7 but I just wanted to pick some of the big picture bullets here of where we are at in the elicitation, 8 9 and we will get into a lot of these in much more 10 detail as we go. 11 least -- and this one is my 12 opinion, and I hope that it is management's opinion, and hopefully ACRS opinions at the end of the day, but 13 14 I really feel like the elicitation objective and the 15 approach that we are following is consistent with the quidance that we got in the SRM for the development of 16 17 LOCA frequencies. And I use the term near-term here, because 18 19 if you look at the SRM, and I will put some of the 20 salient features up from the SRM in a minute, they 21 talk about looking only for the next 10 years or so.

So that is what I mean when I say in the near term, sort of now and into the near future for these LOCA frequencies.

The elicitation effort is structured in

22

23

24

1 such a way that we will get LOCA frequencies as a function of leak rate and operating time. Leak rate 2 3 is important. We are looking at the full range of 4 LOCAs, and now just LBLOCAs. 5 We think that it is important from a risk base not to look at just absolute values, 6 7 relatively how these different break sizes compare. So we think we would be remiss if we looked at a 8 9 reevaluation of just the LBLOCA frequency, or LBLOCA regime, and then neglected the small break and medium 10 11 break, because we would not have a consistent 12 comparison at that point. So we are looking at the full range, and 13 14 we are looking at it as the function of an operating 15 time, and we are considering both piping and nonpiping contributions to these LOCA frequencies. 16 17 And both implicitly and explicitly looking at considerations or contributions from all modes of 18 19 plant operations. 20 MEMBER WALLIS: And the wrong piping would 21 be something like the Davis-Bessie event? 22 MR. TREGONING: Yes. 23 MEMBER WALLIS: I think you won't have 24 difficulty if you come up with a conclusion that that 25 was a very unlikely event.

1	MR. TREGONING: Well, if you look one
2	of the big challenges in LOCA estimation in general is
3	that it is always the that the surprises are the
4	one-time events and are the things that make provide
5	the biggest challenge at the end of the day.
6	And we have had a lot of discussion among
7	the panel about that, and that it is not always the
8	things that you know about. It is the things that you
9	don't know about that are really the significant
10	contributors.
11	MEMBER KRESS: I think it was an unlikely
12	LOCA.
13	MEMBER WALLIS: Well, there was a leak.
14	You know what I am getting at.
15	MEMBER KRESS: You are referring to the
16	large break LOCA.
17	MR. TREGONING: I know what you are
18	getting at, and we have done some work and had some
19	discussion among the panel at going back over the
20	operating experience and looking at similar one-time
21	surprise mechanisms, things that have happened once
22	that we don't expect, and we have good reason to
23	expect won't happen again.
24	And to try to provide some rational
25	assessment of their frequency and potential severity.

1 It is not an easy thing to do. I don't want to say 2 And it is certainly a big challenge in that it is. 3 this project. But we have certainly talked about it. 4 MEMBER POWERS: Maybe you will get into 5 this later, but I am puzzled. If you have something actually that occurs that is unexpected, and suppose 6 7 we put that in a class of unexpected things, stuff 8 that happens. 9 And we ask a Baysian how likely is it that 10 unexpected stuff will occur that has a high potential 11 of leading to a large break LOCA, and you come up with 12 a pretty high number don't you? And you can argue perhaps to me that TMI 13 14 will never occur again, but you can't argue to me that 15 small break LOCAs never occurs again. You can argue to me that erosion of a hole in the head by boric acid 16 will not occur, but it is difficult to argue to me 17 that something of similar surprising character will 18 19 never occur again. 20 And you will be glad to provide us with 21 lists of things that degrade materials. 22 Of course, and what we MR. TREGONING: 23 have tried to do in this exercise, at least again very 24 explicitly, is to look at the -- and I will get into

this in more detail, but to look at the areas within

1 the plant that are LOCA sensitive. 2 Think about the systems, and think about 3 the degradation mechanisms that could occur. 4 about the loading that could occur, both typical and 5 surprise, and try to consolidate all that information and make an assessment as to how likely you think that 6 7 those specific sets of conditions are. And given the likelihood that they occur 8 how severe they will be after the fact. 9 MEMBER POWERS: Well, doesn't the Baysian 10 11 estimate give you a floor under your frequency? 12 MR. TREGONING: The thing with the Baysian estimate, what you can do easily I would grant you, is 13 14 that you can add all of the surprise mechanisms that 15 you have had in your PI and get a frequency of surprise mechanisms. 16 17 What is harder is finding the conditional LOCA severity for those given surprise mechanisms. I 18 19 can say that with pretty good certitude because we are 20 trying to analyze Davis-Bessie now for almost a year, 21 and we have put a lot of time and resource into it, 22 and I think we are finally coming closer now to 23 understanding or having an assessment which is

But I don't know that every event has

somewhat realistic.

24

1 received that same scrutiny or it is even possible. 2 MEMBER WALLIS: Well, to go on now, both TMI and David-Bessie had human behavior aspects, and 3 4 I am not quite sure how you are going to take account 5 of that in your studies. MR. TREGONING: Hopefully that will come 6 7 out later. I do talk about that, and we get into that in another slide. So I am sure that we will have some 8 9 more discussion when we get to that point. 10 The other thing that we are looking at is -- and I am calling them emergency faulting, but those 11 12 one-time loads that are unlikely over the operating history of a plant. Things like earthquake loadings, 13 14 and very large transients, and very large water hammer 15 transients. 16 not trying to analyze 17 frequencies in the elicitation, but we are trying to say that given this loading what is the conditional 18 19 LOCA probability. 20 We are specifically avoiding analyzing the 21 frequencies in this effort because there has been 22 again over the history of the nuclear power industry a lot of work looking at analyzing frequencies, and we 23 24 don't want to supersede that. 25 MEMBER WALLIS: And you are avoiding this

1	one?
2	MR. TREGONING: We are not avoiding it.
3	We are trying to what we are trying to do is to
4	provide information or tools that can be combined with
5	that past work to determine the final LOCA
6	probability.
7	MEMBER WALLIS: Does this include
8	sabotage, terrorism, and that kind of thing?
9	MR. TREGONING: What we are doing at this
10	point is again we are defining loadings at a certain
11	magnitude on the pipe. Now how you get that loading
12	could
13	MEMBER WALLIS: Could be caused by a
14	terrorist?
15	MR. TREGONING: be a variety of
16	reasons, okay?
17	
18	included?
19	MR. TREGONING: Again, we are defining the
20	loadings because we are trying to make sure that we
21	have a scope that we can deal with.
22	We have 12 experts, and most of the
23	experts that we have are experts in materials, and
24	they are experts in plant operation, and they are

experts in piping, and they are experts in structural

1 mechanics. They are experts in materials. 2 So we need to make sure that we have a consistent framework that the information that we get 3 4 out also matches their expertise. They are not 5 necessarily experts in terrorist activities, or the likelihood of terrorist activities. 6 7 So all we are trying to do is to give people a framework that they care comfortable, and 8 9 that the experts are comfortable with. And this was one thing that we touched on for touching some of 10 11 these, and again, very unlikely events that could be 12 due to something like an earthquake, like a terrorist 13 event. 14 And one way that the group decided would 15 be the easiest to deal with, and the most consistent 16 with our expertise. 17 MR. NEWBERY: Bob, let me clarify in response to one question. The question was asked are 18 19 we considering terrorism events here. I think that the staff and the Commission is still looking at the 20 21 guidance that we need to give on all rule making 22 activities with respect to terrorism. 23 So I think that the answer is -- I would 24 answer it no at this point. MR. TREGONING: Not specifically. 25

1 MR. NEWBERY: Not specifically, but the 2 SRM certainly has guidance in it relative to that, and how you would implement this rule. 3 4 MR. TREGONING: The other thing that I 5 would add certainly is that there are other efforts within the agency that are specifically addressing 6 7 that question, and that is not to say that we would 8 certainly not to leverage against some of that work as 9 we go on here. 10 CHAIRMAN BONACA: But coming back to 11 Professor Wallis' question, the failure of relevant 12 programs to control age mechanisms, for example, is not included in your evaluation. 13 It is strictly 14 engineering. 15 MR. TREGONING: By relevant programs what 16 do you mean? 17 CHAIRMAN BONACA: Well, nothing from preventing the boric acid control program weld at 18 19 Davis-Bessie. MR. TREGONING: Well, again we look at all 20 21 of these and you will see when we get into the details 22 that we talk about for each of the degradation 23 mechanisms that we have identified, we talk about 24 mitigation and maintenance procedures that you would 25 use to combat that particular degradation mechanism.

1 CHAIRMAN BONACA: Or preventive. 2 MR. TREGONING: Or preventive. Well, yes, to combat or prevent, and there is certainly an aspect 3 4 of all these degradation mechanisms where there is a 5 likelihood that they won't be carried out correctly. That they will be carried out incorrectly 6 7 and the incorrect actions will actually exercebate the problem. So, yes, we will be definitely considering 8 9 that. And again if you look back over 10 11 operating experience like you all had mentioned, and 12 specifically those types of events that are most prominent in terms of the challenges that they give to 13 14 the system. 15 The elicitation itself, and I will talk a little bit about the philosophy and the way that the 16 17 elicitation is structured. We are combining aspects of those groups in individual elicitation as we felt 18 it appropriate again to maximize the information that 19 20 we get out of the experts, and also tailor the 21 elicitation to their strengths. I will talk a little bit about this. 22 23 is separate from the elicitation, and I have got this 24 as sort of an aside if we get to it, but we also have

plans in place to provide confirmatory analysis for

1	the solicitation, as well as develop a methodology
2	that we can use to continually assess LOCA challenges
3	more rigorously and more robustly as they come up in
4	the future.
5	MEMBER APOSTOLAKIS: What does
6	confirmatory analysis for the elicitation mean?
7	MR. TREGONING: It means that the
8	elicitation will that the end result of the
9	elicitation will be essentially LOCA frequencies as a
10	function of break size.
11	MEMBER APOSTOLAKIS: And are you going to
12	confirm that?
13	MR. TREGONING: We would like to confirm
14	that by using some actual modeling, probablistic
15	modeling. And if we get to that and the problem is
16	that the probablistic modeling is going to take
17	obviously a while to develop.
18	MEMBER APOSTOLAKIS: But the experts may
19	have already used that model?
20	MR. TREGONING: Many of the experts have
21	used models. There is no such model that is as
22	comprehensive as what we are in the process of
23	developing.
24	We have been working on developing
25	predictive tools in this area for 30 or more years.

1	Bill Shack can give a much better history than me.
2	But they tend to be focused on a few different
3	systems, a few different mechanisms. We have never
4	really tried to combine things.
5	MEMBER APOSTOLAKIS: Why have you guys
6	dropped the word opinion? When you say expert
7	elicitation now, is the elicitation expert, or are you
8	eliciting experts? Shouldn't it be expert opinion on
9	your elicitation, or is it too much
10	MR. TREGONING: I knew that I was never
11	going to make you happy.
12	MEMBER SHACK: We are on Viewgraph Number
13	4 of 29.
14	MR. TREGONING: Yes. And I will apologize
15	up front if the terminology that I use is confusing.
16	MEMBER APOSTOLAKIS: Shouldn't it be an
17	expert opinion on this thing?
18	MR. TREGONING: Expert opinion? We are
19	trying to get the opinions out of the expert, and me
20	being a non-expert in elicitation terminology, I might
21	offend you with some of the terminology that I have
22	used.
23	MEMBER APOSTOLAKIS: I just make a quick
24	comment.
25	MR. TREGONING: Okav. I hesitated putting

1	this up there, but I figured that I had to do it, and
2	the purpose is not to parse the SRM language, which we
3	could spend the rest of the time that we have doing.
4	But to just put this up there. I pulled out about the
5	five salient points of the SRM that are related to
6	LOCA frequency evaluation.
7	And what I want to do is to use this as a
8	framework for how we think we are meeting this
9	guidance, and I am going to spend most of the talk
10	talking about this, and conducting this practical
11	reconciliation of LOCA frequency distributions by
12	expert use of service data, the SRM, and expert
13	elicitation.
14	This is what Bill used in his opening
15	remarks. As I am talking about this, I want to
16	MEMBER FORD: Excuse me, but who gave you
17	that first bullet? Was that the instructions that you
18	got from the SRM?
19	MR. TREGONING: Yes, these are from the
20	SRM.
21	MEMBER FORD: Well, who is the technical
22	person who gave you that guidance?
23	MR. TREGONING: Again, it is the
24	Commission.
25	MEMBER FORD: Well, the reason that I am

1	asking the question is that if you take the use of
2	service data from all of the various environment
3	systems that we have in light water reactors, you will
4	have just a random scatter of data. And I fail to see
5	how you will ever make any expert draw any conclusion
6	from that.
7	MEMBER KRESS: That is making sense.
8	CHAIRMAN BONACA: Let's give him a chance.
9	MEMBER FORD: Well, I see nothing there in
10	that 1, 2, and 3. I see nothing at all about the
11	prediction of the time dependent creation of the
12	amount of degradation. There used to be spot checks,
13	and I got a crack of such and such a length after a
14	certain time in some random no?
15	And that is how I expect service data.
16	That at a certain time I found a crack in the steam
17	generator.
18	MEMBER SHACK: Well, that is certainly
19	important to know, but it is not to say that between
20	1, 2, and 3 you don't cover that all, Peter.
21	MEMBER FORD: Probablistic fracture
22	mechanics is just mechanics, and it does not tell you
23	anything about the creation of the damage.
24	MEMBER SHACK: Sure it does.
25	MEMBER FORD: Sure it doesn't.

1	MEMBER SHACK: It depends on how you do
2	it. If you build it into it, it does.
3	MEMBER FORD: Okay. Carry on.
4	MR. TREGONING: I don't know if I can
5	carry on after that. For most of what we will be
6	doing it will be addressing this point that Peter
7	found so distasteful.
8	MEMBER APOSTOLAKIS: I have a question,
9	too.
10	MR. TREGONING: Sure.
11	MEMBER APOSTOLAKIS: Why do you need to
12	reconcile it? I mean, somebody gives you high
13	numbers, and somebody else low numbers?
14	MR. TREGONING: Of course.
15	MEMBER APOSTOLAKIS: And who does what?
16	MR. TREGONING: It depends. This has been
17	one of the historical problems. You see people coming
18	in and usually using either service data or what they
19	claim to be service data, or probablistic fracture
20	mechanics, where they model something.
21	It is technically the same system. You
22	could get results that are easily and I am not
23	making this up, but 10 orders of magnitude different.
24	People laugh, but that is not uncommon. And Peter is
25	shaking his head. That is a common occurrence.

MEMBER APOSTOLAKIS: I understand that for
materials that is an increase of two orders in PRA?
MR. TREGONING: So getting these guys in
the same room without killing each other is also a
good objective of this expert elicitation.
MEMBER APOSTOLAKIS: So the experts then
are giving more reasonable results or we don't know?
MR. TREGONING: Well, we don't know
because they have not given us their results yet. But
that is one of the prime reasons that we are doing the
elicitation, because of this guidance.
MEMBER ROSEN: Can we get off of this
slide?
CHAIRMAN BONACA: We are on page four and
we have quite a ways to go.
MR. TREGONING: I will go to 29, and I am
happy with that. So we are ready to move on then?
Okay, good. This is the general approach that we are
using to address the Commission guidance, and we have
got essentially a four-prong approach.
Again, I am going to focus mainly on the
expert elicitation, although I have got a couple of
slides at the end that talk specifically about this.
I have touched on these already.
Again, we are making sure that we have a

fundamental and consistent assessment of the operating experience. We have constructed expert elicitation to reevaluate these LOCA frequencies and to develop a relationship between leak rates and break size, and frequency, for all LOCA events.

And we are using this not just to give us this relationship, but also to provide some fundamental input that we can use in this computer code development.

Why are we doing this? This is our confirmatory analysis. We want to develop I think, and I am not trying to be egotistical, but I think if we are successful, one of the first codes to hopefully combine operating experience and PFM insights together.

That is a challenge. It is not easy to do obviously, but that is the goal. That is what we are shooting for. We also within this code, we want to explicitly consider again LOCA contributions to piping, and pmn-piping components, and most importantly look at how merging degradation mechanisms could evolve and what challenges they give to the system.

Theoretically if a code was mature enough, something like Davis-Bessie, you would get a hint of

it, and if you have got good enough models built into the code, you can assess the challenges much more quickly than we have been able to do with Davis-Bessie.

And then the fourth piece is as important as the code development, but making sure that we have tools that we can do a continual assessment, and one of the things that we are doing here is we are developing LOCA precursor databases, and building on existing pipe failure databases to incorporate also non-piping failure statistics.

And of course the other thing that we always try to do in research is identify merging degradation mechanisms and conduct the appropriate anticipatory research to assess the LOCA significance.

So the rest of this is going to be focused on that first point that Peter brought up. How are we going to combine these three areas of operating experience, probablistic fracture mechanics, through the detailed solicitation, to give us what we are looking for with this spectrum frequency for both piping and non-piping contributions.

MEMBER FORD: And you are going to give us an example of what a formal solicitation will be provided? It will be data, or will it be opinions, or

1	whatever it will be.
2	MR. TREGONING: It will be both, and there
3	will be data and there will be opinion.
4	MEMBER FORD: And there will be
5	algorithms, prediction algorithms.
6	MR. TREGONING: No, not so much. Not the
7	elicitation. WE will assess for each expert how they
8	arrived at their opinions, okay? So they will be
9	describing their predicted algorithms, but an output
10	will not be a predictive algorithm from this exercise.
11	MEMBER FORD: Okay.
12	MR. TREGONING: It is important to
13	understand how people are arriving at their opinions.
14	MEMBER FORD: I agree.
15	MR. TREGONING: I think that we have
16	caught a lot of this
17	MEMBER SHACK: Why don't you just skip
18	ahead to nine so just we know what you are doing on
19	your elicitation.
20	MR. TREGONING: Okay. That's fine. The
21	formal approach to the elicitation, and these are the
22	6 or 7 steps that we are following, and I am going to
23	go into detail on each of these.
24	We have selected the panel and the
25	facilitation team, and we have developed technical
	•

1 issues that we want to address, and that includes 2 defining the scope and objectives, and constructing the approach, and determining significant issues. 3 4 We have put a lot of work into quantifying 5 these base-case estimates, and I have a lot of discussion on what these are and why they are 6 7 important within the framework of the elicitation. 8 Essentially, they are going 9 quantitative estimates for well-defined piping conditions. And we will have four sets of estimates, 10 two using primarily PFMM modeling and two using 11 12 analysis of service history. But they will be benchmarked to the same 13 14 service history data. 15 CHAIRMAN BONACA: You mean, two estimates, 16 and you will have two separate teams providing 17 estimates regarding the same set, or --MR. TREGONING: We have four different 18 19 people from the expert panel. CHAIRMAN BONACA: All right. Okay. 20 21 MR. TREGONING: We have developed the 22 conditions from the whole group. The whole group 23 defined how the analysis or what the analysis should 24 try to -- what the objectives should be and the 25 results should be.

1 The four people went off and they 2 collaborated, and so in a sense they acted as a group 3 so that they knew that they were using the same set of 4 operating experience data. 5 And then what you will see at the end of the day is that they will come back, and that is that 6 7 follow-up meeting that they had and presented their 8 results to the expert panel. 9 POWERS: MEMBER When you speak 10 operating data, are you speaking only of nuclear 11 powered systems, or are you also considering other 12 systems? MR. TREGONING: Nuclear. 13 We are only 14 looking at the nuclear experience. 15 MEMBER APOSTOLAKIS: Worldwide? MR. TREGONING: Worldwide, but obviously 16 17 we are heavily focused on the U.S. But obviously the databases that we look at and the insight that we have 18 19 is also pulling in the worldwide experience, and three 20 of the panel members that we have are from overseas. 21 So we also get worldwide experience in that regard. 22 MEMBER POWERS: Is there a reason that you 23 have excluded fuel plant experience? 24 MR. TREGONING: There is many reasons. 25 The materials are quite a bit different, and the

1	operating experiences are different. I would just
2	personally say that they are not consistent enough to
3	try to combine those together.
4	If we did, fossil plants have had LBLOCAs.
5	So I don't know that we would want to do that.
6	MEMBER SHACK: You mean the failure
7	mechanisms are quite different.
8	MR. TREGONING: Yes.
9	MEMBER SHACK: And if you have grade
10	failure of an axial weld seam in a cold fire plant,
11	that has absolutely no relevance to it.
12	MR. TREGONING: And that has been a
13	degradation mechanism that has led to LBLOCAs in
14	MEMBER WALLIS: Now, pipes have failed in
15	nuclear plants from thermal fatigue.
16	MR. TREGONING: Yes.
17	MEMBER WALLIS: And I don't see anything
18	here about thermal. It seems to be all probablistic
19	mechanics people. Yet the cores could well be
20	something that is quite different.
21	MR. TREGONING: Well, again, we have a
22	number of piping system and plant experts on this
23	panel that know about thermal fatigue loading and have
24	experience dealing with thermal heat cracking in surge
25	line primarily, and feed water nozzle and things like

1	that.
2	But I am purposely not talking about
3	specific degradation mechanisms, but if you look at
4	the mechanisms that we have talked about, thermal
5	fatigue is quite prominent and quite an important one.
6	MEMBER WALLIS: Yes.
7	CHAIRMAN BONACA: Now here you must have
8	also used the definition of a LOCA.
9	MR. TREGONING: Yes, and I am going to get
LO	to that, too.
L1	MEMBER FORD: But you are identifying
L2	specific code regulation notes?
L3	MR. TREGONING: Of course. We would be
L4	remiss if we didn't.
L5	MR. GILLESPIE: I thought you just said
L6	now that you weren't.
L7	MR. TREGONING: I was not going to
L8	identify them in this talk. You won't see them in
L9	this talk unless you all ask about them.
20	MEMBER FORD: Could I ask?
21	MR. TREGONING: Of course. Yes.
22	MEMBER FORD: Well, could you just quickly
23	tell us what the degradations are that you are
24	considering?
25	MR. TREGONING: Well, essentially anything

1 that we think is relevant. We have gone through every 2 LOCA sensitive piping and identified the materials and degradation mechanisms which are relevant. 3 4 And they include the whole ball of wax, 5 from fatigue, corrosion, corrosion of any vain, IGSCC, PWSCC, trans-granule or external stress, and chloride 6 7 cracking and corrosion. We have looked at boric acid corrosion, 8 9 and we have talked about thermal fatique, mechanical fatigue, more high cycle vibratory fatigue. 10 11 A whole host of things. Any fact, of course, is 12 important. All the things that people classically think about. 13 14 MEMBER FORD: Well, this is a fairly high 15 level approach then, because from those that you mentioned, there is no way of predicting it. 16 17 MR. TREGONING: I am going to show you the approach and I think you will have a really good sense 18 19 of where we are going once you see the approach. other thing we do is formulate the questions. 20 21 If you look at where are at on the 22 schedule, we are up to about here. We are still doing 23 some little tidying up work in this area, and we 24 formulated our questions, and we are getting ready to

start conducting the individual elicitations.

	273
1	MEMBER APOSTOLAKIS: There was an
2	important bullet on the previous slide that we
3	skipped.
4	MR. TREGONING: Which slide is that?
5	MEMBER APOSTOLAKIS: You are educating the
6	experts as a group, but you are eliciting
7	individually.
8	MR. TREGONING: That's correct.
9	MEMBER APOSTOLAKIS: That is a key element
10	here.
11	MR. TREGONING: Yes.
12	MEMBER APOSTOLAKIS: So that everybody
13	comes to the same understanding of the issues, but
14	then you have individual
15	MR. TREGONING: Yes.
16	MEMBER APOSTOLAKIS: Are you going to show
17	us the names of the experts?
18	MR. TREGONING: I was not going to show
19	you the names, but I will tell you the names.
20	MEMBER APOSTOLAKIS: Okay. When?
21	MR. TREGONING: Are you asking for them
22	now?
23	MEMBER APOSTOLAKIS: Are we? Yes.
24	MR. TREGONING: Would you like their
25	affiliations, too? Bruce Bishop of Westinghouse; Vic
l	I

1	Chapman, formerly of Rolls Royce; Gary Wilkowski, of
2	EMC Squared, formerly of Bechtel; Guy Deboo, who is
3	with Exelon; Sam Ranganath, formerly of GE; Pete
4	Riccardella, from Structural Integrity Associates.
5	Let me think. Karen Gott from SKI; Helman
6	Schulz of GRS; David Harris, and Bengt Lydell of Aaron
7	Engineering; and Bill Galyean of INEEEL. I think that
8	is it. And Fred Simmon of INEEL. We have Exelon and
9	Westinghouse.
LO	MEMBER SHACK: But Westinghouse was not a
11	utility person the last time I checked.
L2	MR. TREGONING: Well, industry
L3	participation.
L4	MEMBER SHACK: Well, Guy Deboo is
L5	industry. He is a utility.
L6	MR. TREGONING: Exelon, yes.
L7	MEMBER APOSTOLAKIS: Graham, do you
L8	recognize any names that would be an expert on the
L9	thermal fatigue
20	MEMBER WALLIS: You have no academics?
21	MR. TREGONING: We have no academics.
22	MEMBER WALLIS: No one to keep you honest?
23	These are all people wrapped up in the nuclear
24	business?
25	MR. TREGONING: Yes.

1	MEMBER WALLIS: Seriously.
2	MR. TREGONING: Yes.
3	MEMBER SHACK: But only one of them an
4	owner, with any kind of owner perspective. Like owner
5	of these assets.
6	MR. TREGONING: I would argue that
7	Westinghouse, and Exelon, and GE, have similar
8	perspectives.
9	MEMBER WALLIS: Now I think that this
10	could be a contentious list for a public forum
11	eventually. You are going to have to defend the
12	MEMBER SHACK: Why don't you go to your
13	next slide which discusses the panel selection.
14	MR. TREGONING: Yes, we spent a lot of
15	time on the panel. It is not easy to do obviously.
16	MEMBER APOSTOLAKIS: So the academics were
17	not selected is what it says.
18	MR. TREGONING: We looked at people from
19	across the board, there is no doubt, including
20	academia. The difficulty with this panel is because
21	of the range of technical specialties that are
22	required, we were really looking for broad-based
23	people, because we wanted the most well-founded panel
24	we thought we could get. These are not all the
25	specialties that we looked for, but these are some of

the primary ones.
We eliminated a lot of very good people
who we thought were too narrow, because we were
looking for people that were, again, who had broad
experience in a lot of relevant technical areas.
Because again what we were trying to do
was in general boost the overall knowledge of the
panel itself and keep it very broad so that the
discussions could be fruitful.
If we had a bunch of specialists, and we
had one specialist in each area, we never would have
gotten anywhere I don't believe.
MEMBER APOSTOLAKIS: Who is your
facilitation panel?
MR. TREGONING: The facilitation panel is
myself, Lee Abramson, Alan Kuritzky, Bennett Brady and
Paul Scott of Bechtel; and Ken Jaquoy of he is
formerly an industry consultant, and now independent
consultant.
MEMBER APOSTOLAKIS: Except for Lee, has
anybody else been involved in a elicitation?
MR. TREGONING: I don't think so.
MEMBER APOSTOLAKIS: This agency has
sponsored major efforts in the past, especially in the

seismic area, and couldn't you get one of those guys

1	to participate as a facilitator?
2	MR. TREGONING: Well, when we picked the
3	facilitation team, we wanted to make sure that we had
4	substantive experts that matched these fields also.
5	MEMBER APOSTOLAKIS: And normative.
6	MR. TREGONING: Right, and Lee is our
7	normative expert.
8	MEMBER APOSTOLAKIS: And so he is the only
9	one?
10	MR. TREGONING: Right. So, yes, we could
11	have, but we did focus on making sure that we had
12	appropriate substantive experts. Do you disagree?
13	MEMBER WALLIS: Well, I am just baffled by
14	the whole idea that there are normative and
15	substantive experts. but go on.
16	MEMBER APOSTOLAKIS: Normative is a guy
17	who is familiar with the process, and the issues
18	related to the process of what you should be, and what
19	the pitfalls are. You look at Lee. This is a guy.
20	MR. TREGONING: But you don't have to
21	define it. Just look at Lee.
22	MEMBER APOSTOLAKIS: And substantive guys,
23	these are stress analysts.
24	MEMBER WALLIS: People who know something,
25	right?

1 MEMBER APOSTOLAKIS: And know something 2 about the subject itself, but not the process 3 necessarily. 4 MEMBER ROSEN: I am astounded and entirely 5 dismayed by the idea that you have so few of the asset owners on this, and you said that industry includes 6 7 And let me give you an analogy. 8 If you were about to constitute an expert panel on some issue of great significance to the 9 airline industry, and had no one representing the 10 11 airlines, or one person representing the airlines, I 12 think that a priority would be to discount the answer. What is your response to that? How could 13 14 you have possibly put this together this way? 15 MR. TREGONING: The expert panel, and the panel was known to people in the industry, and we also 16 17 solicited names from the industry. 18 MEMBER WALLIS: That's the problem. 19 CHAIRMAN BONACA: No, I don't think it is 20 Wait a minute now. a problem. 21 MR. TREGONING: Do you have a suggestion 22 of either a person or an entity? 23 MEMBER ROSEN: Give me 30 seconds and I 24 would, sure. MEMBER KRESS: Are you implying that these 25

experts are biased in their opinion?
MEMBER ROSEN: Of course, I am. It is not
only implying, but I am suggesting that they should.
That is exactly what experts do. They come to the
question with their biases from their experience and
points of view.
CHAIRMAN BONACA: Well, I would expect
that people from Westinghouse or GE, which really
relate all their work to a real class of plants, et
cetera, would in fact have more insight of plant
specific individual companies.
MEMBER ROSEN: I disagree.
CHAIRMAN BONACA: And who deal with pipe
systems for a full generation of plants, and they deal
with all the utilities and all the problems that they
have. So I personally think that there is sufficient
have. So I personally think that there is sufficient representation there for the industry, insofar as
representation there for the industry, insofar as
representation there for the industry, insofar as expertise to have this kind of elicitation.
representation there for the industry, insofar as expertise to have this kind of elicitation. MEMBER ROSEN: I disagree respectfully of
representation there for the industry, insofar as expertise to have this kind of elicitation. MEMBER ROSEN: I disagree respectfully of course, Mr. Chairman.
representation there for the industry, insofar as expertise to have this kind of elicitation. MEMBER ROSEN: I disagree respectfully of course, Mr. Chairman. CHAIRMAN BONACA: Yes, I understand. And
representation there for the industry, insofar as expertise to have this kind of elicitation. MEMBER ROSEN: I disagree respectfully of course, Mr. Chairman. CHAIRMAN BONACA: Yes, I understand. And I respectfully disagree with your point of view. I

1 handle a problem like this. I mean, the first guy you 2 call is Riccardella. 3 MEMBER ROSEN: Of course, but that has 4 nothing to do with the constitution of this panel. 5 And I have already said my point of view, is that if you were an airline that you would have some people at 6 7 the end of the operating chain, the food chain, who would be part of this process and who could later on 8 9 say, yes, I was part of it and I agree, or this makes 10 sense overall. They have not done that. 11 MEMBER APOSTOLAKIS: Well, when it says 12 operating mitigation practices, do you think that the current panel members are very familiar with those? 13 14 Is that the expertise of the utility person would 15 have? MEMBER ROSEN: Well, yes, that is one thing 16 17 for sure. MEMBER SIEBER: Those would be things like 18 19 chemical treatment and those are developed by the 20 vendors. MEMBER ROSEN: Off normal circumstances 21 22 that occur. 23 I don't find MEMBER SIEBER: that 24 offensive. MEMBER APOSTOLAKIS: Defensive. 25

1	MEMBER ROSEN: Offensive.
2	MEMBER APOSTOLAKIS: Oh, offensive.
3	MEMBER SIEBER: I am not offended.
4	MEMBER APOSTOLAKIS: Because the way you
5	were speaking and sitting down
6	MEMBER SHACK: Well, we are on Slide 10 of
7	29, and we are heading towards four o'clock. So maybe
8	we will just register that note and move on.
9	MEMBER KRESS: That would be unusual
10	wouldn't it?
11	MEMBER SHACK: I think we can have mixed
12	opinions int he panel as to whether it is a problem.
13	MR. TREGONING: As we move through the
14	process, we certainly will be getting feedback, and
15	the feedback will be welcome, as it always is, from
16	all sources. So if we get some feedback that causes
17	us to go back and revise some of these things for very
18	good reasons, we are certainly open.
19	This is not a closed process and it is not
20	a process necessarily that when we are finished and
21	the panel comes in with the final result that it is a
22	done deal.
23	MEMBER ROSEN: I understand that you are
24	not offended if I don't like your process.
25	MEMBER FORD: Bill, I don't know how you

feel about this, but it seems to me though that this
topic is of such importance that it should be done
correctly. I am ont saying that it is not being done
incorrectly, but there is obviously a lot of
MEMBER SHACK: Can I disagree with that,
Peter?
MEMBER FORD: Well, there is a lot of
opinions around the table. I think that before too
long there should be another try committee, M&M
thermal hydraulics subcommittee meeting for a day and
discuss this.
Once you have got some more or have moved
off the starting block, then
MEMBER SHACK: Well, they are off the
starting block.
CHAIRMAN BONACA: They are already down to
the 5th or 6th bullet.
MEMBER SHACK: But perhaps we should think
about a subcommittee meeting here, but we are moving
or they are moving right along. They have a schedule
to meet.
MR. TREGONING: SEM is aggressive and so
we have no choice.
MEMBER SIEBER: I suggest that we do that
here, too, and move right along.

1 MR. TREGONING: Okay. We covered the 2 first bullet and the next thing I am going to look at 3 is how we develop the technical issues. 4 talked a little bit about this already. The first 5 thing we looked at was developing the scope and objectives for the panel. 6 7 Again, I have brought this up many times, but again we are developing piping and non-piping 8 9 passive system LOCA frequencies as a function of creating an operating time, and we are looking up 10 11 until the end of the license extension period. MEMBER WALLIS: 12 That seems to be to be LOCA frequency is not a function of leak 13 14 rate. 15 MR. TREGONING: Why not? MEMBER SHACK: Break size. 16 17 Break size. MR. TREGONING: But break size has been built on leak rate historically if you 18 19 go back to 11-50. The leak rate determines the plant 20 responses. 21 CHAIRMAN BONACA: And I asked the question 22 before the definition, and I am sure that you will 23 give it to me, but really what I had in my mind before 24 was like an event at VCsummer, where you had a leak,

and would it be part of your database that you have to

	286
1	look at?
2	MR. TREGONING: Yes.
3	CHAIRMAN BONACA: And I imagine it would
4	be, right?
5	MR. TREGONING: Of course.
6	CHAIRMAN BONACA: I would like to know how
7	it gets to be into that given that the definition of
8	LOCA is one that
9	MEMBER SHACK: Any precursor that could
10	lead to a LOCA is obviously
11	MR. TREGONING: That is a precursor event.
12	MEMBER SHACK: His LOCA database is very
13	sparse.
14	CHAIRMAN BONACA: I can wait on the
15	question.
16	MEMBER SHACK: One or two, and we would
17	not need to be here anymore.
18	MR. TREGONING: That's right. That's
19	exactly right.
20	CHAIRMAN BONACA: Thank you.
21	MR. TREGONING: It is a good thing that it
22	is sparse. We are looking at determining these
23	distributions for the topical plant operating cycle
24	and history,and again like I mentioned, we are
25	estimating conditional probability distributions for

1	these rare events, including seismic and other large
2	unexpected
3	MEMBER APOSTOLAKIS: Wait a minute. You
4	estimate conditional LOCA probabilities?
5	MR. TREGONING: Yes. I had a bullet on
6	this earlier.
7	MEMBER APOSTOLAKIS: And the experts do
8	that?
9	MR. TREGONING: Yes. The experts would do
10	that.
11	MEMBER SHACK: This is a conditional
12	probability. If you wham it this hard, this is the
13	chance that it is going to bust.
14	MR. TREGONING: They are not experts in
15	the frequencies of these events. But they are experts
16	on if you were given that event what would happen. So
17	it is well beyond the capabilities of the panel to
18	give the full LOCA probability distributions for these
19	rare things.
20	But it can be combined with other work
21	that has been done in the past to give you that. So
22	you have been trying to get the definition and I
23	finally made it there to the definition.
24	CHAIRMAN BONACA: No, I already had the
25	answer anyway.

1	MR. TREGONING: Can I move on?
2	CHAIRMAN BONACA: Go ahead.
3	MR. TREGONING: We have six categories of
4	LOCAs that we are looking at. Initially, we have
5	tired them to the leak rate threshold, and why do we
6	do that? Well, there is historical reasons for that.
7	That is how we have always done it.
8	MEMBER SHACK: I don't call a hundred-
9	thousand gallons a leak rate.
10	MR. TREGONING: A LOCA rate.
11	MEMBER KRESS: That is a fire hose and a
12	hearse anyway.
13	MR. TREGONING: We have six categories of
14	LOCA, the first three of which are consistent with the
15	historical definitions of a small break, medium break,
16	and large break LOCA.
17	And all we have done here is we have
18	further partitioned the large break LOCA size, and
19	this is the problem that we have had all along.
20	MEMBER WALLIS: Why do you use this absurd
21	unit of gpm when you have got steam coming out of this
22	hole?
23	MR. TREGONING: Well, you can measure
24	that. When I say a leak rate, this is really the rate
25	of the makeup system essentially.

1 CHAIRMAN BONACA: In the beginning. 2 MR. TREGONING: Right. There are very many 3 MEMBER WALLIS: different gallons at that temperature than you do at 4 5 the leak. MR. TREGONING: Right. But we tried to be 6 7 consistent and that is why this is the makeup rate. So we partitioned the large break size and again, to 8 9 examine trends that happen when we get up to larger break size. 10 11 Of course, when you get to this big guy, 12 that is essentially that you are only talking about failures of the largest pipes in the largest pipes in 13 14 the plants. So this gets at our design basis right 15 here, and it gives us a narrow focus on just those 16 design basis type accidents. 17 The other thing that we have done, which I have not shown, but we have gone back and looked at 18 some of the earlier correlations between leak rate and 19 20 break size, and we have reevaluated --21 MEMBER WALLIS: I thought leak was a 22 dribble, and you try to figure out what is the 23 frequency of a LOCA as it is related to leaks. 24 are not saying that at all. You are saying that LOCA

frequency is a function of slow rate out the break.

1	MEMBER SIEBER: Right.
2	MR. TREGONING: Right.
3	MEMBER WALLIS: I thought what you meant
4	was that you detect a leak and it is dripping. What
5	is the chance now that the pipe is going to break.
6	MEMBER SHACK: That's not what he meant.
7	MR. TREGONING: That is not what I meant
8	at all.
9	CHAIRMAN BONACA: They extended the
10	definition.
11	MR. TREGONING: This has been typically
12	what has been called a LOCA. The leak has not been
13	called a LOCA because it is within the makeup capacity
14	of the plant. Some people have called them very small
15	LOCAs over time, but we have never really analyzed it.
16	MEMBER WALLIS: This is absurd. LOCA size
17	based on, and what do you mean by that? The size of
18	the hole based on the flow rate?
19	MR. TREGONING: Yes, the size of the hole
20	based on the flow rate, yes.
21	MEMBER WALLIS: Then it has nothing at
22	this point to do with frequency?
23	MR. TREGONING: It has nothing at this
24	point to do with frequency.
25	MEMBER APOSTOLAKIS: The PRA definition of

1	the large LOCA is which one?
2	MR. TREGONING: This one.
3	MEMBER APOSTOLAKIS: Greater than 5000?
4	MR. TREGONING: Yes.
5	MEMBER APOSTOLAKIS: So that is what, 8
6	inches?
7	MR. TREGONING: It depends on the system,
8	but you are looking at 6 to 8 inches. It depends on
9	the plant, and it depends on where the break is
10	located, but it has always historically been about 6
11	inches.
12	MEMBER SHACK: Close enough for a PRA.
13	MEMBER APOSTOLAKIS: And we have
14	confidence that the experts can make a distinction
15	between something that is 4, 5, 6, categories 4, 5,
16	and 6? I mean, something that they can distinguish?
17	MR. TREGONING: What happens here is that
18	when you go up in leak rate, you effectively eliminate
19	systems that you have to consider.
20	MEMBER APOSTOLAKIS: So they are not
21	really thinking in terms of 25,00 gpm or 100,000.
22	They are thinking in terms of what does it really have
23	to break to get there.
24	MR. TREGONING: Yes. We have developed a
25	correlation between leak rate and break size that the

1	experts are using. So I didn't show this, because
2	this is how the panel developed it.
3	MEMBER APOSTOLAKIS: Call it LOCA rate.
4	Leak is really
5	MEMBER WALLIS: You only need to call it
6	frequency prediction. Nobody cares about this
7	MEMBER SHACK: No, frequency is a function
8	of size.
9	MR. TREGONING: You have to care about
10	that.
11	MEMBER SHACK: It makes a big difference.
12	MEMBER APOSTOLAKIS: Size does matter
13	here.
14	CHAIRMAN BONACA: That is the end point,
15	right?
16	MEMBER WALLIS: Well, let's move on.
17	MR. TREGONING: And we are looking at
18	three time periods. The current time period, which we
19	are at about an average of 25 years of operating
20	experience, and the design life, and then the design
21	life and extension.
22	So this is how the experts this is how
23	we generally classified the issues which affect LOCAs,
24	and this is inaccurate in a sense, because I don't
25	show safety culture in this, but you will see later

1	how we roll in safety culture.
2	MEMBER APOSTOLAKIS: Safety culture.
3	MR. TREGONING: How we try to roll it in.
4	MEMBER APOSTOLAKIS: What is your name
5	again? Actually, Abramson.
6	(Laughter.)
7	MR. TREGONING: You know Lee, and I can't
8	get away with that. I didn't say safety culture.
9	This is how we are dealing with the total LOCA
LO	contribution. We split them as a group into passive
L1	and active system LOCAs.
L2	This is of course where we really have
L3	service history data. Now, the elicitation is only
L4	focusing on the passive system LOCA, but obviously in
L5	the final numbers that we develop, we have to go back
L6	and add up the relevant active system LOCA
L7	contributions in.
L8	And for some sizes these are probably
L9	going to be probably dominant.
20	MEMBER APOSTOLAKIS: So where there at the
21	bottom do you have the time element in the sense that
22	something can be arrested before it becomes very bad?
23	MR. TREGONING: The time element is really
24	in all of this. It is in all of this.
25	MEMBER ADOSTOLAKIS: But let's say that I

1	am looking at aging mechanisms there at the bottom,
2	and so I may have lots of accelerated corrosion, and
3	it is a mechanism on a certain time scale, but they
4	may catch it.
5	So all that stuff is there or are the
6	experts thinking exclusively in terms of the aging
7	mechanism.
8	MR. TREGONING: Time is in here and time
9	is also in materials, and that if you
10	MEMBER APOSTOLAKIS: But what do the
11	experts know about all of this?
12	MEMBER SHACK: The experts think about how
13	long it takes to fail a thing by a given mechanism,
14	and how many changes you have to find it. What are
15	your chances of finding it, and all of that is sort of
16	rolled into the process.
17	MEMBER APOSTOLAKIS: And they are experts
18	at all that stuff?
19	MEMBER SHACK: That's why you have a range
20	of experts, but yes, they are all sort of framed to
21	think that way. That is how piping stress analysts
22	and fracture mechanics guys think.
23	MEMBER APOSTOLAKIS: Are these people
24	happy?
25	MR. TREGONING: Happy in the PRA world, I

1 think. 2 MEMBER APOSTOLAKIS: No, they can't be. MEMBER FORD: Now just to come back to my 3 4 original outburst. I think I can understand now how 5 you are dealing with it, because you said -- I was thinking of trying to do this continuously, and you 6 7 are saying no. I am asking Karen Gott, for instance, do you think that that piping system, a 28 inch 8 scheduled piping in a BWR will last under the current 9 operating conditions of normal water chemistries, and 10 11 being quite specific, will it last 25 years. 12 And you are just asking her that question, and she says yes, no, and you say, well, why. And so 13 14 is that the way it is working? 15 MR. TREGONING: Similar to that. Lee, do you want to jump in here or do you want me to do it? 16 17 He was getting ready to come out of the chair. figured I would call on him anyway. 18 19 MR. ABRAMSON: Lee Abramson, Research. 20 Essentially what we are going to be asking the experts 21 in their quantitative judgment is to make relative, 22 relative comparisons. 23 No one is going to be asked to make any

absolute number, and everything is going to be based

relative to base cases, and particular things which

24

they have some experience with, small break LOCAs, and things int he base case.

That is why we spent a great deal of effort in developing base cases which would be presumably understood in the same way by all of the experts. And then each of the experts are going to be asked to make comparisons to the base case.

And in particular, we are going to go through the range, and we are going to say, okay, consider a medium break LOCA, however you define it, and say how do you expert the frequency of this to compare with, say, a small break LOCA, and same material, same degradation mechanisms, and so on and so forth.

So we are asking them to make relative comparisons in the LOCA frequency under specific conditions, and we are going to try to compare as much as we possibly can, apples with apples.

So that experts in their own minds are only going to have to say make a comparison juggling maybe one thing at a time, rather than all things together. That is the general philosophy of this whole expert elicitation, is for the quantitative estimates, and to make relative numbers compared to things which they feel are pretty well established and

1	pretty well understood, namely the base cases.
2	MR. TREGONING: And in which we have
3	attempted to quantify. So that links back to the
4	quantifying.
5	MEMBER FORD: So of the 12 members that
6	you have, not all of them know a lot about stress
7	corrosion cracking?
8	MR. TREGONING: Correct.
9	MR. ABRAMSON: Correct.
10	MEMBER FORD: Or not a lot of them know
11	about the (inaudible).
12	MR. TREGONING: Correct.
13	MEMBER FORD: And so the experts who are
14	experts in those particular areas, will their answers
15	have a specific weighting compared with the others?
16	MR. ABRAMSON: Well, we are certainly
17	giving each expert the option of opting out of a
18	process that they feel that they don't really know
19	very much about it. That is another reason, of
20	course, for having a relatively large panel, because
21	then hopefully we will be able to get enough useful
22	answers from enough people on the panel so that we
23	will have some estimate of the uncertainly.
24	And we are explicitly asking each expert
25	for uncertainties on each of their answers. So if

1 somebody is particularly uncertain about it, it will 2 show up in his responses. 3 MEMBER APOSTOLAKIS: But, Lee, if the 4 evaluation of these bottom boxes there requires more 5 than one kind of expertise, why are you eliciting the experts individually? Wouldn't it be better to do it 6 7 in subgroups? You just mentioned that you will have a 8 guy who understands the degradation mechanisms, and 9 somebody else who understands the intervention, or 10 11 preventive measures and so on. So it would seem to me 12 that putting it in subgroups would make more sense. So you have a group of people who -- a 13 14 subgroup who understands everything that is going on 15 with respect to this particular issue. MR. ABRAMSON: Well, our basic idea is to 16 use the individual elicitation, because that is a way 17 to try to minimize the particular group dynamics that 18 19 you might get from a group. 20 And also I think it is very important here 21 to try to have the results reflect as much as possible 22 the real scientific uncertainty therein in these 23 answers. 24 MEMBER APOSTOLAKIS: Well, the biases, 25 Lee, that we are talking about that are in group

dynamics refer to groups of experts who are more or less experts of the same things. In other words, if I am looking only at flow accelerated corrosion, and I have five experts for that subject, and then one of them may dominate.

But the value of having a group, that value comes to the surface if you are in a situation where the expertise now, the experts compliment each other. So nobody will dominate really in that case, because I will respect your opinion, and you will respect mine.

So this is something that is really important I think to the elicitation process.

MR. ABRAMSON: I am not quite sure how to answer that. Part of the answer may be, first of all, as Rob suggested, we are trying to get people with a broad range of experience, so that they are not just narrowly expert in one particular aspect.

So that could be part of a response to yours. How well this will work out, I can't say. And another thing is that we are trying to break down -- I don't think that Rob is going to have the time to do this, but if you look at the question, there are literally probably hundreds of questions that we are going to be asking, and the reason that there are so

1	many is because we try to ask them about extremely
2	specific situations.
3	And presumably in doing this, we will be
4	able to tap on their expertise as it applies to the
5	situations and to the degradation mechanisms, for
6	example, and something that they are familiar with.
7	I think how successful we are going to be
8	in this will probably I would expect that we would
9	probably have a pretty good sense of this after we get
10	through the elicitations.
11	MEMBER APOSTOLAKIS: Try it both ways.
12	Nobody is stopping you from doing that.
13	MR. ABRAMSON: Pardon me?
14	MR. TREGONING: Well, when we analyze it,
15	we will certainly analyze it both ways.
16	MEMBER APOSTOLAKIS: Anyway, I have a
17	point here, a different one. What is the purpose of
18	the presentation today? We are not writing a letter
19	are we?
20	MEMBER SHACK: We had not planned on
21	writing a letter. If the committee feels that there
22	is something that we need to address, then that is
23	something, but a letter was not planned.
24	MEMBER APOSTOLAKIS: Okay.
25	MEMBER SHACK: This was to inform the

1 committee how the process was going, and to get some 2 input from it. So when the answer comes back to us, 3 we --MEMBER APOSTOLAKIS: Well, I propose the 4 5 following. It is obvious that there is great interest in this by most of us, and this is of course one of 6 7 the most important issues that the agency is looking at these days, right, 50-46 eventually. 8 9 I am not sure that we are going to get 10 very far today. We are going to have a hell of a lot 11 of questions. We have important letters to write. I 12 propose that we schedule a subcommittee meeting soon, because you really have to see the details here to 13 14 appreciate what is going on to be convinced, and you 15 can't do that in a full committee meeting, 16 terminate this as soon as we can. 17 MR. SNODDERLY: George, the purpose of this meeting now was because it is such an aggressive 18 19 schedule, and the elicitation is scheduled to be done 20 by September, and when we looked at our schedule about 21 when we could schedule meetings. 22 So what we would like to try to do today 23 is to make you aware -- we have made you aware of who

is on the panel, and now to make you aware generally

of what elicitation questions are.

24

1	But I think it is going to be very
2	difficult for us to have much interaction before the
3	elicitation has been completed, and compiling the
4	results.
5	MEMBER APOSTOLAKIS: I think we are
6	achieving today something that is really unfair to the
7	NRC staff. You are creating negative attitudes on the
8	part of the members because they don't see the details
9	to appreciate what is going on.
10	MEMBER FORD: Well, I would not call them
11	negative, George, but they are inquiries, aggressive
12	inquiries.
13	MEMBER APOSTOLAKIS: Well, I mean are
14	concerned.
15	MEMBER SHACK: As a practical matter
16	though, George, if we have the subcommittee meeting,
17	we won't be able to have a committee response to the
18	subcommittee meeting.
19	We can have the subcommittee meeting for
20	information, but
21	MEMBER APOSTOLAKIS: But this is an
22	extremely important topic. I mean, we can't say that
23	the committee cannot get involved in the excruciating
24	details because they have to do it by September 5th.
25	MEMBER SHACK: Well can we continue with

1	this presentation and we will
2	MEMBER APOSTOLAKIS: I would hate to go
3	beyond the allotted time.
4	MEMBER SHACK: Well, we're not.
5	MEMBER APOSTOLAKIS: Because there are
6	very important things to deal with.
7	MEMBER WALLIS: Are we going to be asked
8	to approve the results?
9	MEMBER APOSTOLAKIS: Eventually you will
10	be asked to do that, and to write a letter, yes. And
11	then at that time we will be told that we have already
12	done it. What do you want us to do, select new
13	experts? And I say that is unfair to the staff as
14	well.
15	MEMBER WALLIS: Well, we can say that our
16	role comes after the experts have done their work.
17	MEMBER FORD: But it is unfair to come in
18	at the end.
19	MEMBER SHACK: It is 4:09.
20	MEMBER APOSTOLAKIS: Yes, but this is an
21	important issue.
22	MR. TREGONING: And let me say that we are
23	planning to have the elicitations done by the end of
24	September and then we are looking to have a feedback
25	meeting from the experts where they get to see the

1 results, and they get to see how we analyzed it and at 2 least get the experts themselves to say if they agree in the process and in the final results. 3 4 MEMBER WALLIS: So it is not finished? 5 MR. TREGONING: No, it is not finished, and we are either telling people when they come in to 6 7 do their elicitation that if there is more information that comes out later, and they want to change their 8 9 answers, they can certainly do that. MEMBER WALLIS: I don't think we have to 10 be managing this process. We can look at the final 11 12 results. MEMBER APOSTOLAKIS: 13 14 MR. TREGONING: And the way that we have 15 tried to structure the elicitation is we have tried to 16 decompose things; issues, topics, important 17 contributing factors. And at the end of the day, we roll them all up. 18 19 If there is issues or contributing factors 20 that we have missed, and that you all point out, if 21 there is a flaw that we have missed, I would hope that 22 we could go back and it would be non-fatalistic at that point, and we could essentially address it, and 23 24 see if it makes a difference or not, and then come

back and present the results.

1 Now the thing that would be harder to do 2 is if we wanted to reconstitute the panel in some way, 3 and if wanted to change who is on the panel. 4 MEMBER ROSEN: Which by the way is what I 5 suggest. MEMBER APOSTOLAKIS: But the process may 6 7 be difficult to change, too. I mean, this idea of providing individual elicitations, after a certain 8 9 point things are pretty costly. So I don't know what 10 to say, but it seems to me that this is one of the biggest issues that the agency is working on.n 11 12 I agree with that. CHAIRMAN BONACA: MEMBER APOSTOLAKIS: And I don't think 13 14 that schedule should be the determining factor here. 15 CHAIRMAN BONACA: Schedule what? The 16 whole program? 17 MEMBER APOSTOLAKIS: Yes. MR. TREGONING: One of the things that I 18 19 will say to try to answer it and to follow up what Lee 20 said, we have combined the group and the individual. 21 The group is providing a lot of combined or background 22 information that the rest of the panel has access to. 23 So if there is a specific area that a 24 panel member does not have expertise in, we have been 25 trying to develop information so that they will have

1	that knowledge.
2	MEMBER APOSTOLAKIS: All I am saying is
3	that we really need to go deeply into this. Now when
4	we are going to do that, I don't know.
5	CHAIRMAN BONACA: Anyway, why don't we let
6	Robert go through.
7	MEMBER SHACK: I would really like you to
8	get to Slide 19.
9	MEMBER SIEBER: Before you leave that one,
10	what is the difference between passive and active
11	systems?
12	MEMBER ROSEN: Yes it would be nice to
13	know what is on this slide.
14	MR. TREGONING: Passive systems are pipes
15	and nozzles, and reactor pressure vessels, and things
16	like that. And active system LOCAs are things like
17	valves, and pump seals.
18	MEMBER SIEBER: You mean actual
19	components?
20	MR. TREGONING: Right. Active components.
21	MEMBER SIEBER: As opposed to passive
22	components?
23	MR. TREGONING: Right.
24	MEMBER SIEBER: Thank you.
25	MEMBER WALLIS: Somebody opens a valve and

1	leaves it open. That is an active
2	MEMBER SIEBER: That is not a LOCA then.
3	MR. TREGONING: That is an active.
4	MEMBER ROSEN: It could be if it is a
5	relief valve.
6	MEMBER SHACK: That is one of the most
7	common LOCAs around.
8	CHAIRMAN BONACA: Exactly.
9	MR. TREGONING: That is an active
10	component. A passive would be a valve body failure,
11	let's say. That would be a passive component.
12	MEMBER WALLIS: I would think active
13	where somebody does something, like opening a letdown
14	system, and letting it run.
15	MR. TREGONING: No, that's active. Active
16	can contribute to a passive component failure.
17	MEMBER APOSTOLAKIS: Change of state.
18	MR. TREGONING: So we have talked about
19	the piping base cases, and so what are they exactly.
20	Well, these have been developed iteratively between or
21	among the facilitation team and the expert panel
22	members.
23	And what the people are doing is that they
24	are you sure you don't want to go to 18 for this?
25	MEMBER SHACK: Well, you already told us

-		-	\sim
		1	8
-		- 1	$^{\circ}$

MR. TREGONING: Not really. I think we need to go back to 18. The base cases we are using to provide anchor. These base cases are very specific variables for piping systems, size, material, loading degradation, and mitigation. We have a very specific set of conditions. We have defined five of them.

And for piping now. These are all for piping at this point; 2 for BWR, and 3 for PWR. We tried to hit some of the most important LOCA sensitive systems and then also mechanisms and loading histories.

So each of these are being -- we are calculating the LOCA frequencies for each set of base case conditions as a function of leak rate and operating time. As I mentioned, we have four panel members individually doing calculations; two using operating experience, and two using PFM.

MEMBER RANSOM: How is historical data factored into this?

MR. TREGONING: Yes, I am going to get to that. In fact, you see it right here. But let me get down there first. We developed these things iteratively like I said. We are evaluating these at three different time periods.

And to get down to how we are using the operating experience, and where we have the most operating experience is in terms of leaking cracks. So we have told each of the four members that are doing their analysis that they have to benchmark their analysis so that you essentially get agreement to the leaking crack frequency that you would get at an average of 25 years, which is essentially where we are now.

MEMBER RANSOM: I was thinking more of the chemical industry, and even some of the nuclear industry, where you have accelerated corrosion, and you have pipe ruptures, and so there is a little bit known about their frequency.

MR. TREGONING: There are, but again like I mentioned earlier, we have really tried to limit to nuclear experience only because of the uniqueness of the materials degradation mechanisms, and then also the quality of the materials, and the robustness of the mitigation and maintenance procedures.

So that makes our industry unique enough to I think only look at that specific subsection of results. LOCAs were done in 1400, and in fact they did go -- in fact, a lot of the early LOCA numbers were based on oil and gas transmission piping, simply

because they did not have anything else, and not because they thought it was relevant.

In fact, if you go back to WASH-1400, there is a big disclaimer that says we don't think that this is relevant. However, we have only got a hundred or so years of operating experience, and we don't feel that is enough basis to make a judgment at this point.

So we think we have got enough operating experience now, especially with precursors. We do have pretty good precursor databases, and that is what we have been looking at for the piping.

Another stipulation is we are trying to make sure that all the base case calculations capture the conditions that were established by the panel. The panel determines what these conditions were, and by conditions I mean again the degradation mechanism, the geometry of the material, and the loading conditions.

And along with these base case calculations, we have also done sensitivity analyses using PFM to look at the effect of seismic loading and in-service inspections. So this gets at your question what happens if you miss it, and what happens if you don't. So how the probability of detection and the

1	resolution of the ISI affects it.
2	And look at variability and the loading
3	history. Of course, with PFM, this is a prime driver.
4	MEMBER SHACK: Well, let me just mention
5	for Vice, too, that Mr. Lydell is sort of the industry
6	custodian of the biggest and most complete, and most
7	detailed database on piping cracks. George knows it
8	because it is sort of a PRA.
9	When they need a frequency on something,
10	they go to that.
11	MEMBER APOSTOLAKIS: He also published in
12	my journals.
13	MR. TREGONING: He is okay.
14	MEMBER SHACK: In a sense, you know,
15	service experience is strongly plugged in here.
16	MR. TREGONING: So that is how we do the
17	piping. How do we do the non-piping. Well, we could
18	have done the same thing. We could have chosen
19	several presentative systems and then examined and
20	extrapolated the operating experience through
21	modeling.
22	We did not decide to do that because with
23	non-piping there is a whole or a much bigger range of
24	failure mechanisms that are in play just because you
25	are dealing with things that are not just piping. You

1	are dealing with bolts, and thermal sleeves, and
2	things that are totally different components.
3	So it didn't make sense to pursue this
4	approach any more. So what we are doing here, and
5	what we don't have for non-piping is we don't have the
6	same robust precursor database.
7	We are essentially trying to develop that
8	for leaking and cracking frequencies, and that is
9	something that we are working on quite feverishly as
10	we speak.
11	MEMBER FORD: Would that include cracks L-
12	grade or core shrouds?
13	MR. TREGONING: Core shrouds would not
14	lead to a LOCA.
15	MEMBER FORD: You are absolutely correct.
16	MR. TREGONING: CRDM nozzles.
17	MEMBER ROSEN: Reactor coolant pump casing
18	bolts.
19	MR. TREGONING: Yes. Yes. We talked
20	about a number of bolt failures.
21	MEMBER WALLIS: And the seals on the
22	pumps?
23	MR. TREGONING: Seals we are considering
24	as part of it, and because there is a maintenance plan
25	for seals, we are incorporating those into the active

seals, seal failures, and we are not looking at seal failures. MEMBER WALLIS: Well, thinking about seals, it is not just the seal. It is the cooling system for the seal, and there is a whole chain of events which can fail a seal, and not just the seal itself. Do you have to write a PRA for the seal? MR. TREGONING: Again, we are not explicitly considering the seal, because we will roll it in after the fact. MEMBER WALLIS: But you have to do it some day. MR. TREGONING: Yes, and we will deal with the seal, I think, MEMBER WALLIS: But the thing itself, it is a series of events which leads to the failure, and that is what you have to somehow capture for some of these things. MR. TREGONING: Well, that is all of these things. MEMBER WALLIS: But some of them are simpler than others.
MEMBER WALLIS: Well, thinking about seals, it is not just the seal. It is the cooling system for the seal, and there is a whole chain of events which can fail a seal, and not just the seal itself. Do you have to write a PRA for the seal? MR. TREGONING: Again, we are not explicitly considering the seal, because we will roll it in after the fact. MEMBER WALLIS: But you have to do it some day. MR. TREGONING: Yes, and we will deal with the seal, I think, MEMBER WALLIS: But the thing itself, it is a series of events which leads to the failure, and that is what you have to somehow capture for some of these things. MR. TREGONING: Well, that is all of these things. MEMBER WALLIS: But some of them are
seals, it is not just the seal. It is the cooling system for the seal, and there is a whole chain of events which can fail a seal, and not just the seal itself. Do you have to write a PRA for the seal? MR. TREGONING: Again, we are not explicitly considering the seal, because we will roll it in after the fact. MEMBER WALLIS: But you have to do it some day. MR. TREGONING: Yes, and we will deal with the seal, I think, MEMBER WALLIS: But the thing itself, it is a series of events which leads to the failure, and that is what you have to somehow capture for some of these things. MR. TREGONING: Well, that is all of these things. MEMBER WALLIS: But some of them are
system for the seal, and there is a whole chain of events which can fail a seal, and not just the seal itself. Do you have to write a PRA for the seal? MR. TREGONING: Again, we are not explicitly considering the seal, because we will roll it in after the fact. MEMBER WALLIS: But you have to do it some day. MR. TREGONING: Yes, and we will deal with the seal, I think, MEMBER WALLIS: But the thing itself, it is a series of events which leads to the failure, and that is what you have to somehow capture for some of these things. MR. TREGONING: Well, that is all of these things. MEMBER WALLIS: But some of them are
events which can fail a seal, and not just the seal itself. Do you have to write a PRA for the seal? MR. TREGONING: Again, we are not explicitly considering the seal, because we will roll it in after the fact. MEMBER WALLIS: But you have to do it some day. MR. TREGONING: Yes, and we will deal with the seal, I think, MEMBER WALLIS: But the thing itself, it is a series of events which leads to the failure, and that is what you have to somehow capture for some of these things. MR. TREGONING: Well, that is all of these things. MR. TREGONING: But some of them are
itself. Do you have to write a PRA for the seal? MR. TREGONING: Again, we are not explicitly considering the seal, because we will roll it in after the fact. MEMBER WALLIS: But you have to do it some day. MR. TREGONING: Yes, and we will deal with the seal, I think, MEMBER WALLIS: But the thing itself, it is a series of events which leads to the failure, and that is what you have to somehow capture for some of these things. MR. TREGONING: Well, that is all of these things. MEMBER WALLIS: But some of them are
MR. TREGONING: Again, we are not explicitly considering the seal, because we will roll it in after the fact. MEMBER WALLIS: But you have to do it some day. MR. TREGONING: Yes, and we will deal with the seal, I think, MEMBER WALLIS: But the thing itself, it is a series of events which leads to the failure, and that is what you have to somehow capture for some of these things. MR. TREGONING: Well, that is all of these things. MR. TREGONING: But some of them are
explicitly considering the seal, because we will roll it in after the fact. MEMBER WALLIS: But you have to do it some day. MR. TREGONING: Yes, and we will deal with the seal, I think, MEMBER WALLIS: But the thing itself, it is a series of events which leads to the failure, and that is what you have to somehow capture for some of these things. MR. TREGONING: Well, that is all of these things. MEMBER WALLIS: But some of them are
roll it in after the fact. MEMBER WALLIS: But you have to do it some day. MR. TREGONING: Yes, and we will deal with the seal, I think, MEMBER WALLIS: But the thing itself, it is a series of events which leads to the failure, and that is what you have to somehow capture for some of these things. MR. TREGONING: Well, that is all of these things. MEMBER WALLIS: But some of them are
MEMBER WALLIS: But you have to do it some day. MR. TREGONING: Yes, and we will deal with the seal, I think, MEMBER WALLIS: But the thing itself, it is a series of events which leads to the failure, and that is what you have to somehow capture for some of these things. MR. TREGONING: Well, that is all of these things. MEMBER WALLIS: But some of them are
day. MR. TREGONING: Yes, and we will deal with the seal, I think, MEMBER WALLIS: But the thing itself, it is a series of events which leads to the failure, and that is what you have to somehow capture for some of these things. MR. TREGONING: Well, that is all of these things. MEMBER WALLIS: But some of them are
MR. TREGONING: Yes, and we will deal with the seal, I think, MEMBER WALLIS: But the thing itself, it is a series of events which leads to the failure, and that is what you have to somehow capture for some of these things. MR. TREGONING: Well, that is all of these things. MEMBER WALLIS: But some of them are
the seal, I think, MEMBER WALLIS: But the thing itself, it is a series of events which leads to the failure, and that is what you have to somehow capture for some of these things. MR. TREGONING: Well, that is all of these things. MEMBER WALLIS: But some of them are
MEMBER WALLIS: But the thing itself, it is a series of events which leads to the failure, and that is what you have to somehow capture for some of these things. MR. TREGONING: Well, that is all of these things. MEMBER WALLIS: But some of them are
is a series of events which leads to the failure, and that is what you have to somehow capture for some of these things. MR. TREGONING: Well, that is all of these things. MEMBER WALLIS: But some of them are
that is what you have to somehow capture for some of these things. MR. TREGONING: Well, that is all of these things. MEMBER WALLIS: But some of them are
these things. MR. TREGONING: Well, that is all of these things. MEMBER WALLIS: But some of them are
MR. TREGONING: Well, that is all of these things. MEMBER WALLIS: But some of them are
things. MEMBER WALLIS: But some of them are
MEMBER WALLIS: But some of them are
simpler than others.
MR. TREGONING: I have not found that one
yet unfortunately. Okay. So we are going to use
vet unfortunately. Okay. So we are going

1	these leaking and crack component frequencies as our
2	anchor for our non-piping responses. And then each
3	expert is going to have to determine how to translate
4	that information into meaningful LOCA estimates.
5	So certainly not a trivial exercise, but
6	this is what the experts for the most part, this is
7	what they do for a living.
8	MEMBER APOSTOLAKIS: So in your training
9	session, you train them to think in terms of
10	frequency, or these are experts who have actually used
11	frequency?
12	MR. TREGONING: Like Lee said, we are
13	going to be asking only relative questions.
14	MEMBER APOSTOLAKIS: The training.
15	MR. ABRAMSON: Using relative quantitative
16	judgment.
17	MR. TREGONING: Right.
18	MEMBER APOSTOLAKIS: So all of these guys
19	have worked with probabilities in the past and they
20	understand what it means?
21	MR. ABRAMSON: They understand
22	frequencies, and we are not talking about
23	probabilities. We are talking about frequencies.
24	MEMBER WALLIS: You are not talking about
25	frequencies at all.

1	MR. ABRAMSON: The whole idea here was to
2	try to ask them questions
3	MEMBER WALLIS: It is all probability
4	isn't it?
5	MR. ABRAMSON: The idea was to try to
6	phrase the questions in terms of the experts'
7	expertise, in terms of the systems that they have been
8	working with their whole career.
9	So we tried to frame the questions in
10	terms of extremely specific physical situations,
11	degradation mechanisms, and materials, and so on and
12	so forth, and so that sets the stage.
13	And then we say, all right, you have this
14	situation and compare it to what happened with a small
15	break LOCA or whatever. And the base case is what do
16	you think about the relative frequency, just relative
17	frequency difference. We don't ask them explicitly
18	about probabilities.
19	MEMBER APOSTOLAKIS: You are talking about
20	the base case development here now. So for the base
21	case the experts are asked to come up with
22	frequencies.
23	MR. ABRAMSON: No, the base case
24	MEMBER APOSTOLAKIS: Then they do what you
25	say here.

1	MR. ABRAMSON: was done by specific
2	people, these four people on the panel, who are base
3	case they have experience in developing base cases,
4	and they develop the specific absolute numbers based
5	on their service experience and based on data for the
6	most part isn't it?
7	MR. TREGONING: Well, again, that's what
8	we had the four of them do. They each ran models and
9	predictions, extrapolating the service history
LO	experience to give them LOCA estimates.
L1	So not surprisingly, you have a range of
L2	estimates among the four of them, which in some sense
L3	gives us a measure of uncertainty, too.
L4	MR. ABRAMSON: Right. And each expert on
L5	the panel in the elicitation will be asked to choose
L6	which base case they prefer to anchor towards, to
L7	compare with.
L8	MR. TREGONING: Or they can anchor just
L9	with the conditions.
20	MR. ABRAMSON: Right.
21	MR. TREGONING: And then we will propagate
22	the uncertainty throughout their answers.
23	MEMBER APOSTOLAKIS: Now when you say
24	frequency information into meaningful LOCA estimates,
25	does that include uncertainty, the base case?

1	MR. ABRAMSON: The base case I don't think
2	explicitly includes uncertainties.
3	MR. TREGONING: Again, the base case for
4	non-piping is just going to be leaking and crack
5	component frequency data. So these are accounting for
6	things that have happened.
7	MEMBER APOSTOLAKIS: But you need a base
8	case for a large LOCA don't you?
9	MR. TREGONING: You need to go from this
10	leak and crack
11	MEMBER APOSTOLAKIS: I am telling you we
12	really need a subcommittee meeting.
13	MR. ABRAMSON: I think we are doing this.
14	We have a base case for small LOCAs, and then we are
15	saying, all right, consider the comparable materials,
16	and degradation mechanisms, and what do you think are
17	the chances of a large one.
18	MEMBER APOSTOLAKIS: So the base case is
19	based on data as much as you can.
20	MR. ABRAMSON: Right.
21	MEMBER APOSTOLAKIS: And then you are
22	going to larger
23	MR. TREGONING: Right, using a relative
24	comparison.
25	MEMBER APOSTOLAKIS: That is actually very

1	good.
2	MR. ABRAMSON: What we are doing is we are
3	extrapolating as much as we possibly can from the
4	observed data.
5	MEMBER APOSTOLAKIS: I like that.
6	MEMBER SHACK: But, for example, on the
7	hot-leg, you will have somebody compute a frequency
8	for the break of the hot-leg?
9	MR. TREGONING: For the break of the hot-
10	leg under, and we looked at the hot-leg specifically
11	for PWSCC cracking, but not the hot-leg under every
12	set of conditions, but the hot-leg for PWSCC.
13	MEMBER SHACK: For the PWSCC.
14	MR. TREGONING: Exactly. We will have a
15	set of frequencies.
16	MEMBER ROSEN: A complete break, or a
17	small break?
18	MR. TREGONING: They are looking at the
19	range of breaks.
20	MEMBER ROSEN: You will have them compute
21	a set of these things?
22	MR. TREGONING: Yes, for each leak
23	pattern.
24	MEMBER ROSEN: How likely is it to have a
25	double-ended rupture and presumably you could plot

1	that?
2	MR. TREGONING: They have done all the six
3	LOCA categories that I listed, and for the hot-leg,
4	they could fill in also those numbers. We have had
5	them do it for smaller piping systems, too, where you
6	can only get up to a Category 1, 2, 3, or maybe 4,
7	LOCA.
8	You can't get the bigger ones, but you can
9	get a range of smaller ones. So, yes, that is exactly
10	right. They look at the frequency of small breaks and
11	then all the way up to the largest break possible.
12	MEMBER WALLIS: You have about a half-a-
13	,minute per slide and a minute to wrap up.
14	MR. TREGONING: Bill, tell me where to
15	jump to.
16	MEMBER SIEBER: Tell me about the second
17	bullet.
18	MR. TREGONING: I will be happy to.
19	MEMBER APOSTOLAKIS: You are actually
20	serious.
21	MR. TREGONING: Let me go to this one,
22	because
23	MEMBER SHACK: Hit 22 and 28, and we will
24	call it quits there. This one and then 28.
25	MR. TREGONING: I figured you would want

1	to see 28. These are the areas that we are asking
2	them questions about. We are asking the experts to
3	validate or evaluate the base case and how that
4	evaluation went. Do they agree with the numbers and
5	do they not agree with the numbers. Do they have
6	different numbers that they would like to use.
7	What anchoring set of conditions do they
8	want to use. Then we are asking generic questions
9	about regulatory and utility safety culture. And we
10	had a kick-off meeting and we identified a whole host
11	of issues within here that could affect LOCAs. We
12	decided
13	MEMBER ROSEN: How would this team know
14	anything about utility safety culture? There is only
15	one guy on the team that can have any background.
16	MR. TREGONING: Again, we had
17	MEMBER SIEBER: That is my question.
18	MR. TREGONING: Again, between
19	Westinghouse, and Exelon, and GE
20	MEMBER ROSEN: I'm sorry to laugh, but
21	does Westinghouse know about utility safety culture?
22	MR. TREGONING: Industry safety culture.
23	MEMBER ROSEN: I'm an adult.
24	MEMBER APOSTOLAKIS: Okay. So you got the
25	comment. Let's move on.

MR. TREGONING: 1 So we are asking them 2 generally about these issues, and then we are also 3 asking about again LOCA frequencies for piping and 4 non-piping, and then these conditional probabilities 5 under emergency faulted loads. MEMBER APOSTOLAKIS: 6 Okav. 7 MR. TREGONING: This is 28, and this talks about the passive code development, and so we will be 8 using this to provide confirmatory analysis. 9 objective of this is to determine again the same 10 11 relationship, but to do it computationally as much as 12 possible, and it is a pool that we will be using for continual --13 14 MEMBER APOSTOLAKIS: Excuse me, but why 15 does it have to be confirmatory? Why isn't this an additional piece of information that some super being 16 will combine and blend with the results of the expert 17 opinion in your elicitation exercise? 18 19 MR. TREGONING: Theoretically, it would. 20 MEMBER APOSTOLAKIS: But that is what you 21 will do in fact. I don't think that you are trying --22 your objective here is not to tell the world the 23 experts are good. Your objective is to -- you say, 24 look, I really don't know what the frequency of large

breaks is, but I have a body of knowledge here which

1	is represented by experts.
2	I have a body of knowledge here that is
3	represented by calculational models. I will do both,
4	and then I will sit back and see how I can put them
5	together. If they happen to agree, then great. But
6	if they don't agree, I will have to do something. But
7	when
8	MR. TREGONING: When I used confirmatory,
9	I didn't mean validate, per se.
10	MEMBER APOSTOLAKIS: Don't do it again.
11	MR. TREGONING: I meant exactly what you
12	said.
13	MEMBER APOSTOLAKIS: I know you did.
14	MR. TREGONING: A somewhat independent
15	assessment, although we are using some of the results
16	with the elicitation to feed into our codes, and so
17	they won't be entirely independent.
18	MEMBER APOSTOLAKIS: Fine.
19	MR. TREGONING: But it will be another
20	tool or another approach to evaluate or to get to the
21	same question.
22	MEMBER APOSTOLAKIS: Right. And
23	ultimately perhaps you may want to have another group
24	of experts taking all this information and just saying
25	this is it the technical facilitator integrator

1	MR. TREGONING: Yes. Hopefully I won't be
2	involved in that aspect.
3	MEMBER WALLIS: So this is all written up
4	at the end so that someone can understand it?
5	CHAIRMAN BONACA: Of course.
6	MR. TREGONING: Yes, of course it is
7	written up at the end, and hopefully people will
8	understand that. That has been our goal. In fact, we
9	have been heavily documenting the process as we go.
10	MEMBER WALLIS: I think it is very
11	important for this particular issue that you have a
12	very understandable rationale at the end.
13	MEMBER APOSTOLAKIS: I would like to see
14	actually an example with numbers walking through the
15	whole exercise.
16	MR. TREGONING: Yes. I would have been
17	happy to present that, but given the time
18	MEMBER APOSTOLAKIS: There is no way
19	today, but we should do that well before we have to
20	write a letter.
21	MEMBER SHACK: Let me talk to you about
22	this again, George. We will be discussing this matter
23	again in the future.
24	MEMBER APOSTOLAKIS: But not at the full
25	committee meeting.

1	MEMBER KRESS: No, the subcommittee.
2	MR. TREGONING: I am sure at the full
3	committee we will be discussing it, too.
4	MEMBER SHACK: At the full committee, we
5	will be discussing it, too.
6	MEMBER ROSEN: I think we need a letter.
7	MEMBER APOSTOLAKIS: Now?
8	MEMBER ROSEN: Yes.
9	MEMBER SHACK: Why don't you just finish
10	the slide and we will discuss that.
11	MR. TREGONING: Well, again the approach,
12	we are constructing separate modules for piping and
13	non-piping, and then again these surprise mechanisms
14	that we have talked about.
15	We are trying to couple again through the
16	code PFM modeling with an understanding of operating
17	experience. We want to make sure that the modeling
18	frequencies are scaled based on this operating
19	experience. Again, we will be using insights from the
20	elicitation to focus on the most important systems and
21	mechanisms.
22	And there is a European program called
23	NURBIM that has similar objectives that we will be
24	working with on this effort. And also in terms of our
25	LOCA precursor development, too, there is also

1	international efforts for the development of piping
2	databases that we are part of, and I think we will
3	also look at starting up one for non-piping LOCA
4	precursor events, too.
5	So we are looking at starting up an
6	international effort there, too. So that is it.
7	MEMBER KRESS: I would like to ask you a
8	provocative question. I think this is good stuff, and
9	stuff that needs to be done, and will help us in risk
10	analysis and other places. The question that I would
11	ask is how are you going to use this to help risk
12	informed 10 CFR 50.46?
13	How will it be put to use in risk-
14	informing 10 CFR 50.46, which is the title of this.
15	MR. TREGONING: Do you want me to tackle
16	it? Do you guys want to tackle it?
17	MS. MCKENNA: This is Eileen McKenna, NRR.
18	We have a working group that has been tasked to work
19	on the rule making that would take advantage of the
20	information
21	MEMBER KRESS: This is a question for NRR,
22	you're right.
23	MS. MCKENNA: Yes, and our schedules are
24	running in parallel, and so we are kind of having to
25	figure out what we are going to do with it before we

1 know what we are going to get. 2 But we are trying to deal with the issues that you are also seeing in the SRM about what kind of 3 4 risk cut-off metrics we should be considering, and 5 some of the other considerations that we need to bring to bear in making decisions with respect to what kinds 6 7 of changes might occur as a result of redefining the maximum break size and what kinds wouldn't occur. 8 And those kinds of issues that we are 9 actively working on, and we will be discussing it at 10 11 a future meeting with the committee, but we just are 12 not ready to have that kind of dialogue. MEMBER KRESS: Well, expressly, I was 13 14 hoping you would say that you will not say that given 15 your frequency as a function of leak size that you will determine the contribution of these different 16 sizes to risk, and cut off at a given risk. 17 I am hoping that is not what you want to 18 19 do with it. 20 MS. MCKENNA: We hear you, and that is not 21 our current plan. 22 MR. TREGONING: But realizing that this is 23 just one technical piece, and that research is ongoing

and will be ongoing in looking at integrating this,

assessment

risk

probablistic

with

24

25

thermal

and

1 hydraulic analysis to come up with hopefully a technical basis behind whatever change is envisioned 2 3 for the ECCS rule. 4 MEMBER FORD: I have got a question along 5 somewhat other similar lines. It is my understanding that the rule making, once it is made, is somewhat 6 7 cast in concrete. And yet this particular technology is forever being developed further. 8 9 So in 2 years time when we may have a different perspective of how you predict the future 10 11 behavior of leak rates and the effect on risk, it 12 might be different in 2 years time. Do we have the wherewithal to change the rule? 13 14 MEMBER KRESS: Hopefully you will write 15 the rule so that is accounted for. This is Eileen McKenna 16 MS. MCKENNA: I think if you read the SRM, you will see that 17 some of that concept was already built into that. 18 talks about doing kind of doing a relook of the 19 20 frequencies and potentials for changes, and things 21 having to be undone, and obviously this poses a great 22 challenge for us in regulatory space of how to deal 23 with that kind of a process, which is very different

than what we have done in the past. But that is part

of the SRM also.

24

1	MEMBER FORD: The reg guides can be
2	changed.
3	MS. MCKENNA: yes.
4	MEMBER ROSEN: I would like to say why I
5	think we need a letter.
6	MEMBER SHACK: Is there anything else
7	before I turn it back over to the chairman?
8	CHAIRMAN BONACA: Okay. Thank you for the
9	presentation, and I think at this stage we can go off
10	the record now.
11	(Whereupon, at 4:34 p.m., the meeting was
12	recessed.)
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	
2 E	